

Bill Jennings
California Sportfishing Protection Alliance
3536 Rainier Avenue
Stockton, CA 95204
Tel: 209-464-5067
Fax: 209-464-1028
E-mail: deltkeep@aol.com

Mike Jackson
Law Office of Mike Jackson
P.O. Box 207
429 W. Main Street
Quincy, CA 95971
Tel: 530-283-1007
Fax: 530-283-0712
E-mail: mjatty@sbcglobal.net

VIA: Electronic Submission
Hardcopy to Follow

Andrew Packard
Law Office of Andrew Packard
319 Pleasant Street
Petaluma, CA 94952
Tel: 707-763-7227
Fax: 707-763-9227
E-mail: andrew@packardlawoffices.com

For Petitioner California Sportfishing Protection Alliance

BEFORE THE STATE WATER RESOURCES CONTROL BOARD

In the Matter of Waste Discharge Requirements And Cease & Desist Order For City of Redding Stillwater Wastewater Treatment Facility, California Regional Water Quality Control Board – Central Valley Region Orders No. R5-2007-0058, R5-2007-0059; NPDES No. CA0082589)) PETITION FOR REVIEW

Pursuant to Section 13320 of California Water Code and Section 2050 of Title 23 of the California Code of Regulations (CCR), California Sportfishing Protection Alliance (“CSPA” or “petitioner”) petitions the State Water Resources Control Board (State Board) to review and vacate the final decision of the California Regional Water Quality Control Board for the Central Valley Region (“Regional Board”) in adopting Waste Discharge Requirements (NPDES No. CA0082589) for City of Redding Stillwater Wastewater Treatment Facility, on 21 June 2007. *See* Orders No. R5-2007-0058 and No. R5-2007-0059. The issues raised in this petition were raised in timely written comments.

1. NAME AND ADDRESS OF THE PETITIONERS:

California Sportfishing Protection Alliance
3536 Rainier Avenue
Stockton, California 95204
Attention: Bill Jennings, Executive Director

2. THE SPECIFIC ACTION OR INACTION OF THE REGIONAL BOARD WHICH THE STATE BOARD IS REQUESTED TO REVIEW AND A COPY OF ANY ORDER OR RESOLUTION OF THE REGIONAL BOARD WHICH IS REFERRED TO IN THE PETITION:

Petitioner seeks review of Orders No. R5-2007-0058 and No. R5-2007-0059, Waste Discharge Requirements (NPDES No. CA0082589) for City of Redding Stillwater Wastewater Treatment Facility. Copies of the Orders are attached as Attachment 1 and 2.

3. THE DATE ON WHICH THE REGIONAL BOARD ACTED OR REFUSED TO ACT OR ON WHICH THE REGIONAL BOARD WAS REQUESTED TO ACT:

21 June 2007

4. A FULL AND COMPLETE STATEMENT OF THE REASONS THE ACTION OR FAILURE TO ACT WAS INAPPROPRIATE OR IMPROPER:

CSPA submitted a detailed comment letter on 19 May 2007. That letter and the following comments set forth in detail the reasons and points and authorities why CSPA believes the Order fails to comport with statutory and regulatory requirements. The specific reasons the adopted Orders are improper are

A. **The Order contains numeric Effluent Limitations for alpha BHC, beta BHC and gamma BHC contrary to the Basin Plan water quality objective of “non-detectable” in violation of Federal Regulations 40 CFR 122.44 and California Water Code (CWC) Section 13377.**

The Order, Table 6, contains numeric Effluent Limitations for alpha BHC, beta BHC and gamma BHC contrary to the water quality control plan (Basin Plan) water quality objective of non-detectable. The Basin Plan prohibits total identifiable persistent chlorinated hydrocarbon pesticides to be present in the water column at concentrations detectable within the accuracy of analytical methods approved by USEPA or the Executive Officer. The California Water Code (CWC), Section 13377 states in part that: “...the state board or the regional boards shall...issue waste discharge requirements...which apply and ensure compliance with ...water quality control plans, or for the protection of beneficial uses...” Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the

receiving water. Failure to include an effluent limitation of non-detectable for alpha BHC, beta BHC and gamma BHC in the Order violates 40 CFR 122.44 and CWC 13377.

B. The Order utilized mixing zones to develop limitations for copper, zinc, cyanide chlorodibromomethane and dichlorobromomethane without having conducted a mixing zone analysis as required by the Basin Plan and the SIP and the proposed limitations may therefore exceed water quality standards in violation of Federal Regulations 40 CFR 122.44 and CWC Section 13377.

The Order utilized mixing zones to develop limitations for copper, zinc, cyanide chlorodibromomethane and dichlorobromomethane. The Order, Fact Sheet page F-7, states that the Discharger in attempting to conduct a mixing zone study found that all of the diffuser ports, except one, were plugged. There was no mixing zone study and with only one port operational the discharge is not likely to be completely mixed in the receiving stream.

The Basin Plan, page IV-16.00, requires the Regional Board use EPA's *Technical Support Document for Water Quality Based Toxics Control (TSD)*. The TSD, page 70, defines a first stage of mixing, close to the point of discharge, where complete mixing is determined by the momentum and buoyancy of the discharge. Obviously the wastewater discharge here is not completely mixed in the first stage. The second stage is defined by the TSD where the initial momentum and buoyancy of the discharge are diminished and waste is mixed by ambient turbulence. The TSD goes on to state that in large rivers this second stage mixing may extend for miles. There are drinking water intakes, and proposed intakes, downstream of the wastewater discharge which could be impacted prior to the pollutants from the discharge are completely mixed. The TSD, Section 4.4, requires that if complete mix does not occur in a short distance mixing zone monitoring and modeling must be undertaken.

The extensive SIP, Section 1.4.2.2, requirements for a mixing zone study apply here and must be analyzed before a mixing zone is allowed for this discharge. The proposed Effluent Limitations in the Order are not supported by the scientific investigation that is required by the SIP and the Basin Plan.

SIP Section 1.4.2.2 requires that a mixing zone shall not:

1. Compromise the integrity of the entire waterbody.
2. Cause acutely toxic conditions to aquatic life.
3. Restrict the passage of aquatic life.
4. Adversely impact biologically sensitive habitats.
5. Produce undesirable aquatic life.
6. Result in floating debris.
7. Produce objectionable color, odor, taste or turbidity.
8. Cause objectionable bottom deposits.
9. Cause Nuisance.
10. Dominate the receiving water body or overlap a different mixing zone.
11. Be allowed at or near any drinking water intake.

The Order's mixing zones have not addressed a single required item of the SIP. To the contrary the Sacramento River is already 303d listed as impaired for copper and zinc and the permit appears to indicate that a domestic or municipal water intake may be nearby downstream. A very clear unaddressed requirement (SIP Section 1.4.2.2) for mixing zones is that the point(s) in the receiving stream where the applicable criteria must be met shall be specified in the Order. The "edge of the mixing zone" has not been defined.

The California Water Code (CWC), Section 13377 states in part that: "...the state board or the regional boards shall...issue waste discharge requirements...which apply and ensure compliance with ...water quality control plans, or for the protection of beneficial uses..." Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Failure to include "end of pipe" effluent limitations, since a mixing zone analysis was not conducted, violates 40 CFR 122.44 and CWC 13377.

C. The Order does not contain mass based Effluent Limitations contrary to Federal Regulations and technical advise from EPA.

Section 5.7.1 of U.S. EPA's *Technical Support Document for Water Quality Based Toxics Control* (TSD, EPA/505/2-90-001) states with regard to mass-based Effluent Limits:

"Mass-based effluent limits are required by NPDES regulations at 40 CFR 122.45(f). The regulation requires that all pollutants limited in NPDES permits have limits, standards, or prohibitions expressed in terms of mass with three exceptions, including one for pollutants that cannot be expressed appropriately by mass. Examples of such pollutants are pH, temperature, radiation, and whole effluent toxicity. Mass limitations in terms of pounds per day or kilograms per day can be calculated for all chemical-specific toxics such as chlorine or chromium. Mass-based limits should be calculated using concentration limits at critical flows. For example, a permit limit of 10 mg/l of cadmium discharged at an average rate of 1 million gallons per day also would contain a limit of 38 kilograms/day of cadmium."

Mass based limits are particularly important for control of bioconcentratable pollutants. Concentration based limits will not adequately control discharges of these pollutants if the effluent concentrations are below detection levels. For these pollutants, controlling mass loadings to the receiving water is critical for preventing adverse environmental impacts.

However, mass-based effluent limits alone may not assure attainment of water quality standards in waters with low dilution. In these waters, the quantity of effluent discharged has a strong effect on the instream dilution and therefore

upon the RWC. At the extreme case of a stream that is 100 percent effluent, it is the effluent concentration rather than the mass discharge that dictates the instream concentration. Therefore, EPA recommends that permit limits on both mass and concentration be specified for effluents discharging into waters with less than 100 fold dilution to ensure attainment of water quality standards.”

Federal Regulations, 40 CFR 122.45 (f), states the following with regard to mass limitations:

- “(1) all pollutants limited in permits shall have limitations, standards, or prohibitions expressed in terms of mass except:
 - (i) For pH, temperature, radiation or other pollutants which cannot be expressed by mass;
 - (ii) When applicable standards and limitationa are expressed in terms of other units of measurement; or
 - (iii) If in establishing permit limitations on a case-by-case basis under 125.3, limitations expressed in terms of mass are infeasible because the mass of the pollutant discharged cannot be related to a measure of operation (for example, discharges of TSS from certain mining operations), and permit conditions ensure that dilution will not be used as a substitute for treatment.
- (2) Pollutants limited in terms of mass additionally may be limited in terms of other units of measurement, and the permit shall require the permittee to comply with both limitations.”

Federal Regulations, 40 CFR 122.45 (B)(1), states the following: “In the case of POTWs, permit effluent limitations, standards, or prohibitions shall be calculated based on design flow.”

Traditional wastewater treatment plant design utilizes average dry weather flow rates for organic, individual constituent, loading rates and peak wet weather flow rates for hydraulic design of pipes, weir overflow rates, and pumps.

Increased wet weather flow rates are typically caused by inflow and infiltration (I/I) into the sewer collection system that dilutes constituent loading rates and does not add to the mass of wastewater constituents.

For POTWs priority pollutants, such as metals, have traditionally been reduced by the reduction of solids from the wastestream, incidental to treatment for organic material. Following adoption of the CTR, compliance with priority pollutants is of critical importance and systems will need to begin utilizing loading rates of individual constituents in the WWTP design process. It is highly likely that the principal design parameters for individual priority pollutant removal will be based on mass, making mass

based Effluent Limitations critically important to compliance. The inclusion of mass limitations will be of increasing importance to achieving compliance with requirements for individual pollutants.

As systems begin to design to comply with priority pollutants, the design systems for POTWs will be more sensitive to similar restrictions as industrial dischargers currently face where production rates (mass loadings) are critical components of treatment system design and compliance. Currently, Industrial Pretreatment Program local limits are frequently based on mass. Failure to include mass limitations would allow industries to discharge mass loads of individual pollutants during periods of wet weather when a dilute concentration was otherwise observed, upsetting treatment processes, causing effluent limitation processes, sludge disposal issues, or problems in the collection system.

TMDLs represent a mass loading that may occur over a given time period to attain and maintain water quality standards. Mass loadings from WWTPs are critical to determining individual discharger allocations once a TMDL has been completed.

Mixing zone allowances will increase the mass loadings of a pollutant to a waterbody and decrease treatment requirements. Accurate mass loadings are critical to mixing zone determinations.

In addition to the above citations, on June 26th 2006 U.S. EPA, Mr. Douglas Eberhardt, Chief of the CWA Standards and Permits Office, sent a letter to Dave Carlson at the Central Valley Regional Water Quality Control Board strongly recommending that NPDES permit effluent limitations be expressed in terms of mass as well as concentration.

D. The Order contains an Effluent Limitation for acute toxicity that allows mortality that exceeds the Basin Plan water quality objective and does not comply with Federal regulations, at 40 CFR 122.44 (d)(1)(i).

Federal regulations, at 40 CFR 122.44 (d)(1)(i), require that limitations must control all pollutants or pollutant parameters which the Director determines are or may be discharged at a level which will cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality. The Water Quality Control Plan for the Sacramento/ San Joaquin River Basins (Basin Plan), Water Quality Objectives (Page III-8.00) for Toxicity is a narrative criteria which states that all waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life. This section of the Basin Plan further states, in part that, compliance with this objective will be determined by analysis of indicator organisms.

The Tentative Permit requires that the Discharger conduct acute toxicity tests and states that compliance with the toxicity objective will be determined by analysis of

indicator organisms. However, the Tentative Permit contains a discharge limitation that allows 30% mortality (70% survival) of fish species in any given toxicity test.

The Regional Board has looked hard and long to find some citation as to the source of the limitation that would allow or recommend 10% and 30% mortality, such a find however does not eliminate the more restrictive applicable Basin Plan objective that simply prohibits the discharge from causing mortality in the receiving stream.

For an ephemeral or low flow stream, such as the case here, allowing 30% mortality in acute toxicity tests allows that same level of mortality in the receiving stream, in violation of federal regulations and contributes to exceedance of the Basin Plan's narrative water quality objective for toxicity. Accordingly, the Order must be revised to prohibit acute toxicity in accordance with Federal regulations, at 40 CFR 122.44 (d)(1)(i).

E. The Order does not contain Effluent Limitations for chronic toxicity and therefore does not comply with Federal regulations, at 40 CFR 122.44 (d)(1)(i) and the SIP

Order states that: “On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.” The SIP, Section 4, Toxicity Control Provisions, Water Quality-Based Toxicity Control, states that: “A chronic toxicity effluent limitation is required in permits for all dischargers that will cause, have a reasonable potential to cause, or contribute to chronic toxicity in receiving waters.”

Federal regulations, at 40 CFR 122.44 (d)(1)(i), require that limitations must control all pollutants or pollutant parameters which the Director determines are or may be discharged at a level which will cause, or contribute to an excursion above any State water quality standard, including state narrative criteria for water quality. The Water Quality Control Plan for the Sacramento/ San Joaquin River Basins (Basin Plan), Water Quality Objectives (Page III-8.00) for Toxicity is a narrative criteria which states that all waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life. The Order states that: “...to ensure compliance with the Basin Plan’s narrative toxicity objective, the discharger is required to conduct whole effluent toxicity testing...”. However, sampling does not equate with or ensure compliance. The Tentative Permit requires the Discharger to conduct an investigation of the possible sources of toxicity if a threshold is exceeded.

This language is not a limitation and essentially eviscerates the Regional Board's authority, and the authority granted to third parties under the Clean Water Act, to find the Discharger in violation for discharging chronically toxic constituents. An effluent limitation for chronic toxicity must be included in the Order. In addition, the Chronic Toxicity Testing Dilution Series should bracket the actual dilution at the time of discharge, not use default values that are not relevant to the discharge.

Order is quite simply wrong; by failing to include effluent limitations prohibiting chronic toxicity the Order does not "...implement the SIP". The Regional Board has commented time and again that no chronic toxicity effluent limitations are being included in NPDES permit until the State Board adopts a numeric limitation. The Regional Board explanation does not excuse the Order's failure to comply with Federal Regulations, the SIP, the Basin Plan and the CWC. The Regional Board's Basin Plan, as cited above, already states that: "...waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses..." Accordingly, the Order must be revised to prohibit chronic toxicity (mortality and adverse sublethal impacts to aquatic life, (sublethal toxic impacts are clearly defined in EPA's toxicity guidance manuals)) in accordance with Federal regulations, at 40 CFR 122.44 (d)(1)(i) and the Basin Plan and the SIP.

F. The Order does not contain an Effluent Limitation for ammonia in violation of Federal Regulations 40 CFR 122.44 and California Water Code, Section 13377.

The Order is for a domestic wastewater treatment plant. Domestic wastewater treatment plants, by their nature, receive ammonia in concentrations ranging from 30 mg/l to 60 mg/l and present a reasonable potential to exceed the Basin Plan narrative toxicity water quality objective. Ammonia is toxic to aquatic life in fairly low concentrations. The Central Valley Regional Board has a long established history of including ammonia limitations in NPDES permits based on U.S. EPA's ambient criteria for the protection of freshwater aquatic life, which has established BPTC for POTWs. Failure to operate a wastewater treatment plant in a nitrification mode allows ammonia concentrations to pass through the system. The nitrification process can be a fairly unstable treatment process; even POTWs that employ nitrification should be limited for ammonia to ensure the system is properly operated. The California Water Code (CWC), Section 13377 states in part that: "...the state board or the regional boards shall...issue waste discharge requirements...which apply and ensure compliance with ...water quality control plans, or for the protection of beneficial uses..." Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Where numeric water quality objectives have not been established, 40 CFR §122.44(d) specifies that WQBELs may be established using USEPA criteria guidance under CWA section 304(a), proposed State criteria or a State policy interpreting narrative criteria supplemented with other relevant information, or an indicator parameter. Failure to include an effluent limitation for ammonia in the Order violates 40 CFR 122.44 and CWC 13377.

G. The Order incorrectly cites a DHS letter as stating that secondary treated sewage with an instream dilution ratio of 20-to-1 is protective of the domestic and municipal beneficial uses of the receiving stream.

The Order, Fact Sheet page F-19 No. g, incorrectly cites a April 8, 1999 DHS letter as stating that secondary treated sewage with an instream dilution ratio of 20-to-1 is protective of the domestic and municipal beneficial uses of the receiving stream. The reference to drinking water is properly excluded from a similar Finding in the Fact Sheet, page F-30 No. m. The citation regarding secondary treated sewage with an instream dilution ratio of 20-to-1 being protective of the domestic and municipal beneficial uses is incorrect and should be removed from page F-19. Actually, the Finding should be elaborated to state that DHS has commented on the Stockton and Placer County permits that tertiary treatment plus a dilution ratio of 20-to-1 is protective of the domestic and municipal beneficial uses of the receiving stream. The permit should be amended to state that the level of treatment provided at Redding is not protective of the municipal and domestic beneficial uses of the receiving stream. California Water Code, section 13377, requires that: "Notwithstanding any other provision of this division, the state board and the regional boards shall, as required or authorized by the Federal Water Pollution Control Act, as amended, issue waste discharge and dredged or fill material permits which apply and ensure compliance with all applicable provisions of the act and acts amendatory thereof or supplementary, thereto, together with any more stringent effluent standards or limitations necessary to implement water quality control plans, or for the protection of beneficial uses, or to prevent nuisance."

H. The proposed “advanced secondary” treatment system does not provide Best Practicable Treatment and Control (BPTC) of the discharge which is evidenced by the fact that the discharge cannot meet many of the proposed Effluent Limitations and the level of treatment provided at Redding is not protective of the municipal and domestic beneficial uses of the receiving stream.

As a part of the Antidegradation Policy, Dischargers are required to provide BPTC. The Antidegradation Policy, State Water Resources Control Board Resolution No. 68-16, states that: "Any activity which produces or may produce a waste or increased volume or concentration of waste and which discharges or proposes to discharge to existing high quality waters will be required to meet waste discharge requirements which will result in the best practicable treatment or control of the discharge necessary to assure that (a) a pollution or nuisance will not occur and (b) the highest water quality consistent with the maximum benefit to the people of the State will be maintained." The Antidegradation Policy has been incorporated into the Basin Plan. Waste Discharge Requirements must require that the treatments systems provide BPTC.

5. THE MANNER IN WHICH THE PETITIONERS ARE AGGRIEVED.

CSPA is a non-profit, environmental organization that has a direct interest in reducing pollution to the waters of the Central Valley. CSPA's members benefit directly from the waters in the form of recreational hiking, photography, fishing, swimming, hunting, bird watching, boating, consumption of drinking water and scientific investigation. Additionally, these waters are an important resource for recreational and commercial fisheries.

Central Valley waterways also provide significant wildlife values important to the mission and purpose of the Petitioners. This wildlife value includes critical nesting and feeding grounds for resident water birds, essential habitat for endangered species and other plants and animals, nursery areas for fish and shellfish and their aquatic food organisms, and numerous city and county parks and open space areas.

CSPA's members reside in communities whose economic prosperity depends, in part, upon the quality of water. CSPA has actively promoted the protection of fisheries and water quality throughout California before state and federal agencies, the State Legislature and Congress and regularly participates in administrative and judicial proceedings on behalf of its members to protect, enhance, and restore declining aquatic resources.

CSPA member's health, interests and pocketbooks are directly harmed by the failure of the Regional Board to develop an effective and legally defensible program addressing discharges to waters of the state and nation.

6. THE SPECIFIC ACTION BY THE STATE OR REGIONAL BOARD WHICH PETITIONER REQUESTS.

Petitioners seek an Order by the State Board to:

- A. Vacate Orders No. R5-2007-0058, R5-2007-0059 (NPDES No. CA0082589) and remand to the Regional Board with instructions prepare and circulate a new tentative order that comports with regulatory requirements.
- B. Alternatively: prepare, circulate and issue a new order that is protective of identified beneficial uses and comports with regulatory requirements.

Petitioners, however, request that the State Board hold in abeyance further action on this Petition for up to two years or further notice by Petitioners, whichever comes first. Petitioners, along with other environmental groups, anticipate filing one or more additional petitions for review challenging decisions by the Regional Board concerning the issues raised in this Petition in the coming months. For economy of the State Board and all parties, Petitioners will request the State Board to consolidate these petitions and/or resolve the common issues presented by these petitions by action on a subset of the petitions. Accordingly, Petitioners urge that holding this Petition in abeyance for now is a sensible approach.

7. A STATEMENT OF POINTS AND AUTHORITIES IN SUPPORT OF LEGAL ISSUES RAISED IN THE PETITION.

CSPA's arguments and points of authority are adequately detailed in the above comments and our 19 May 2007 comment letter. Should the State Board have additional questions regarding the issues raised in this petition, CSPA will provide additional briefing on any such questions.

The petitioners believe that an evidentiary hearing before the State Board will not be necessary to resolve the issues raised in this petition. However, CSPA welcomes the opportunity to present oral argument and respond to any questions the State Board may have regarding this petition.

8. A STATEMENT THAT THE PETITION HAS BEEN SENT TO THE APPROPRIATE REGIONAL BOARD AND TO THE DISCHARGERS, IF NOT THE PETITIONER.

A true and correct copy of this petition, without attachment, was sent electronically and by First Class Mail to Ms. Pamela Creedon, Executive Officer, Regional Water Quality Control Board, Central Valley Region, 11020 Sun Center Drive #200, Rancho Cordova, CA 95670-6114.

As CSPA never received a copy of the Notice of Adoption and is unclear as to the proper name and address of the responsible party that should be sent notice of this petition, a true and correct copy of this petition, without attachment, was sent to the Discharger in care of: To Whom It May Concern, City of Redding Stillwater Wastewater Treatment Facility, 6475 Airport Road, Anderson, CA 96007.

9. A STATEMENT THAT THE ISSUES RAISED IN THE PETITION WERE PRESENTED TO THE REGIONAL BOARD BEFORE THE REGIONAL BOARD ACTED, OR AN EXPLANATION OF WHY THE PETITIONER COULD NOT RAISE THOSE OBJECTIONS BEFORE THE REGIONAL BOARD.

CSPA presented the issues addressed in this petition to the Regional Board in a 19 May 2007 detailed comment letter that was accepted into the record.

If you have any questions regarding this petition, please contact Bill Jennings at (209) 464-5067 or Michael Jackson at (530) 283-1007.

Dated: 20 June 2007

Respectfully submitted,



Bill Jennings, Executive Director
California Sportfishing Protection Alliance

Attachment No. 1: Order No. R5-2007-0058
Attachment No. 2: Order No. R5-2007-0059

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD

CENTRAL VALLEY REGION

415 Knollcrest Drive, Suite 100, Redding, CA 96002
Phone (530) 224-4845 • FAX (530) 224-4857
<http://www.waterboards.ca.gov/centralvalley>

ORDER NO. R5-2007-0058
NPDES NO. CA0082589

WASTE DISCHARGE REQUIREMENTS FOR THE CITY OF REDDING STILLWATER WASTEWATER TREATMENT FACILITY SHASTA COUNTY

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 1. Discharger Information

Discharger	City of Redding		
Name of Facility	Stillwater Wastewater Treatment Facility		
Facility Address	6475 Airport Road		
	Anderson, CA 96007		
	Shasta County		

The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a **major** discharge.

The discharge by the City of Redding from the discharge points identified below is subject to waste discharge requirements as set forth in this Order:

Table 2. Discharge Location

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
D-001	Advanced Secondary Treated Wastewater	40° 28' 26.8" N	122° 16' 07.5" W	Sacramento River

Table 3. Administrative Information

This Order was adopted by the Regional Water Quality Control Board on:	21 June 2007
This Order shall become effective on:	10 August 2007
This Order shall expire on:	01 June 2012
The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than:	180 days prior to the Order expiration date

IT IS HEREBY ORDERED, that Order No. **5-01-216** is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on **21 June 2007**.

PAMELA C. CREEDON, Executive Officer

Table of Contents

I.	Facility Information	1
II.	Findings	1
III.	Discharge Prohibitions.....	7
IV.	Effluent Limitations and Discharge Specifications	9
A.	Effluent Limitations – Discharge Point D-001.....	9
1.	Final Effluent Limitations – Discharge Point D-001.....	9
2.	Interim Effluent Limitations	10
B.	Land Discharge Specifications – Emergency Storage Ponds.....	10
C.	Reclamation Specifications – Discharge Point REC-001	11
V.	Receiving Water Limitations	11
A.	Surface Water Limitations.....	11
B.	Groundwater Limitations	13
VI.	Provisions	14
A.	Standard Provisions.....	14
B.	Monitoring and Reporting Program (MRP) Requirements	18
C.	Special Provisions.....	18
1.	Reopener Provisions	18
2.	Special Studies, Technical Reports and Additional Monitoring Requirements	20
3.	Best Management Practices and Pollution Prevention	22
4.	Construction, Operation and Maintenance Specifications	24
5.	Special Provisions for Municipal Facilities (POTWs Only)	24
6.	Other Special Provisions	28
7.	Compliance Schedules.....	28
VII.	Compliance Determination	30

List of Tables

Table 1.	Discharger Information	Cover
Table 2.	Discharge Location	Cover
Table 3.	Administrative Information	Cover
Table 4.	Facility Information.....	1
Table 5.	Basin Plan Beneficial Uses.....	3
Table 6.	Effluent Limitations	9
Table 7.	Interim Effluent Limitations	10

List of Attachments

Attachment A – Definitions	A-1
Attachment B – Map	B-1
Attachment C – Aerial Photograph	C-1
Attachment D – Standard Provisions	D-1
Attachment E – Monitoring and Reporting Program (MRP)	E-1
Attachment F – Fact Sheet.....	F-1

I. FACILITY INFORMATION

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 4. Facility Information

Discharger	City of Redding
Name of Facility	Stillwater Wastewater Treatment Facility
Facility Address	6475 Airport Road
	Anderson, CA 96007
	Shasta County
Facility Contact, Title, and Phone	John Szychulda, Plant Supervisor, (530) 378-6702
Mailing Address	P.O. Box 917, Anderson, CA 96007
Type of Facility	Publicly Owned Treatment Works
Facility Design Flow	4.0 million gallons per day (mgd)

II. FINDINGS

The California Regional Water Quality Control Board, Central Valley Region (hereinafter Regional Water Board), finds:

A. Background. The City of Redding (hereinafter Discharger) is currently discharging pursuant to Order No. 5-01-216 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0082589. The Discharger submitted a Report of Waste Discharge, dated 28 February 2006, and applied for a NPDES permit renewal to discharge up to an average monthly dry weather flow of 4.0 mgd of treated domestic wastewater (advanced secondary treatment) from the Stillwater Wastewater Treatment Facility, hereinafter Facility. The application was deemed complete on 30 March 2006.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

B. Facility Description. The Discharger owns and operates a Publicly Owned Treatment Works. The treatment system consists of screening for removal of large solids, activated sludge treatment with secondary clarification, filtration, and chlorination/dechlorination. Waste activated sludge is treated by aerobic digestion followed by belt-filter-press dewatering. Biosolids are disposed at a sanitary landfill and land applied on property owned by the Discharger. Wastewater is discharged through a diffuser from Discharge D-001 (see table on cover page) to the Sacramento River, a water of the United States, within the Sacramento River Watershed. Attachment B provides a map of the area around the Facility. Attachment C provides an aerial photo of the Facility.

C. Legal Authorities. This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code

(commencing with section 13370). It shall serve as a NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with section 13260).

- D. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through E are also incorporated into this Order.
- E. California Environmental Quality Act (CEQA).** Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code sections 21100-21177.
- F. Technology-based Effluent Limitations.** Section 301(b) of the CWA and implementing USEPA permit regulations at section 122.44, title 40 of the Code of Federal Regulations (CFR)¹ require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Secondary Treatment Standards at Part 133 and Best Professional Judgment (BPJ) in accordance with Part 125, section 125.3. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet (Attachment F).
- G. Water Quality-based Effluent Limitations.** Section 301(b) of the CWA and section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. This Order contains requirements, expressed as a technology equivalence requirement, more stringent than secondary treatment requirements that are necessary to meet applicable water quality standards. The Regional Water Board has considered the factors listed in CWC Section 13241 in establishing these requirements. The rationale for these requirements, which consist of tertiary treatment or equivalent requirements, is discussed in the Fact Sheet.

Section 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) EPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a

¹ All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated.

calculated numeric water quality criterion, such as a proposed State criterion or policy interpreting the State's narrative criterion, supplemented with other relevant information, as provided in 40 CFR section 122.44(d)(1)(vi).

H. Water Quality Control Plans. The Regional Water Board adopted a *Water Quality Control Plan, Fourth Edition (Revised August 2006), for the Sacramento and San Joaquin River Basins* (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses applicable to the Sacramento River (from Shasta Dam to Colusa Basin Drain) are as follows: municipal and domestic supply; agricultural supply, including stock watering; industrial service supply; hydropower generation; water contact recreation, including canoeing and rafting; non-contact water recreation, including aesthetic enjoyment; commercial and sport fishing; warm freshwater habitat; cold freshwater habitat; warm migration of aquatic organisms; cold migration of aquatic organisms; warm spawning, reproduction, and/or early development; cold spawning, reproduction, and /or early development; wildlife habitat; and navigation.

Table 5. Basin Plan Beneficial Uses

Discharge Point	Receiving Water Name	Beneficial Use(s)
D-001	Sacramento River (from Shasta Dam to Colusa Basin Drain)	<p><u>Existing:</u> Municipal and domestic water supply (MUN), agricultural supply and stock watering (AGR), industrial service supply and power (IND), contact (REC-1) and non-contact (REC-2) water recreation, warm freshwater habitat (WARM); cold freshwater habitat (COLD); migration (MGR); spawning (SPWN), wildlife habitat (WILD), and navigation (NAV).</p> <p><u>Potential:</u> Ground water recharge (GWR), freshwater replenishment (FRESH), preservation or rare, threatened or endangered species (RARE).</p>

The Basin Plan includes a list of Water Quality Limited Segments (WQLSs), which are defined as "...those sections of lakes, streams, rivers or other fresh water bodies where water quality does not meet (or is not expected to meet) water quality standards even after the application of appropriate limitations for point sources (40 CFR 130, et seq.)." The Basin Plan also states, "Additional treatment beyond minimum federal standards will be imposed on dischargers to WQLSs. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be met in the segment." The Sacramento River from Keswick Dam to Cottonwood Creek has been listed as an impaired waterbody pursuant to Section 303(d) of the Clean Water Act for cadmium, copper, unknown toxicity, and zinc. The listing for the metals is mainly a result of long term affects of mining operations at Iron Mountain Mine (located along this

reach of river) in addition to other mines up stream of Shasta Dam. The listing for unknown toxicity has a proposed TMDL (Total Maximum Daily Load) completion date of 2019.

In April 2002, the Regional Board published the *Upper Sacramento River TMDL for Cadmium, Copper, and Zinc* final report. Proposed numeric acute and chronic targets for dissolved cadmium, copper, and zinc were issued as part of a TMDL program. Due to the proposed remedial activities scheduled for Iron Mountain Mine and other mine sites during the next five years, Regional Board staff proposed a 5-year TMDL water management strategy that included monitoring by NPDES-permitted dischargers for dissolved cadmium, copper, and zinc, and flow to quantify their dissolved metal loads. Review of ambient metal concentration data collected by staff, other agencies, and dischargers will allow for the determination of whether the upstream remediation efforts enable dissolved metal concentrations in the Sacramento River water to comply with the proposed targets. A review of the TMDL along with USEPA's 5-year review for the Iron Mountain Mine site is scheduled for 2008.

- I. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995 and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.
- J. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- K. Compliance Schedules and Interim Requirements.** In general, an NPDES permit must include final effluent limitations that are consistent with Clean Water Act section 301 and with 40 CFR 122.44(d). There are exceptions to this general rule. The State Water Board has concluded that where the Regional Water Board's Basin Plan allows for schedules of compliance and the Regional Water Board is newly interpreting a narrative standard, it may include schedules of compliance in the permit to meet effluent limits that implement a narrative standard. See *In the Matter of Waste Discharge Requirements for Avon Refinery* (State Board Order WQ 2001-06 at pp. 53-55). See also *Communities for a Better Environment et al. v. State Water Resources Control Board*, 34 Cal.Rptr.3d 396, 410 (2005). The Basin Plan for the Sacramento and San

Joaquin Rivers includes a provision that authorizes the use of compliance schedules in NPDES permits for water quality objectives that are adopted after the date of adoption of the Basin Plan, which was September 25, 1995 (See Basin Plan at page IV-16). Consistent with the State Water Board's Order in the CBE matter, the Regional Water Board has the discretion to include compliance schedules in NPDES permits when it is including an effluent limitation that is a "new interpretation" of a narrative water quality objective. This conclusion is also consistent with the United States Environmental Protection Agency policies and administrative decisions. See, e.g., Whole Effluent Toxicity (WET) Control Policy. The Regional Water Board, however, is not required to include a schedule of compliance, but may issue a Time Schedule Order pursuant to Water Code section 13300 or a Cease and Desist Order pursuant to Water Code section 13301 where it finds that the discharger is violating or threatening to violate the permit. The Regional Water Board will consider the merits of each case in determining whether it is appropriate to include a compliance schedule in a permit, and, consistent with the Basin Plan, should consider feasibility of achieving compliance, and must impose a schedule that is as short as practicable to achieve compliance with the objectives, criteria, or effluent limit based on the objective or criteria.

For CTR constituents, Section 2.1 of the SIP provides that, based on a Discharger's request and demonstration that it is infeasible for an existing Discharger to achieve immediate compliance with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed 5 years from the date that the permit is issued or reissued, nor may it extend beyond 10 years from the effective date of the SIP (or May 18, 2010) to establish and comply with CTR criterion-based effluent limitations. Where a compliance schedule for a final effluent limitation that exceeds 1 year, the Order must include interim numeric limitations for that constituent or parameter. Where allowed by the Basin Plan, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to implement a new or revised water quality objective. This Order includes compliance schedules and interim effluent limitations and/or discharge specifications. A detailed discussion of the basis for the compliance schedule(s) and interim effluent limitation(s) and/or discharge specifications is included in the Fact Sheet.

L. Alaska Rule. On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes. (40 C.F.R. § 131.21; 65 Fed. Reg. 24641 (April 27, 2000).) Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000 may be used for CWA purposes, whether or not approved by USEPA.

M. Stringency of Requirements for Individual Pollutants. This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on BOD_5 , TSS, and pH.

The water quality-based effluent limitations consist of restrictions on pathogens. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum, federal technology-based requirements that are necessary to meet water quality standards. These limitations are more stringent than required by the CWA. Specifically, this Order includes effluent limitations for BOD and TSS that are more stringent than applicable federal standards, but that are nonetheless necessary to meet numeric objectives or protect beneficial uses. The rationale for including these limitations is explained in the Fact Sheet. In addition, the Regional Water Board has considered the factors in Water Code section 13241 in establishing these requirements.

Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant water quality-based effluent limitations were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR section 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations are based on the CTR-SIP, which was approved by USEPA on May 1, 2001. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "*applicable water quality standards for purposes of the [Clean Water] Act*" pursuant to 40 CFR section 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the technology-based requirements of the CWA and the applicable water quality standards for purposes of the CWA.

N. Antidegradation Policy. Section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 is consistent with the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. As discussed in detail in the Fact Sheet the permitted discharge is consistent with the antidegradation provision of section 131.12 and State Water Board Resolution No. 68-16.

O. Anti-Backsliding Requirements. Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40, Code of Federal Regulations section 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order.

- P. Monitoring and Reporting.** Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.
- Q. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet.
- R. Provisions and Requirements Implementing State Law.** The provisions/requirements in subsections IV.B, IV.C, and V.B of this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.
- S. Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet of this Order.
- T. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet of this Order.

III. DISCHARGE PROHIBITIONS

- A. Discharge of wastewater at a location or in a manner different from that described in the Findings is prohibited.
- B. The by-pass or overflow of wastes to surface waters is prohibited, except as allowed by Federal Standard Provisions I.G. and I.H. (Attachment D).
- C. Neither the discharge nor its treatment shall create a nuisance as defined in Section 13050 of the California Water Code.
- D. The Discharger shall not allow pollutant-free wastewater to be discharged into the collection, treatment, and disposal system in amounts that significantly diminish the system's capability to comply with this Order. Pollutant-free wastewater means rainfall, groundwater, cooling waters, and condensates that are essentially free of pollutants.

- E. The discharge of waste that causes violation of any narrative water quality objective contained in the Basin Plan is prohibited.
- F. The discharge of waste that causes violation of any numeric water quality objective contained in the Basin Plan is prohibited.
- G. Where any numeric or narrative water quality objective contained in the Basin Plan is already being violated, the discharge of waste that causes further degradation or pollution is prohibited.
- H. The Discharger shall not cause pollution as defined in Section 13050 of the California Water Code.
- I. Discharge of storm water at a location or in a manner different from that described in the Findings is prohibited.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations – Discharge Point D-001

1. Final Effluent Limitations – Discharge Point D-001

The Discharger shall maintain compliance with the following effluent limitations at Discharge Point D-001, with compliance measured at Monitoring Location EFF-001 as described in the attached MRP (Attachment E):

- a. The Discharger shall maintain compliance with the effluent limitations specified in Table 6:

Table 6. Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
BOD 5-day @ 20°C	mg/L	10	15	30	--	--
	lbs/day ^a	334	500	1,001	--	--
Total Suspended Solids	mg/L	10	15	30	--	--
	lbs/day ^a	334	500	1,001	--	--
pH	standard units	--	--	--	6.0	9.0
Copper, Total Recoverable	ug/L	13.7	--	27.4	--	---
Zinc, Total Recoverable	ug/L	57.8	--	115.9	--	--
Cyanide, Total (as CN)	ug/L	31.8	--	63.7	--	--
Chlorodibromomethane	ug/L	12.1	--	24.2	--	--
Dichlorobromomethane	ug/L	18.1	--	36.2	--	--
alpha-BHC	ug/L	0.11	--	0.21	--	--
beta-BHC	ug/L	0.15	--	0.30	--	--
gamma-BHC	ug/L	0.81	--	1.62	--	--
Chlorine Residual	mg/L	--	0.01 ^b	0.02 ^c	--	--
Total Coliform Organisms	MPN/100 mL	23 ^d	--	500	--	--

a Based upon a dry weather treatment design flow of 4.0 mgd.

b 4-day average.

c 1-hour average.

d Monthly median.

- b. **Percent Removal:** The average monthly percent removal of BOD 5-day 20°C and total suspended solids shall not be less than 85 percent.
- c. **Acute Whole Effluent Toxicity.** Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:
 - i. 70%, minimum for any one bioassay; and
 - ii. 90%, median for any three consecutive bioassays.

- d. **Total Residual Chlorine.** Effluent total residual chlorine shall not exceed:
 - i. 0.01 mg/L, as a 4-day average;
 - ii. 0.02 mg/L, as a 1-hour average;
- e. **Total Coliform Organisms.** Effluent total coliform organisms shall not exceed:
 - i. 23 most probable number (MPN) per 100 mL, as a 30-day median; and
 - ii. 500 MPN/100 mL, more than once in any 30-day period.
- f. **Average Daily Discharge Flow.** The monthly average daily dry weather (May through September) discharge flow shall not exceed 4.0 mgd. Flows occurring in May shall be excluded from this limitation if significant rain events occur or seasonal high groundwater conditions persist.

2. Interim Effluent Limitations

- a. During the period beginning 10 August 2007 and ending on 18 May 2010, the Discharger shall maintain compliance with the following limitations at D-001, with compliance measured at Monitoring Location EFF-001 as described in the attached MRP. These interim effluent limitations shall apply in lieu of the corresponding final effluent limitations specified for the same parameters during the time period indicated in this provision.

Table 7. Interim Effluent Limitations

Parameter	Units	Effluent Limitations	
		Average Monthly	Maximum Daily
Copper, Total Recoverable	ug/L	29.1	--

B. Land Discharge Specifications – Emergency Storage Ponds

- 1. The discharge of waste classified as "hazardous" as defined in section 2521(a) of Title 23, California Code of Regulations (CCR), or "designated", as defined in section 13173 of the CWC, to the treatment ponds is prohibited.
- 2. Objectionable odors originating at this facility shall not be perceivable beyond the limits of the wastewater treatment and disposal areas (or property owned by the Discharger).
- 3. As a means of discerning compliance with Land Discharge Specification B.2, the dissolved oxygen content in the upper zone (1 foot) of wastewater in ponds shall not be less than 1.0 mg/L.

4. The emergency overflow ponds shall be managed to prevent the breeding of mosquitoes. In particular:
 - i. Weeds shall be minimized.
 - ii. Dead algae, vegetation, and debris shall not accumulate on the water surface.
5. Public contact with the wastewater shall be precluded through such means as fences, signs, or other acceptable alternatives.

C. Reclamation Specifications – Discharge Point REC-001

1. The discharge shall be distributed uniformly on adequate acreage in compliance with Water Reclamation Requirements Order No. 98-016 or its update.
2. In accordance with Title 22, all reclaimed water used for irrigation of fodder and fiber crops and pasture for animals not producing milk for human consumption, shall be adequately oxidized.

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in the Sacramento River:

1. **Bacteria.** The fecal coliform concentration, based on a minimum of not less than five samples for any 30-day period, to exceed a geometric mean of 200 MPN/100 mL, nor more than ten percent of the total number of fecal coliform samples taken during any 30-day period to exceed 400 MPN/100 mL.
2. **Biostimulatory Substances.** Water to contain biostimulatory substances which promote aquatic growths in concentrations that cause nuisance or adversely affect beneficial uses.
3. **Chemical Constituents.** Chemical constituents to be present in concentrations that adversely affect beneficial uses.
4. **Color.** Discoloration that causes nuisance or adversely affects beneficial uses.
5. **Dissolved Oxygen:**
 - a. The monthly median of the mean daily dissolved oxygen concentration to fall below 85 percent of saturation in the main water mass;
 - b. The 95 percentile dissolved oxygen concentration to fall below 75 percent of saturation; nor

- c. The dissolved oxygen concentration to be reduced below 7.0 mg/L at any time.
 - d. From 1 June to 31 August: Concentrations of dissolved oxygen to fall below 9.0 mg/L. When natural conditions lower dissolved oxygen below this level, the concentrations shall be maintained at or above 95 percent saturation.
6. **Floating Material.** Floating material to be present in amounts that cause nuisance or adversely affect beneficial uses.
7. **Oil and Grease.** Oils, greases, waxes, or other materials to be present in concentrations that cause nuisance, result in a visible film or coating on the surface of the water or on objects in the water, or otherwise adversely affect beneficial uses.
8. **pH.** The pH to be depressed below 6.5, raised above 8.5, nor changed by more than 0.5 units.
9. **Pesticides:**
- a. Pesticides to be present, individually or in combination, in concentrations that adversely affect beneficial uses;
 - b. Pesticides to be present in bottom sediments or aquatic life in concentrations that adversely affect beneficial uses;
 - c. Total identifiable persistent chlorinated hydrocarbon pesticides to be present in the water column at concentrations detectable within the accuracy of analytical methods approved by USEPA or the Executive Officer.
 - d. Pesticide concentrations to exceed those allowable by applicable antidegradation policies (see State Water Board Resolution No. 68-16 and 40 CFR §131.12.).
 - e. Pesticide concentrations to exceed the lowest levels technically and economically achievable.
 - f. Pesticides to be present in concentration in excess of the maximum contaminant levels set forth in California Code of Regulations, Title 22, Division 4, Chapter 15.
 - g. Thiobencarb to be present in excess of 1.0 ug/L.
 - h. Diazinon concentrations in excess of 0.080 ug/L (1-hour average) or 0.050 ug/L (4-day average) to occur more than once every three years on average.
10. **Radioactivity:**
- a. Radionuclides to be present in concentrations that are harmful to human, plant, animal, or aquatic life nor that result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal, or aquatic life.
 - b. Radionuclides to be present in excess of the maximum contaminant levels specified in Table 4 (MCL Radioactivity) of Section 64443 of Title 22 of the California Code of Regulations.

11. **Suspended Sediments.** The suspended sediment load and suspended sediment discharge rate of surface waters to be altered in such a manner as to cause nuisance or adversely affect beneficial uses.
12. **Settleable Substances.** Substances to be present in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.
13. **Suspended Material.** Suspended material to be present in concentrations that cause nuisance or adversely affect beneficial uses.
14. **Taste and Odors.** Taste- or odor-producing substances to be present in concentrations that impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.
15. **Temperature.** The natural temperature to be increased by more than 5°F, or to higher than 56°F when such an increase will be detrimental to the fishery, which is more restrictive.
16. **Toxicity.** Toxic substances to be present, individually or in combination, in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.
17. **Turbidity.** The turbidity to increase as follows:
 - a. More than 1 Nephelometric Turbidity Unit (NTU) where natural turbidity is between 0 and 5 NTUs.
 - b. More than 20 percent where natural turbidity is between 5 and 50 NTUs.
 - c. More than 10 NTU where natural turbidity is between 50 and 100 NTUs.
 - d. More than 10 percent where natural turbidity is greater than 100 NTUs.

B. Groundwater Limitations

1. The discharge shall not cause the underlying groundwater to be degraded.
2. Release of waste constituents from any storage, treatment, or disposal component associated with the WWTP shall not, in combination with other sources of the waste constituents, cause groundwater within influence of the WWTP to contain waste constituents in concentrations in excess of natural background quality or that listed below, whichever is greater:
 - a. Total coliform organisms median of 2.2 MPN/100 mL over any seven-day period.

VI. PROVISIONS

A. Standard Provisions

1. The Discharger shall comply with all Standard Provisions included in Attachment D of this Order.
2. The Discharger shall comply with the following provisions:
 - a. If the Discharger's wastewater treatment plant is publicly owned or subject to regulation by California Public Utilities Commission, it shall be supervised and operated by persons possessing certificates of appropriate grade according to Title 23, CCR, Division 3, Chapter 26.
 - b. After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
 - i. violation of any term or condition contained in this Order;
 - ii. obtaining this Order by misrepresentation or by failing to disclose fully all relevant facts;
 - iii. a change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; and
 - iv. a material change in the character, location, or volume of discharge.

The causes for modification include:

- *New regulations.* New regulations have been promulgated under Section 405(d) of the Clean Water Act, or the standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued.
- *Land application plans.* When required by a permit condition to incorporate a land application plan for beneficial reuse of sewage sludge, to revise an existing land application plan, or to add a land application plan.
- *Change in sludge use or disposal practice.* Under 40 Code of Federal Regulations (CFR) 122.62(a)(1), a change in the Discharger's sludge use or disposal practice is a cause for modification of the permit. It is cause for revocation and reissuance if the Discharger requests or agrees.

The Regional Water Board may review and revise this Order at any time upon application of any affected person or the Regional Water Board's own motion.

- c. If a toxic effluent standard or prohibition (including any scheduled compliance specified in such effluent standard or prohibition) is established under Section 307(a) of the CWA, or amendments thereto, for a toxic pollutant that is present in the discharge authorized herein, and such standard or prohibition is more stringent than any limitation upon such pollutant in this Order, the Regional Water Board will revise or modify this Order in accordance with such toxic effluent standard or prohibition.

The Discharger shall comply with effluent standards and prohibitions within the time provided in the regulations that establish those standards or prohibitions, even if this Order has not yet been modified.

- d. This Order shall be modified, or alternately revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - i. contains different conditions or is otherwise more stringent than any effluent limitation in the Order; or
 - ii. controls any pollutant limited in the Order.

The Order, as modified or reissued under this paragraph, shall also contain any other requirements of the CWA then applicable.

- e. The provisions of this Order are severable. If any provision of this Order is found invalid, the remainder of this Order shall not be affected.
- f. The Discharger shall take all reasonable steps to minimize any adverse effects to waters of the State or users of those waters resulting from any discharge or sludge use or disposal in violation of this Order. Reasonable steps shall include such accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge or sludge use or disposal.
- g. The Discharger shall ensure compliance with any existing or future pretreatment standard promulgated by USEPA under Section 307 of the CWA, or amendment thereto, for any discharge to the municipal system.
- h. The discharge of any radiological, chemical or biological warfare agent or high-level, radiological waste is prohibited.
- i. A copy of this Order shall be maintained at the discharge facility and be available at all times to operating personnel. Key operating personnel shall be familiar with its content.
- j. Safeguard to electric power failure:

- i. The Discharger shall provide safeguards to assure that, should there be reduction, loss, or failure of electric power, the discharge shall comply with the terms and conditions of this Order.
 - ii. Upon written request by the Regional Water Board the Discharger shall submit a written description of safeguards. Such safeguards may include alternate power sources, standby generators, retention capacity, operating procedures, or other means. A description of the safeguards provided shall include an analysis of the frequency, duration, and impact of power failures experienced over the past five years on effluent quality and on the capability of the Discharger to comply with the terms and conditions of the Order. The adequacy of the safeguards is subject to the approval of the Regional Water Board.
 - iii. Should the treatment works not include safeguards against reduction, loss, or failure of electric power, or should the Regional Water Board not approve the existing safeguards, the Discharger shall, within ninety days of having been advised in writing by the Regional Water Board that the existing safeguards are inadequate, provide to the Regional Water Board and USEPA a schedule of compliance for providing safeguards such that in the event of reduction, loss, or failure of electric power, the Discharger shall comply with the terms and conditions of this Order. The schedule of compliance shall, upon approval of the Regional Water Board, become a condition of this Order.
- k. The Discharger, upon written request of the Regional Water Board, shall file with the Board a technical report on its preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events. This report may be combined with that required under Regional Water Board Standard Provision VI.A.2.m.

The technical report shall:

- i. Identify the possible sources of spills, leaks, untreated waste by-pass, and contaminated drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks and pipes should be considered.
- ii. Evaluate the effectiveness of present facilities and procedures and state when they became operational.
- iii. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule containing interim and final dates when they will be constructed, implemented, or operational.

The Regional Water Board, after review of the technical report, may establish conditions which it deems necessary to control accidental discharges and to minimize the effects of such events. Such conditions shall be incorporated as part of this Order, upon notice to the Discharger.

- I. A publicly owned treatment works (POTW) whose waste flow has been increasing, or is projected to increase, shall estimate when flows will reach hydraulic and treatment capacities of its treatment and disposal facilities. The projections shall be made in January, based on the last three years' average dry weather flows, peak wet weather flows and total annual flows, as appropriate. When any projection shows that capacity of any part of the facilities may be exceeded in four years, the Discharger shall notify the Regional Water Board by 31 January. A copy of the notification shall be sent to appropriate local elected officials, local permitting agencies and the press. Within 120 days of the notification, the Discharger shall submit a technical report showing how it will prevent flow volumes from exceeding capacity or how it will increase capacity to handle the larger flows. The Regional Water Board may extend the time for submitting the report.
- m. The Discharger shall submit technical reports as directed by the Executive Officer. All technical reports required herein that involve planning, investigation, evaluation, or design, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in California pursuant to California Business and Professions Code, sections 6735, 7835, and 7835.1. To demonstrate compliance with Title 16, CCR, sections 415 and 3065, all technical reports must contain a statement of the qualifications of the responsible registered professional(s). As required by these laws, completed technical reports must bear the signature(s) and seal(s) of the registered professional(s) in a manner such that all work can be clearly attributed to the professional responsible for the work.
- n. Laboratories that perform sample analyses must be identified in all monitoring reports submitted to the Regional Water Board and USEPA.
- o. The Discharger shall conduct analysis on any sample provided by USEPA as part of the Discharge Monitoring Quality Assurance (DMQA) program. The results of any such analysis shall be submitted to USEPA's DMQA manager.
- p. Effluent samples shall be taken downstream of the last addition of wastes to the treatment or discharge works where a representative sample may be obtained prior to mixing with the receiving waters. Samples shall be collected at such a point and in such a manner to ensure a representative sample of the discharge.
- q. All monitoring and analysis instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary, at least yearly, to ensure their continued accuracy.
- r. The Discharger shall file with the Regional Water Board technical reports on self-monitoring performed according to the detailed specifications contained in the Monitoring and Reporting Program attached to this Order.

- s. The results of all monitoring required by this Order shall be reported to the Regional Water Board, and shall be submitted in such a format as to allow direct comparison with the limitations and requirements of this Order. Unless otherwise specified, discharge flows shall be reported in terms of the monthly average and the daily maximum discharge flows.
- t. The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the CWC, including, but not limited to, sections 13385, 13386, and 13387.
- u. For POTWs, prior to making any change in the point of discharge, place of use, or purpose of use of treated wastewater that results in a decrease of flow in any portion of a watercourse, the Discharger must file a petition with the State Water Board, Division of Water Rights, and receive approval for such a change. (CWC section 1211).
- v. In the event the Discharger does not comply or will be unable to comply for any reason, with any prohibition, maximum daily effluent limitation, 1-hour average effluent limitation, or receiving water limitation contained in this Order, the Discharger shall notify the Regional Water Board by telephone (530) 224-4845 within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing within five days, unless the Regional Water Board waives confirmation. The written notification shall include the information required by Attachment D, Section V.E.1 [40 CFR section 122.41(l)(6)(i)].

B. Monitoring and Reporting Program (MRP) Requirements

- 1. The Discharger shall comply with the MRP, and future revisions thereto, in Attachment E of this Order.

C. Special Provisions

1. Reopener Provisions

- a. This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity, monitoring requirements on internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.
- b. Conditions that necessitate a major modification of a permit are described in 40 CFR section 122.62, including:
 - i. If new or amended applicable water quality standards are promulgated or approved pursuant to Section 303 of the CWA, or amendments thereto, this

- permit may be reopened and modified in accordance with the new or amended standards.
- ii. When new information, that was not available at the time of permit issuance, would have justified different permit conditions at the time of issuance.
 - c. **Mercury.** If mercury is found to be causing toxicity based on acute or chronic toxicity test results, or if a TMDL program is adopted, this Order may be reopened and an effluent limitation imposed. If the Regional Water Board determines that a mercury offset program is feasible for Dischargers subject to a NPDES permit, then this Order may be reopened to evaluate the need for a mercury offset program for the Discharger.
 - d. **Pollution Prevention.** This Order requires the Discharger prepare a pollution prevention plan following CWC section 13263.3(d)(3) for copper and zinc. Based on a review of the pollution prevention plan, this Order may be reopened for addition and/or modification of effluent limitations and requirements for these constituents.
 - e. **Whole Effluent Toxicity.** As a result of a Toxicity Reduction Evaluation (TRE), this Order may be reopened to include a chronic toxicity limitation, a new acute toxicity limitation, and/or a limitation for a specific toxicant identified in the TRE. Additionally, if the State Water Board revises the SIP's toxicity control provisions that would require the establishment of numeric chronic toxicity effluent limitations, this Order may be reopened to include a numeric chronic toxicity effluent limitation based on the new provisions.
 - f. **Water Effects Ratios (WER) and Metal Translators.** A default WER of 1.0 has been used in this Order for calculating CTR criteria for applicable priority pollutant inorganic constituents. In addition, site-specific dissolved-to-total metal translators have been used to convert water quality objectives from dissolved to total recoverable when developing effluent limitations for copper and zinc. If the Discharger performs studies to determine site-specific WERs and/or additional site-specific dissolved-to-total metal translators, this Order may be reopened to modify the effluent limitations for the applicable inorganic constituents.
 - g. **Total Maximum Daily Loads (TMDL).** This Order may be reopened and modified as necessary to implement any TMDLs that are adopted or modified and are applicable to the receiving water.
 - h. **Technical Studies.** This Order may be reopened for addition and/or modification of effluent limitations and requirements if the Discharger performs technical studies that demonstrate and justify a change or modification of effluent limits.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

- a. **Chronic Whole Effluent Toxicity.** For compliance with the Basin Plan's narrative toxicity objective, this Order requires the Discharger to conduct chronic whole effluent toxicity testing, as specified in the Monitoring and Reporting Program (Attachment E, Section V.). Furthermore, this Provision requires the Discharger to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity. If the discharge exceeds the toxicity numeric monitoring trigger established in this Provision, the Discharger is required to initiate a Toxicity Reduction Evaluation (TRE), in accordance with an approved TRE Work Plan, and take actions to mitigate the impact of the discharge and prevent reoccurrence of toxicity. A TRE is a site-specific study conducted in a stepwise process to identify the source(s) of toxicity and the effective control measures for effluent toxicity. TREs are designed to identify the causative agents and sources of whole effluent toxicity, evaluate the effectiveness of the toxicity control options, and confirm the reduction in effluent toxicity. This Provision includes requirements for the Discharger to develop and submit a TRE Work Plan and includes procedures for accelerated chronic toxicity monitoring and TRE initiation.
 - i. **Initial Investigative Toxicity Reduction Evaluation (TRE) Work Plan.** Within 90 days of the effective date of this Order, the Discharger shall submit to the Regional Water Board an Initial Investigative TRE Work Plan for approval by the Executive Officer. This should be a one to two page document including, at minimum:
 - a) A description of the investigation and evaluation techniques that will be used to identify potential causes and sources of effluent toxicity, effluent variability, and treatment system efficiency;
 - b) A description of the facility's methods of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in operation of the facility; and
 - c) A discussion of who will conduct the Toxicity Identification Evaluation, if necessary (i.e. an in-house expert or outside contractor).
 - ii. **Accelerated Monitoring and TRE Initiation.** When the numeric toxicity monitoring trigger is exceeded during regular chronic toxicity monitoring, and the testing meets all test acceptability criteria, the Discharger shall initiate accelerated monitoring as required in the Accelerated Monitoring Specifications. WET testing results exceeding the monitoring trigger during accelerated monitoring demonstrates a pattern of toxicity and requires the Discharger to initiate a TRE to address the effluent toxicity.
 - iii. **Numeric Monitoring Trigger.** The numeric toxicity monitoring trigger is $> 10 \text{ TUC}$ (where TUC = 100/NOEC). The monitoring trigger is not an effluent limitation; it is the toxicity threshold at which the Discharger is

required to begin accelerated monitoring and initiate a TRE. Further discussion on the monitoring trigger is included in the Fact Sheet.

- iv. **Accelerated Monitoring Specifications.** If the monitoring trigger is exceeded during regular chronic toxicity testing, within 14-days of notification by the laboratory of the test results, the Discharger shall initiate accelerated monitoring. Accelerated monitoring shall consist of four (4) chronic toxicity tests in a six-week period (i.e. one test every two weeks) using the species that exhibited toxicity. The following protocol shall be used for accelerated monitoring and TRE initiation:
 - a) If the results of four (4) consecutive accelerated monitoring tests do not exceed the monitoring trigger, the Discharger may cease accelerated monitoring and resume regular chronic toxicity monitoring. However, notwithstanding the accelerated monitoring results, if there is adequate evidence of a pattern of effluent toxicity, the Executive Officer may require that the Discharger initiate a TRE.
 - b) If the source(s) of the toxicity is easily identified (i.e. temporary plant upset), the Discharger shall make necessary corrections to the facility and shall continue accelerated monitoring until four (4) consecutive accelerated tests do not exceed the monitoring trigger. Upon confirmation that the effluent toxicity has been removed, the Discharger may cease accelerated monitoring and resume regular chronic toxicity monitoring.
 - c) If the result of any accelerated toxicity test exceeds the monitoring trigger, the Discharger shall cease accelerated monitoring and initiate a TRE to investigate the cause(s) of, and identify corrective actions to reduce or eliminate effluent toxicity. Within thirty (30) days of notification by the laboratory of the test results exceeding the monitoring trigger during accelerated monitoring, the Discharger shall submit a TRE Action Plan to the Regional Water Board including, at minimum:
 - 1) Specific actions the Discharger will take to investigate and identify the cause(s) of toxicity, including TRE WET monitoring schedule;
 - 2) Specific actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity; and
 - 3) A schedule for these actions.

Within sixty (60) days of notification by the laboratory of the test results, the Discharger shall submit to the Regional Water Board a TRE Work Plan for approval by the Executive Officer. The TRE Work Plan shall outline the procedures for identifying the source(s) of, and reducing or eliminating

effluent toxicity. The TRE Work Plan must be developed in accordance with EPA guidance¹.

- b. **Constituent Study.** Not Applicable.
- c. **Mixing Zone and Dilution Study.** The Discharger shall submit to the Regional Water Board a site-specific mixing zone and dilution study as described in Section 1.4.2 of the SIP no later than **1 year prior to the expiration date of this Order** for approval by the Executive Officer.
- d. **Site-Specific Translator Study.** The Discharger shall submit to the Regional Board a site-specific translator study, performed in accordance with Section 1.4.1 of the SIP, by no later than **1 year prior to the expiration date of this Order** for approval by the Executive Officer.
- e. **BPTC Evaluation Tasks.** Not Applicable.

3. Best Management Practices and Pollution Prevention

- a. **Pollutant Minimization Program.** The Discharger shall develop and conduct a Pollutant Minimization Program (PMP) as further described below when there is evidence (e.g., sample results reported as DNQ when the effluent limitation is less than the MDL, sample results from analytical methods more sensitive than those methods required by this Order, presence of whole effluent toxicity, health advisories for fish consumption, results of benthic or aquatic organism tissue sampling) that a priority pollutant is present in the effluent above an effluent limitation and either: 1) A sample result is reported as DNQ and the effluent limitation is less than the RL; or 2) A sample result is reported as ND and the effluent limitation is less than the MDL, using definitions described in Attachment A and reporting protocols described in MRP Section X.

The PMP shall include, but not be limited to, the following actions and submittals acceptable to the Regional Water Board:

- i. An annual review and semi-annual monitoring of potential sources of the reportable priority pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling;
- ii. Quarterly monitoring for the reportable priority pollutant(s) in the influent to the wastewater treatment system;

¹ See Attachment F (Fact Sheet) Section VII.B.2.a. for a list of EPA guidance documents that must be considered in development of the TRE Workplan.

- iii. Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable priority pollutant(s) in the effluent at or below the effluent limitation;
 - iv. Implementation of appropriate cost-effective control measures for the reportable priority pollutant(s), consistent with the control strategy; and
 - v. An annual status report that shall be sent to the Regional Water Board including:
 - (1) All PMP monitoring results for the previous year;
 - (2) A list of potential sources of the reportable priority pollutant(s);
 - (3) A summary of all actions undertaken pursuant to the control strategy; and
 - (4) A description of actions to be taken in the following year.
- b. **Pollution Prevention Plan for Copper and Zinc.** The Discharger shall prepare and implement a pollution prevention plan for copper and zinc in accordance with CWC section 13263.3(d)(3). The minimum requirements for the pollution prevention plan are outlined in the Fact Sheet, Attachment F, Section VII.B.3. A work plan and time schedule for preparation of the pollution prevention plan shall be completed and submitted **within 6 months of the effective date of this Order** for approval by the Executive Officer. The Pollution Prevention Plan shall be completed and submitted to the Regional Water Board **within two (2) years following work plan approval by the Executive Officer**, and progress reports shall be submitted in accordance with the Monitoring and Reporting Program (Attachment E, Section X.D.1.).
- c. **Salinity Evaluation and Minimization Plan.** The Discharger shall prepare a salinity evaluation and minimization plan to address sources of salinity from the Facility. The plan shall be completed and submitted to the Regional Water Board **within 2 years of the effective date of this Order** for the approval by the Executive Officer.
- d. **Performance Evaluation Report.** An average monthly effluent limit (AMEL) performance trigger has been set for gamma-BHC as described in the Fact Sheet, Section IV.C.3. The Discharger shall prepare a performance evaluation report describing why the effluent concentration exceeded the AMEL performance trigger and what measures are being taken to maintain past performance concentrations. The Performance Evaluation Report shall be submitted, when necessary, within 60 days following the end of the monitoring period.

4. Construction, Operation and Maintenance Specifications

a. Treatment and Emergency Storage Pond Operating Requirements.

- i. The treatment facilities and emergency storage ponds shall be designed, constructed, operated, and maintained to prevent inundation or washout due to floods with a 100-year return frequency.
- ii. Public contact with wastewater shall be precluded through such means as fences, signs, and other acceptable alternatives.
- iii. Ponds shall be managed to prevent breeding of mosquitoes. In particular,
 - a) An erosion control program should assure that small coves and irregularities are not created around the perimeter of the water surface.
 - b) Weeds shall be minimized.
 - c) Dead algae, vegetation, and debris shall not accumulate on the water surface.
- iv. Freeboard shall never be less than two feet (measured vertically to the lowest point of overflow).
- v. Ponds shall have sufficient capacity to accommodate allowable wastewater flow and design seasonal precipitation and ancillary inflow and infiltration during the non-irrigation season. Design seasonal precipitation shall be based on total annual precipitation using a return period of 100 years, distributed monthly in accordance with historical rainfall patterns. Freeboard shall never be less than two feet (measured vertically to the lowest point of overflow).
- vi. Prior to the onset of the rainy season of each year, available pond storage capacity shall at least equal the volume necessary to comply with Land Discharge Specification v.

5. Special Provisions for Municipal Facilities (POTWs Only)

a. Pretreatment Requirements.

- i. The Discharger shall implement its approved pretreatment program and the program shall be an enforceable condition of this Order. If the Discharger fails to perform the pretreatment functions, the Regional Water Board, the State Water Board or the U.S. Environmental Protection Agency (U.S. EPA) may take enforcement actions against the Discharger as authorized by the CWA.
- ii. The Discharger shall enforce the Pretreatment Standards promulgated under sections 307(b), 307(c), and 307(d) of the Clean Water Act. The Discharger shall perform the pretreatment functions required by 40 CFR Part 403

including, but not limited to:

- a) Adopting the legal authority required by 40 CFR 403.8(f)(1);
 - b) Enforcing the Pretreatment Standards of 40 CFR 403.5 and 403.6;
 - c) Implementing procedures to ensure compliance as required by 40 CFR 403.8(f)(2); and
 - d) Providing funding and personnel for implementation and enforcement of the pretreatment program as required by 40 CFR 403.8(f)(3).
- iii. The Discharger shall implement, as more completely set forth in 40 CFR 403.5, the necessary legal authorities, programs, and controls to ensure that the following incompatible wastes are not introduced to the treatment system, where incompatible wastes are:
- a) Wastes which create a fire or explosion hazard in the treatment works;
 - b) Wastes which will cause corrosive structural damage to treatment works, but in no case wastes with a pH lower than 5.0, unless the works is specially designed to accommodate such wastes;
 - c) Solid or viscous wastes in amounts which cause obstruction to flow in sewers, or which cause other interference with proper operation or treatment works;
 - d) Any waste, including oxygen demanding pollutants (BOD, etc.), released in such volume or strength as to cause inhibition or disruption in the treatment works, and subsequent treatment process upset and loss of treatment efficiency;
 - e) Heat in amounts that inhibit or disrupt biological activity in the treatment works, or that raise influent temperatures above 40°C (104°F), unless the Regional Water Board approves alternate temperature limits;
 - f) Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;
 - g) Pollutants which result in the presence of toxic gases, vapors, or fumes within the treatment works in a quantity that may cause acute worker health and safety problems; and:
 - h) Any trucked or hauled pollutants, except at points predesignated by the Discharger.

- iv. The Discharger shall implement, as more completely set forth in 40 CFR 403.5, the legal authorities, programs, and controls necessary to ensure that indirect discharges do not introduce pollutants into the sewerage system that, either alone or in conjunction with a discharge or discharges from other sources:
 - a) Flow through the system to the receiving water in quantities or concentrations that cause a violation of this Order, or:
 - b) Inhibit or disrupt treatment processes, treatment system operations, or sludge processes, use, or disposal and either cause a violation of this Order or prevent sludge use or disposal in accordance with this Order.
- b. **Sludge/Biosolids Discharge Specifications**
 - i. Collected screenings, residual sludge, biosolids, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer, and consistent with *Consolidated Regulations for Treatment, Storage, Processing, or Disposal of Solid Waste*, as set forth in Title 27, CCR, Division 2, Subdivision 1, section 20005, et seq. Removal for further treatment, disposal, or reuse at sites (i.e., landfill, composting sites, soil amendment sites) that are operated in accordance with valid waste discharge requirements issued by a regional water quality control board will satisfy these specifications.
 - ii. Sludge and solid waste shall be removed from screens, sumps, ponds, clarifiers, etc. as needed to ensure optimal plant performance.
 - iii. The treatment of sludge generated at the Facility shall be confined to the Facility property and conducted in a manner that precludes infiltration of waste constituents into soils in a mass or concentration that will violate Groundwater Limitations V.B. In addition, the storage of residual sludge, solid waste, and biosolids on Facility property shall be temporary and controlled, and contained in a manner that minimizes leachate formation and precludes infiltration of waste constituents into soils in a mass or concentration that will violate Groundwater Limitations V.B.
 - iv. The use and disposal of biosolids shall comply with existing Federal and State laws and regulations, including permitting requirements and technical standards included in 40 CFR 503. If the State Water Board and the Regional Water Board are given the authority to implement regulations contained in 40 CFR 503, this Order may be reopened to incorporate appropriate time schedules and technical standards. The Discharger must comply with the standards and time schedules contained in 40 CFR 503 whether or not they have been incorporated into this Order.

c. Biosolids Disposal Requirements

- i. The Discharger shall comply with the Monitoring and Reporting Program for biosolids disposal contained in Attachment E.
- ii. Any proposed change in biosolids use or disposal practice from a previously approved practice shall be reported to the Executive Officer and U.S. EPA Regional Administrator at least **90 days** in advance of the change.
- iii. The Discharger is encouraged to comply with the “Manual of Good Practice for Agricultural Land Application of Biosolids” developed by the California Water Environment Association.

d. Biosolids Storage Requirements

- i. Facilities for the storage of Class B biosolids shall be located, designed and maintained to restrict public access to biosolids.
- ii. Biosolids storage facilities shall be designed and maintained to prevent washout or inundation from a storm or flood with a return frequency of 100 years.
- iii. Biosolids storage facilities, which contain biosolids, shall be designed and maintained to contain all storm water falling on the biosolids storage area during a rainfall year with a return frequency of 100 years.
- iv. Biosolids storage facilities shall be designed, maintained and operated to minimize the generation of leachate.

- e. Collection System.** On May 2, 2006, the State Water Board adopted State Water Board Order 2006-0003, a Statewide General WDR for Sanitary Sewer Systems. The Discharger shall be subject to the requirements of Order 2006-0003 and any future revisions thereto. Order 2006-0003 requires that all public agencies that currently own or operate sanitary sewer systems apply for coverage under the General WDR. The Discharger has applied for and has been approved for coverage under State Water Board Order 2006-0003 for operation of its wastewater collection system.

Regardless of the coverage obtained under Order 2006-0003, the Discharger's collection system is part of the treatment system that is subject to this Order. As such, pursuant to federal regulations, the Discharger must properly operate and maintain its collection system [40 CFR section 122.41(e)], report any non-compliance [40 CFR section 122.41(l)(6) and (7)], and mitigate any discharge from the collection system in violation of this Order [40 CFR. section 122.41(d)].

- f. This permit, and the Monitoring and Reporting Program which is a part of this permit, requires that certain parameters be monitored on a continuous basis. The wastewater treatment plant is not staffed on a full time basis. Permit violations or system upsets can go undetected during this period. The Discharger is required to establish an electronic system for operator notification for continuous recording device alarms. For existing continuous monitoring systems, the electronic notification system shall be installed **within six months of adoption** of this permit. For systems installed following permit adoption, the notification system shall be installed simultaneously.

6. Other Special Provisions

- a. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to the Regional Water Board.

To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the State of incorporation if a corporation, address and telephone number of the persons responsible for contact with the Regional Water Board and a statement. The statement shall comply with the signatory and certification requirements in the Federal Standard Provisions (Attachment D, Section V.B.) and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the California Water Code. Transfer shall be approved or disapproved in writing by the Executive Officer.

7. Compliance Schedules

a. Compliance Schedules for Final Effluent Limitations for Copper

- i. **By on or before 18 May 2010** the Discharger shall comply with the final effluent limitations for copper. On 1 May 2007, the Discharger submitted a compliance schedule justification for copper. The compliance schedule justification included all items specified in Paragraph 3, items (a) through (d), of section 2.1 of the SIP. As this compliance schedule is greater than one year, the Discharger shall submit semi-annual progress reports in accordance with the Monitoring and Reporting Program (Attachment E, Section X.D.1.)
- ii. **Corrective Action Plan/Implementation Schedule.** The Discharger shall submit to the Regional Water Board a corrective action plan and

implementation schedule to assure compliance with the final effluent limitations for copper **within 6 months of the effective date of this Order.**

- iii. **Pollution Prevention Plan.** The Discharger shall prepare and implement a pollution prevention plan for copper, in accordance with CWC section 13263.3(d)(3). The minimum requirements for the pollution prevention plan are outlined in the Fact Sheet, Attachment F, Section VII.B.3. A work plan and time schedule for preparation of the pollution prevention plan shall be completed and submitted to the Regional Water Board **within 6 months of the effective date of this Order** for approval by the Executive Officer. The Pollution Prevention Plan shall be completed and submitted to the Regional Water Board **within two (2) years following work plan approval by the Executive Officer**, and progress reports shall be submitted in accordance with the Monitoring and Reporting Program (Attachment E, Section X.D.1.).
- iv. **Treatment Feasibility Study.** The Discharger is required to perform an engineering treatment feasibility study examining the feasibility, costs, and benefits of different treatment options that may be required to remove copper from the discharge. A work plan and time schedule for preparation of the treatment feasibility study shall be completed and submitted to the Regional Water Board **within 6 months of the effective date of this Order** for approval by the Executive Officer. If studies to be conducted by the Discharger do not result in justifying alternate effluent limitations that can be met by current treatment facilities, then the treatment feasibility study shall be completed and submitted to the Regional Water Board **within two (2) years following work plan approval by the Executive Officer**, and progress reports shall be submitted in accordance with the Monitoring and Reporting Program (Attachment E, Section X.D.1.).

b. Compliance Schedule for Repair and/or Replacement of Effluent Outlet Diffuser

- i. **By on or before 1 April 2010** the Discharger shall have a properly operating effluent outfall diffuser.
- ii. **Corrective Action Plan/Implementation Schedule.** The Discharger shall submit to the Regional Water Board a corrective action plan and implementation schedule to assure compliance with diffuser repair and replacement deadline **within 9 months of the effective date of this Order.**
- iii. **Final Work Plan with Engineering Design Plans.** The Discharger shall submit to the Regional Board a work plan and time schedule for the diffuser repair and/or replacement project, accompanied by the engineering design plans for the effluent outfall/diffuser design by **1 January 2009.**

VII. COMPLIANCE DETERMINATION

Compliance with the limitations contained in this Order will be determined as specified below:

- A. **Persistent Chlorinated Hydrocarbon Pesticides Receiving Water Limitations.** The non-detectable (ND) limitation applies to each individual pesticide. No individual pesticide may be present in the receiving water at detectable concentrations. The Discharger shall use USEPA standard analytical techniques for persistent chlorinated hydrocarbon pesticides with a minimum acceptable reporting level as indicated in appendix 4 of the SIP.
- B. **BOD and TSS Effluent Limitations.** Compliance with the final effluent limitations for BOD and TSS required in **Section IV.A.1.a.** shall be ascertained by 24-hour composite samples. Compliance with effluent limitations **Section IV.A.1.b.** for percent removal shall be calculated using the arithmetic mean of 20°C BOD (5-day) and total suspended solids in effluent samples collected over a monthly period as a percentage of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period.
- C. **Average Daily Discharge Flow Effluent Limitations.** The Average Daily Discharge Flow represents the daily average flow when groundwater is at or near normal and runoff is not occurring. Compliance with the Average Daily Discharge Flow effluent limitations will be measured at times when groundwater is at or near normal and runoff is not occurring.
- D. **Total Residual Chlorine Effluent Limitations.** Continuous monitoring analyzers for chlorine residual or for dechlorination agent residual in the effluent are appropriate methods for compliance determination. A positive residual dechlorination agent in the effluent indicates that chlorine is not present in the discharge, which demonstrates compliance with the effluent limitations. This type of monitoring can also be used to prove that some chlorine residual exceedances are false positives. Continuous monitoring data showing either a positive dechlorination agent residual or a chlorine residual at or below the prescribed limit are sufficient to show compliance with the total residual chlorine effluent limitations, as long as the instruments are maintained and calibrated in accordance with the manufacturer's recommendations.

Any excursion above the 1-hour average or 4-day average total residual chlorine effluent limitations is a violation. If the Discharger conducts continuous monitoring and the Discharger can demonstrate, through data collected from a back-up monitoring system, that a chlorine spike recorded by the continuous monitor was not actually due to chlorine, then any excursion resulting from the recorded spike will not be considered an exceedance, but rather reported as a false positive.

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (u), also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = u = \Sigma x / n \quad \text{where: } \Sigma x \text{ is the sum of the measured ambient water concentrations, and } n \text{ is the number of samples.}$$

Average Monthly Effluent Limitation (AMEL): the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL): the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Best Practicable Treatment or Control (BPTC): BPTC is a requirement of State Water Resources Control Board Resolution 68-16 – “Statement of Policy with Respect to Maintaining High Quality of Waters in California” (referred to as the “Antidegradation Policy”). BPTC is the treatment or control of a discharge necessary to assure that, “*(a) a pollution or nuisance will not occur and (b) the highest water quality consistent with maximum benefit to the people of the State will be maintained.*” Pollution is defined in CWC Section 13050(l). In general, an exceedance of a water quality objective in the Basin Plan constitutes “pollution”.

Bioaccumulative pollutants are those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV) is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge: Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the

arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ) are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA) is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in U.S. EPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration is the estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries mean waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters are all surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation: the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation: the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL) means the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median is the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL) is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML) is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND) are those sample results less than the laboratory's MDL.

Ocean Waters are the territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP) means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The

goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Regional Water Board.

Reporting Level (RL) is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Satellite Collection System is the portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water is any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ) is a measure of variability that is calculated as follows:

$$\sigma = (\sum[(x - u)^2]/(n - 1))^{0.5}$$

where:

x is the observed value;


u is the arithmetic mean of the observed values; and

n is the number of samples.


Toxicity Reduction Evaluation (TRE) is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity,

evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

ATTACHMENT B – MAP



ATTACHMENT C – AERIAL PHOTOGRAPH



Aerial Imagery Courtesy of GlobeXplorer.com, May 2006

ATTACHMENT D –STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 C.F.R. § 122.41(a).)
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 C.F.R. § 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 C.F.R. § 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 C.F.R. § 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 C.F.R. § 122.41(e).)

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 C.F.R. § 122.41(g).)

2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 C.F.R. § 122.5(c).)

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 C.F.R. § 122.41(i); Wat. Code, § 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 C.F.R. § 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 C.F.R. § 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 C.F.R. § 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (40 C.F.R. § 122.41(i)(4).)

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 C.F.R. § 122.41(m)(1)(i).)
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 C.F.R. § 122.41(m)(1)(ii).)
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 C.F.R. § 122.41(m)(2).)

3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 C.F.R. § 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 C.F.R. § 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 C.F.R. § 122.41(m)(4)(i)(B)); and
 - c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 C.F.R. § 122.41(m)(4)(i)(C).)
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 C.F.R. § 122.41(m)(4)(ii).)
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 C.F.R. § 122.41(m)(3)(i).)
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 C.F.R. § 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 C.F.R. § 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was

caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 C.F.R. § 122.41(n)(2).).

2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 C.F.R. § 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 C.F.R. § 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 C.F.R. § 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 C.F.R. § 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 C.F.R. § 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 C.F.R. § 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 C.F.R. § 122.41(f).)

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 C.F.R. § 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code. (40 C.F.R. § 122.41(l)(3); § 122.61.)

III. STANDARD PROVISIONS – MONITORING

- A.** Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 C.F.R. § 122.41(j)(1).)
- B.** Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order. (40 C.F.R. § 122.41(j)(4); § 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A.** Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 C.F.R. § 122.41(j)(2).)

- B. Records of monitoring information shall include:**

1. The date, exact place, and time of sampling or measurements (40 C.F.R. § 122.41(j)(3)(i));
2. The individual(s) who performed the sampling or measurements (40 C.F.R. § 122.41(j)(3)(ii));
3. The date(s) analyses were performed (40 C.F.R. § 122.41(j)(3)(iii));
4. The individual(s) who performed the analyses (40 C.F.R. § 122.41(j)(3)(iv));
5. The analytical techniques or methods used (40 C.F.R. § 122.41(j)(3)(v)); and
6. The results of such analyses. (40 C.F.R. § 122.41(j)(3)(vi).)

- C. Claims of confidentiality for the following information will be denied (40 C.F.R. § 122.7(b)):**

1. The name and address of any permit applicant or Discharger (40 C.F.R. § 122.7(b)(1)); and
2. Permit applications and attachments, permits and effluent data. (40 C.F.R. § 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 C.F.R. § 122.41(h); Wat. Code, § 13267.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 C.F.R. § 122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 C.F.R. § 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 C.F.R. § 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 C.F.R. § 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 C.F.R. § 122.22(b)(3).)

4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 C.F.R. § 122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 C.F.R. § 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 C.F.R. § 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 C.F.R. § 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board. (40 C.F.R. § 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 C.F.R. § 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 C.F.R. § 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 C.F.R. § 122.41(l)(6)(i).)
2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 C.F.R. § 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 C.F.R. § 122.41(l)(6)(iii).)

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 C.F.R. § 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 C.F.R. § 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 C.F.R. § 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 C.F.R. § 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements. (40 C.F.R. § 122.41(l)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 C.F.R. § 122.41(l)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 C.F.R. § 122.41(l)(8).)

VI. STANDARD PROVISIONS – ENFORCEMENT

- A.** The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 C.F.R. § 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 C.F.R. § 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order. (40 C.F.R. § 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 C.F.R. § 122.42(b)(3).)

Attachment E – Monitoring and Reporting Program

Table of Contents

Attachment E – Monitoring and Reporting Program (MRP)	E-1
I. General Monitoring Provisions.....	E-1
II. Monitoring Locations	E-2
III. Influent Monitoring Requirements.....	E-2
A. Monitoring Location INF-001.....	E-2
IV. Effluent Monitoring Requirements	E-3
A. Monitoring Location EFF-001.....	E-3
V. Whole Effluent Toxicity Testing Requirements	E-4
VI. Land Discharge Monitoring Requirements – Not Applicable	E-7
VII. Reclamation Monitoring Requirements.....	E-7
A. Monitoring Location REC-001	E-7
VIII. Receiving Water Monitoring Requirements – Surface Water.....	E-8
A. Monitoring Location R-001	E-8
B. Monitoring Location R-001a.....	E-9
IX. Other Monitoring Requirements.....	E-9
A. Biosolids	E-9
B. Municipal Water Supply	E-10
X. Reporting Requirements.....	E-10
A. General Monitoring and Reporting Requirements.....	E-10
B. Self Monitoring Reports (SMRs)	E-12
C. Discharge Monitoring Reports (DMRs)	E-14
D. Other Reports	E-14

List of Tables

Table E-1. Monitoring Station Locations	E-2
Table E-2. Influent Monitoring.....	E-2
Table E-3. Effluent Monitoring	E-3
Table E-4. Chronic Toxicity Testing Dilution Series.....	E-6
Table E-5. Reclamation Monitoring Requirements	E-7
Table E-6a. Receiving Water Monitoring Requirements for R-001 and R-002	E-8
Table E-6b. Receiving Water Monitoring Requirements for R-001a	E-9
Table E-7. Municipal Water Supply Monitoring Requirements.....	E-10
Table E-8. Monitoring Periods and Reporting Schedule	E-13
Table E-9. Reporting Requirements for Special Provisions Progress Reports	E-14

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

The Code of Federal Regulations section 122.48 requires that all NPDES permits specify monitoring and reporting requirements. Water Code Sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements, which implement the federal and state regulations.

I. GENERAL MONITORING PROVISIONS

- A. Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring locations specified below and, unless otherwise specified, before the monitored flow joins or is diluted by any other waste stream, body of water, or substance. Monitoring locations shall not be changed without notification to and the approval of this Regional Water Board.
- B. Chemical, bacteriological, and bioassay analyses shall be conducted at a laboratory certified for such analyses by the State Department of Health Services. In the event a certified laboratory is not available to the Discharger, analyses performed by a noncertified laboratory will be accepted provided a Quality Assurance-Quality Control Program is instituted by the laboratory. A manual containing the steps followed in this program must be kept in the laboratory and shall be available for inspection by Regional Water Board staff. The Quality Assurance-Quality Control Program must conform to USEPA guidelines or to procedures approved by the Regional Water Board.
- C. All analyses shall be performed in a laboratory certified to perform such analyses by the California Department of Health Services. Laboratories that perform sample analyses shall be identified in all monitoring reports.
- D. Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. All monitoring instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy. All flow measurement devices shall be calibrated at least once per year to ensure continued accuracy of the devices.
- E. Monitoring results, including noncompliance, shall be reported at intervals and in a manner specified in this Monitoring and Reporting Program.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-1. Monitoring Station Locations

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
--	INF-001	Treatment plant headworks. 40° 28' 39.6" N, 122° 17' 28.2" W
D-001	EFF-001	Downstream from the last connection through which wastes can be admitted into the outfall. 40° 28' 30.7" N, 122° 16' 32.4" W
D-001	EFF-002	Downstream from EFF-001, at the bubble trap.
--	R-001	Sacramento River - 100 feet upstream from point of discharge
--	R-001a	Sacramento River – Caldwell Park boat launch ramp 40° 35' 38.2" N, 122° 23' 54.0 W
--	R-002	Sacramento River – 1,000 feet downstream from the point of discharge.
--	BIO-001	Biosolids Storage Area
--	SPL-001	Water Supply
REC-001	REC-001	Reclamation Water Flow Measurement Location

III. INFLUENT MONITORING REQUIREMENTS

A. Monitoring Location INF-001

1. The Discharger shall monitor influent to the facility at INF-001 as follows:

Table E-2. Influent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Flow	mgd	Continuous	Daily	²
BOD 5-day 20°C	mg/L	24-hr Composite ¹	2/month	²
Total Suspended Solids	mg/L	24-hr Composite ¹	2/month	²

¹ 24-hour flow proportional or time-weighted composite.

² Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for priority pollutants the methods must meet the lowest minimum levels (MLs) specified in Attachment 4 of the SIP, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board.

2. A 24-hour composite influent sample shall be collected annually and analyzed for total cadmium, chromium, copper, lead, nickel, silver, and zinc. The influent sample shall be collected at the same time an effluent sample is obtained for analysis of priority pollutants.

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Location EFF-001

1. The Discharger shall monitor effluent at EFF-001 as follows. Effluent samples should be representative of the volume and quality of the discharge. Time of collection of samples shall be recorded. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level:

Table E-3. Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Flow	mgd	Meter	Continuous	⁹
Total Residual Chlorine ¹	mg/L	Meter	Continuous	⁹
pH	pH Units	Grab	1/day	⁹
Temperature ²	°F (°C)	Grab	1/week	⁹
BOD 5-day 20°C	mg/L, lbs/day	24-hr Composite ⁸	1/week	⁹
Total Suspended Solids	mg/L, lbs/day	24-hr Composite ⁸	1/week	⁹
Total Coliform Organisms	MPN/100 mL	Grab	1/week	⁹
Ammonia (as N) ^{2,3}	mg/L	Grab	1/month	⁹
Electrical Conductivity @ 25°C	umhos/cm	Grab	1/month	⁹
Cadmium, Total Recoverable	ug/L	Grab	1/month	⁹
Copper, Total Recoverable	ug/L	Grab	1/month	⁹
Zinc, Total Recoverable	ug/L	Grab	1/month	⁹
Cyanide, Total (as CN)	ug/L	Grab	1/month	⁹
Chlorodibromomethane	ug/L	Grab	1/month	⁹
Dichlorobromomethane	ug/L	Grab	1/month	⁹
Persistent Chlorinated Hydrocarbon Pesticides	ug/L	Grab	1/quarter	⁹
Total Dissolved Solids ⁴	mg/L	Grab	1/quarter	⁹
Nitrate (as N)	mg/L	Grab	1/quarter	⁹
Nitrite (as N)	mg/L	Grab	1/quarter	⁹
Aluminum, Total	ug/L	Grab	1/year	⁹
Standard Minerals ⁶	mg/L	Grab	1/year	⁹
Priority Pollutants ^{5,7}	ug/L	Grab	1/year	⁹

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
-----------	-------	-------------	----------------------------	---------------------------------

- ¹ Total chlorine residual must be monitored with a method sensitive to and accurate at the permitted level of 0.01 mg/L. Report peak 1-hour average for each day and peak 4-day average for the month.
- ² Concurrent with biotoxicity monitoring.
- ³ Report as total and un-ionized ammonia.
- ⁴ Concurrent with electrical conductivity monitoring.
- ⁵ For priority pollutant constituents with effluent limitations, detection limits shall be below the effluent limitations. If the lowest minimum level (ML) published in Appendix 4 of the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Plan or SIP) is not below the effluent limitation, the detection limit shall be the lowest ML. For priority pollutant constituents without effluent limitations, the detection limits shall be equal to or less than the lowest ML published in Appendix 4 of the SIP.
- ⁶ Standard minerals shall include the following: boron, calcium, iron, magnesium, potassium, sodium, chloride, manganese, phosphorus, total alkalinity (including alkalinity series), and hardness, and include verification that the analysis is complete (i.e., cation/anion balance).
- ⁷ Concurrent with receiving surface water sampling at R-001a (receiving water hardness and pH shall be determined at R-001a at the same time EFF-001 sample taken).
- ⁸ 24-hour flow proportioned or time-weighted composite.
- ⁹ Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for priority pollutants the methods must meet the lowest minimum levels (MLs) specified in Attachment 4 of the SIP, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board.

2. If the discharge is intermittent rather than continuous, then on the first day of each such intermittent discharge, the Discharger shall monitor and record data for all of the constituents listed above, after which the frequencies of analysis given in the schedule shall apply for the duration of each such intermittent discharge.

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

- A. **Acute Toxicity Testing.** The Discharger shall conduct acute toxicity testing to determine whether the effluent is contributing acute toxicity to the receiving water. The Discharger shall meet the following acute toxicity testing requirements:
1. Monitoring Frequency – the Discharger shall perform quarterly acute toxicity testing, concurrent with effluent ammonia sampling.
 2. Sample Types – For static non-renewal and static renewal testing, the samples shall be grab samples and shall be representative of the volume and quality of the discharge. The effluent samples shall be taken at the effluent monitoring location EFF-001.
 3. Test Species – Test species shall be rainbow trout (*Oncorhynchus mykiss*).
 4. Methods – The acute toxicity testing samples shall be analyzed using EPA-821-R-02-012, Fifth Edition. Temperature, total residual chlorine, and pH shall be recorded at the time of sample collection. No pH adjustment may be made unless approved by the Executive Officer.

5. **Test Failure** – If an acute toxicity test does not meet all test acceptability criteria, as specified in the test method, the Discharger must re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.

- B. **Chronic Toxicity Testing.** The Discharger shall conduct three species chronic toxicity testing to determine whether the effluent is contributing chronic toxicity to the receiving water. The Discharger shall meet the following chronic toxicity testing requirements:
 1. **Monitoring Frequency** – the Discharger shall perform annual three species chronic toxicity testing.

 2. **Sample Types** – Effluent samples shall be 24-hour flow proportional or time-weighted composites and shall be representative of the volume and quality of the discharge. The effluent samples shall be taken at the effluent monitoring location EFF-002. The receiving water control shall be a grab sample obtained from the R-001 sampling location, as identified in the Monitoring and Reporting Program.

 3. **Sample Volumes** – Adequate sample volumes shall be collected to provide renewal water to complete the test in the event that the discharge is intermittent.

 4. **Test Species** – Chronic toxicity testing measures sublethal (e.g. reduced growth, reproduction) and/or lethal effects to test organisms exposed to an effluent compared to that of the control organisms. The Discharger shall conduct chronic toxicity tests with:
 - The cladoceran, water flea, *Ceriodaphnia dubia* (survival and reproduction test);
 - The fathead minnow, *Pimephales promelas* (larval survival and growth test); and
 - The green alga, *Selenastrum capricornutum* (growth test).

 5. **Methods** – The presence of chronic toxicity shall be estimated as specified in *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition*, EPA/821-R-02-013, October 2002.

 6. **Reference Toxicant** – As required by the SIP, all chronic toxicity tests shall be conducted with concurrent testing with a reference toxicant and shall be reported with the chronic toxicity test results.

 7. **Dilutions** – The chronic toxicity testing shall be performed using the dilution series identified in Table E-5, below. The receiving water control shall be used as the diluent (unless the receiving water is toxic). The Discharger may initially test at 100 percent effluent and if there are no toxicity effects observed at 100 percent effluent, testing utilizing the dilution series identified in Table E-5 will not be required. If toxicity effects are observed at 100 percent effluent, chronic toxicity testing utilizing

the dilution series must be initiated within 24 hours of knowledge of laboratory results.

8. **Test Failure** –The Discharger must re-sample and re-test as soon as possible, but no later than fourteen (14) days after receiving notification of a test failure. A test failure is defined as follows:
 - a. The reference toxicant test or the effluent test does not meet all test acceptability criteria as specified in the *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition*, EPA/821-R-02-013, October 2002 (Method Manual), and its subsequent amendments or revisions; or
 - b. The percent minimum significant difference (PMSD) measured for the test exceeds the upper PMSD bound variability criterion in Table 6 on page 52 of the Method Manual. (A retest is only required in this case if the test results do not exceed the monitoring trigger specified in (Provisions VI.C.2.a.iii.)

Table E-4. Chronic Toxicity Testing Dilution Series

Sample	Dilutions (%)					Controls	
	100	75	50	25	12.5	Receiving Water	Laboratory Water
% Effluent	100	75	50	25	12.5	0	0
% Receiving Water	0	25	50	75	87.5	100	0
% Laboratory Water	0	0	0	0	0	0	100

- C. **WET Testing Notification Requirements.** The Discharger shall notify the Regional Water Board within 24-hrs after the receipt of test results exceeding the monitoring trigger during regular or accelerated monitoring, or an exceedance of the acute toxicity effluent limitation.
- D. **WET Testing Reporting Requirements.** All toxicity test reports shall include the contracting laboratory's complete report provided to the Discharger and shall be in accordance with the appropriate "Report Preparation and Test Review" sections of the method manuals. At a minimum, whole effluent toxicity monitoring shall be reported as follows:

1. **Chronic WET Reporting.** Regular chronic toxicity monitoring results shall be reported to the Regional Water Board within 30 days following completion of the test, and shall contain, at minimum:
 - a. The results expressed in TUc, measured as 100/NOEC, and also measured as 100/LC₅₀, 100/EC₂₅, 100/IC₂₅, and 100/IC₅₀, as appropriate.
 - b. The statistical methods used to calculate endpoints;

- c. The statistical output page, which includes the calculation of the percent minimum significant difference (PMSD);
- d. The dates of sample collection and initiation of each toxicity test; and
- e. The results compared to the numeric toxicity monitoring trigger.

Additionally, the monthly discharger self-monitoring reports shall contain an updated chronology of chronic toxicity test results expressed in TUc, and organized by test species, type of test (survival, growth or reproduction), and monitoring frequency, i.e., either quarterly, monthly, accelerated, or TRE. (Note: items a through c, above, are only required when testing is performed using the full dilution series.)

2. **Acute WET Reporting.** Acute toxicity test results shall be submitted with the monthly discharger self-monitoring reports and reported as percent survival.
3. **TRE Reporting.** Reports for Toxicity Reduction Evaluations shall be submitted in accordance with the schedule contained in the Discharger's approved TRE Work Plan.
4. **Quality Assurance (QA).** The Discharger must provide the following information for QA purposes:
 - a. Results of the applicable reference toxicant data with the statistical output page giving the species, NOEC, LOEC, type of toxicant, dilution water used, concentrations used, PMSD, and dates tested.
 - b. The reference toxicant control charts for each endpoint, which include summaries of reference toxicant tests performed by the contracting laboratory.
 - c. Any information on deviations or problems encountered and how they were dealt with.

VI. LAND DISCHARGE MONITORING REQUIREMENTS – NOT APPLICABLE

VII. RECLAMATION MONITORING REQUIREMENTS

A. Monitoring Location REC-001

1. The Discharger shall monitor the reclaimed water flow at REC-001 as follows:

Table E-5. Reclamation Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency ^a	Required Analytical Test Method
Flow	Gallons	Continuous	1/day	--

^a When reclaimed water is being used for crop irrigation.

VIII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER

A. Monitoring Location R-001

1. The Discharger shall monitor the Sacramento River at R-001 and R-002 as follows:

Table E-6a. Receiving Water Monitoring Requirements for R-001 and R-002

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Dissolved Oxygen	mg/L	Grab	1/month	a
pH	Standard Units	Grab	1/month	a
Temperature	°F (°C)	Grab	1/month	a
Turbidity	NTU	Grab	1/month	a
Electrical Conductivity @ 25°C	umhos/cm	Grab	1/month	a
Persistent Chlorinated Hydrocarbon Pesticides ^b	ug/L	Grab	1/year	a
Copper, Total Recoverable ^c	ug/L	Grab	1/year	a
Zinc, Total Recoverable ^c	ug/L	Grab	1/year	a
Copper, Dissolved ^c	ug/L	Grab	1/year	a
Zinc, Dissolved ^c	ug/L	Grab	1/year	a

^a Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for priority pollutants the methods must meet the lowest minimum levels (MLs) specified in Attachment 4 of the SIP, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board.

^b Required only at R-002

^c Required only at R-001, receiving water hardness and pH required at time of sampling, concurrent with monitoring at R-001a, during the period of January through May.

2. In conducting the receiving water sampling, a log shall be kept of the receiving water conditions through the reach bounded by R-001 and R-002. Attention shall be given to the presence or absence of:

- a. Floating or suspended matter
- b. Discoloration
- c. Bottom deposits
- d. Aquatic life
- e. Visible films, sheens or coatings
- f. Fungi, slimes, or objectionable growths
- g. Potential nuisance conditions

Notes on receiving water conditions shall be summarized in the monitoring report.

B. Monitoring Location R-001a

1. The Discharger shall monitor the Sacramento River at R-001a (Caldwell Park boat launch ramp) as follows:

Table E-6b. Receiving Water Monitoring Requirements for R-001a

Parameter ^(a)	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Cadmium, Total Recoverable	ug/L	Grab	1/month	d
Copper, Total Recoverable	ug/L	Grab	1/month	d
Zinc, Total Recoverable	ug/L	Grab	1/month	d
Cadmium, Dissolved	ug/L	Grab	1/year ^b	d
Copper, Dissolved	ug/L	Grab	1/year ^b	d
Zinc, Dissolved	ug/L	Grab	1/year ^b	d
Electrical Conductivity @ 25°C	µmhos/cm	Grab	1/year	d
Priority Pollutants	ug/L	Grab	1/year	d
Temperature	°F (°C)	Grab	1/year	d
pH	standard units	Grab	1/year	d
Dissolved Organic Carbon	mg/L	Grab	1/year	d
Standard Minerals ^c	mg/L	Grab	1/year	d
Alkalinity	mg/L CaCO ₃	Grab	1/year	d
Sulfide	mg/L	Grab	1/year	d

^a Receiving water hardness and pH shall be determined at R-001a at the same time of monitoring. These samples shall be taken the same day as effluent samples for the same constituents are taken.

^b During period of January through May.

^c Standard minerals shall include the following: boron, calcium, iron, magnesium, potassium, sodium, chloride, manganese, phosphorus, total alkalinity (including alkalinity series), and hardness, and include verification that the analysis is complete (i.e., cation/anion balance).

^d Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for priority pollutants the methods must meet the lowest minimum levels (MLs) specified in Attachment 4 of the SIP, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board.

IX. OTHER MONITORING REQUIREMENTS

A. Biosolids

1. Monitoring Location BIO-001

1. A composite sample of sludge shall be collected annually at Monitoring Location BIO-001 in accordance with EPA's POTW Sludge Sampling and Analysis Guidance Document, August 1989, and tested for priority pollutants listed in 40 CFR section 122 Appendix D, Tables II and III (excluding total phenols).
2. A composite sample of sludge shall be collected when sludge is removed from the ponds for disposal in accordance with USEPA's POTW Sludge Sampling and Analysis Guidance Document, August 1989, and tested for the metals listed in Title 22.

3. Sampling records shall be retained for a minimum of **five years**. A log shall be kept of sludge quantities generated and of handling and disposal activities. The frequency of entries is discretionary; however, the log should be complete enough to serve as a basis for part of the annual report.
4. Upon removal of sludge, the Discharger shall submit characterization of sludge quality, including sludge percent solids and quantitative results of chemical analysis for the priority pollutants listed in 40 CFR 122 Appendix D, Tables II and III (excluding total phenols). Suggested methods for analysis of sludge are provided in USEPA publications titled "Test Methods for Evaluating Solid Waste: Physical/Chemical Methods" and "Test Methods for Organic Chemical Analysis of Municipal and Industrial Wastewater". Recommended analytical holding times for sludge samples should reflect those specified in 40 CFR 136.6.3(e). Other guidance is available in USEPA's POTW Sludge Sampling and Analysis Guidance Document, August 1989.

B. Municipal Water Supply

1. Monitoring Location SPL-001

The Discharger shall monitor the Municipal Water Supply at SPL-001 as follows. A sampling station shall be established where a representative sample of the municipal water supply can be obtained. Municipal water supply samples shall be collected at approximately the same time as effluent samples.

Table E-7. Municipal Water Supply Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Electrical Conductivity @ 25°C ¹	umhos/cm	Grab	1/quarter	²

¹ If the water supply is from more than one source, the EC shall be reported as a weighted average and include copies of supporting calculations.

² Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for priority pollutants the methods must meet the lowest minimum levels (MLs) specified in Attachment 4 of the SIP, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board.

X. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. Upon written request of the Regional Water Board, the Discharger shall submit a summary monitoring report. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year(s).

3. **Compliance Time Schedules.** For compliance time schedules included in the Order, the Discharger shall submit to the Regional Water Board, on or before each compliance due date, the specified document or a written report detailing compliance or noncompliance with the specific date and task. If noncompliance is reported, the Discharger shall state the reasons for noncompliance and include an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Regional Water Board by letter when it returns to compliance with the compliance time schedule.
4. The Discharger shall report to the Regional Water Board any toxic chemical release data it reports to the State Emergency Response Commission within 15 days of reporting the data to the Commission pursuant to section 313 of the "Emergency Planning and Community Right to Know Act of 1986."
5. **Reporting Protocols.** The Discharger shall report with each sample result the applicable Reporting Level (RL) and the current Method Detection Limit (MDL), as determined by the procedure in Part 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc."). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
 - d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from *extrapolation* beyond the lowest point of the calibration curve.
 - e. For non-priority pollutants and field lab-measured pollutants and parameters, reporting of the MDL and result is adequate.
6. **Multiple Sample Data.** When determining compliance with an AMEL, AWEL, or MDEL for priority pollutants and more than one sample result is available, the

Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

- a. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
- b. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

B. Self Monitoring Reports (SMRs)

1. At any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit Self-Monitoring Reports (SMRs) using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). Until such notification is given, the Discharger shall submit hard copy SMRs. The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
2. Monitoring results shall be submitted to the Regional Water Board by the **first day of the second month following sample collection**. Quarterly and annual monitoring results shall be submitted by the **first day of the second month following each calendar quarter, semi-annual period, and year**, respectively.
3. In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly whether the discharge complies with waste discharge requirements. The highest daily maximum for the month, monthly and weekly averages, and medians, and removal efficiencies (%) for BOD and Total Suspended Solids, shall be determined and recorded as needed to demonstrate compliance.
4. With the exception of flow, all constituents monitored on a continuous basis (metered), shall be reported as daily maximums, daily minimums, and daily averages; flow shall be reported as the total volume discharged per day for each day of discharge.
5. If the Discharger monitors any pollutant at the locations designated herein more frequently than is required by this Order, the results of such monitoring shall be included in the calculation and reporting of the values required in the discharge

monitoring report form. Such increased frequency shall be indicated on the discharge monitoring report form.

6. A letter transmitting the self-monitoring reports shall accompany each report. Such a letter shall include a discussion of requirement violations found during the reporting period, and actions taken or planned for correcting noted violations, such as operation or facility modifications. If the Discharger has previously submitted a report describing corrective actions and/or a time schedule for implementing the corrective actions, reference to the previous correspondence will be satisfactory. The transmittal letter shall contain the penalty of perjury statement by the Discharger, or the Discharger's authorized agent, as described in the Standard Provisions.
7. SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D), to the address listed below:

Regional Water Quality Control Board
Central Valley Region
415 Knollcrest Drive, Suite #100
Redding, CA 96002-0129

8. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-8. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
Continuous	Permit effective date	All	Submit with monthly SMR
Hourly	Permit effective date	Hourly	Submit with monthly SMR
Daily	Permit effective date	(Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling.	Submit with monthly SMR
Weekly	Sunday following permit effective date or on permit effective date if on a Sunday	Sunday through Saturday	Submit with monthly SMR
Monthly	First day of calendar month following permit effective date or on permit effective date if that date is first day of the month	1 st day of calendar month through last day of calendar month	32 days from the end of the monitoring period
Quarterly	Closest of January 1, April 1, July 1, or October 1 following (or on) permit effective date	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31	32 days from the end of the monitoring period
Semiannually	Closest of January 1 or July 1 following (or on) permit effective date	January 1 through June 30 July 1 through December 31	32 days from the end of the monitoring period

Annually	January 1 following (or on) permit effective date	January 1 through December 31	32 days from the end of the monitoring period
----------	---	-------------------------------	---

C. Discharge Monitoring Reports (DMRs)

- As described in Section X.B.1 above, at any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit SMRs that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.
- DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharger shall submit the original DMR and one copy of the DMR to the address listed below:

Standard Mail	FedEx/UPS/ Other Private Carriers
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 th Floor Sacramento, CA 95814

- All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated cannot be accepted unless they follow the exact same format as EPA form 3320-1.

D. Other Reports

- Progress Reports.** As specified in the compliance time schedules required in Special Provisions VI, progress reports shall be submitted in accordance with the following reporting requirements. At minimum, the progress reports shall include a discussion of the status of final compliance, whether the Discharger is on schedule to meet the final compliance date, and the remaining tasks to meet the final compliance date.

Table E-9. Reporting Requirements for Special Provisions Progress Reports

Special Provision	Reporting Requirements
Pollution Prevention Plan for copper and zinc	1 December , annually, after approval of work plan
Compliance Schedules for Final Effluent Limitations for copper, compliance with final effluent limitations.	1 June , annually, until final compliance

Special Provision	Reporting Requirements
Compliance Schedules for Final Effluent Limitations for copper, Pollution Prevention Plan	1 June , annually, after approval of work plan until final compliance
Compliance Schedules for Final Effluent Limitations for copper, Treatment Feasibility Study (provide link to provision)	1 June , annually, after approval of work plan until final compliance

2. Within **60 days** of permit adoption, the Discharger shall submit a report outlining minimum levels, method detection limits, and analytical methods for approval, with a goal to achieve detection levels below applicable water quality criteria. At a minimum, the Discharger shall comply with the monitoring requirements for CTR constituents as outlined in Section 2.3 and 2.4 of the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California*, adopted 2 March 2000 by the State Water Resources Control Board. All peaks identified by analytical methods shall be reported.
3. The Discharger's sanitary sewer system collects wastewater using sewers, pipes, pumps, and/or other conveyance systems and directs the raw sewage to the wastewater treatment plant. A "sanitary sewer overflow" is defined as a discharge to ground or surface water from the sanitary sewer system at any point upstream of the wastewater treatment plant. Sanitary sewer overflows are prohibited by this Order. All violations must be reported as required in Standard Provisions. Facilities (such as wet wells, regulated impoundments, tanks, highlines, etc.) may be part of a sanitary sewer system and discharges to these facilities are not considered sanitary sewer overflows, provided that the waste is fully contained within these temporary storage facilities.
4. **Annual Operations Report.** By **30 January** of each year, the Discharger shall submit a written report to the Executive Officer containing the following:
 - a. The names, certificate grades, and general responsibilities of all persons employed at the Facility.
 - b. The names and telephone numbers of persons to contact regarding the plant for emergency and routine situations.
 - c. A statement certifying when the flow meter(s) and other monitoring instruments and devices were last calibrated, including identification of who performed the calibration.
 - d. A statement certifying whether the current operation and maintenance manual, and contingency plan, reflect the wastewater treatment plant as currently constructed and operated, and the dates when these documents were last revised and last reviewed for adequacy.

- e. The Discharger may also be requested to submit an annual report to the Regional Water Board with both tabular and graphical summaries of the monitoring data obtained during the previous year. Any such request shall be made in writing. The report shall discuss the compliance record. If violations have occurred, the report shall also discuss the corrective actions taken and planned to bring the discharge into full compliance with the waste discharge requirements.
5. **Annual Pretreatment Reporting Requirements.** The Discharger shall submit annually a report to the Regional Water Board, with copies to US EPA Region 9 and the State Water Board, describing the Discharger's pretreatment activities over the previous 12 months. In the event that the Discharger is not in compliance with any conditions or requirements of this Order, including noncompliance with pretreatment audit/compliance inspection requirements, then the Discharger shall also include the reasons for noncompliance and state how and when the Discharger shall comply with such conditions and requirements.

An annual report shall be submitted by **28 February** and include at least the following items:

- a. A summary of analytical results from representative, flow proportioned, 24-hour composite sampling of the POTW's influent and effluent for those pollutants EPA has identified under Section 307(a) of the CWA which are known or suspected to be discharged by industrial users.

Sludge shall be sampled during the same 24-hour period and analyzed for the same pollutants as the influent and effluent sampling and analysis. The sludge analyzed shall be a composite sample of a minimum of 12 discrete samples taken at equal time intervals over the 24-hour period. Wastewater and sludge sampling and analysis shall be performed at least annually. The discharger shall also provide any influent, effluent or sludge monitoring data for nonpriority pollutants which may be causing or contributing to Interference, Pass-Through or adversely impacting sludge quality. Sampling and analysis shall be performed in accordance with the techniques prescribed in 40 CFR 136 and amendments thereto.

- b. A discussion of Upset, Interference, or Pass-Through incidents, if any, at the treatment plant, which the Discharger knows or suspects were caused by industrial users of the POTW. The discussion shall include the reasons why the incidents occurred, the corrective actions taken and, if known, the name and address of, the industrial user(s) responsible. The discussion shall also include a review of the applicable pollutant limitations to determine whether any additional limitations, or changes to existing requirements, may be necessary to prevent Pass-Through, Interference, or noncompliance with sludge disposal requirements.

- c. The cumulative number of industrial users that the Discharger has notified regarding Baseline Monitoring Reports and the cumulative number of industrial user responses.
- d. An updated list of the Discharger's industrial users including their names and addresses, or a list of deletions and additions keyed to a previously submitted list. The Discharger shall provide a brief explanation for each deletion. The list shall identify the industrial users subject to federal categorical standards by specifying which set(s) of standards are applicable. The list shall indicate which categorical industries, or specific pollutants from each industry, are subject to local limitations that are more stringent than the federal categorical standards. The Discharger shall also list the noncategorical industrial users that are subject only to local discharge limitations. The Discharger shall characterize the compliance status through the year of record of each industrial user by employing the following descriptions:
 - i. complied with baseline monitoring report requirements (where applicable);
 - ii. consistently achieved compliance;
 - iii. inconsistently achieved compliance;
 - iv. significantly violated applicable pretreatment requirements as defined by 40 CFR 403.8(f)(2)(vii);
 - v. complied with schedule to achieve compliance (include the date final compliance is required);
 - vi. did not achieve compliance and not on a compliance schedule; and
 - vii. compliance status unknown.

A report describing the compliance status of each industrial user characterized by the descriptions in items iii. through vii. above shall be submitted for each calendar quarter **within 32 days of the end of the quarter**. The report shall identify the specific compliance status of each such industrial user and shall also identify the compliance status of the POTW with regards to audit/pretreatment compliance inspection requirements. If none of the aforementioned conditions exist, at a minimum, a letter indicating that all industries are in compliance and no violations or changes to the pretreatment program have occurred during the quarter must be submitted. The information required in the fourth quarter report shall be included as part of the annual report. This quarterly reporting requirement shall commence upon issuance of this Order.

- e. A summary of the inspection and sampling activities conducted by the Discharger during the past year to gather information and data regarding the industrial users. The summary shall include:
 - i. the names and addresses of the industrial users subjected to surveillance and an explanation of whether they were inspected, sampled, or both and the frequency of these activities at each user; and
 - ii. the conclusions or results from the inspection or sampling of each industrial user.

- f. A summary of the compliance and enforcement activities during the past year. The summary shall include the names and addresses of the industrial users affected by the following actions:
 - i. Warning letters or notices of violation regarding the industrial users' apparent noncompliance with federal categorical standards or local discharge limitations. For each industrial user, identify whether the apparent violation concerned the federal categorical standards or local discharge limitations.
 - ii. Administrative orders regarding the industrial users noncompliance with federal categorical standards or local discharge limitations. For each industrial user, identify whether the violation concerned the federal categorical standards or local discharge limitations.
 - iii. Civil actions regarding the industrial users' noncompliance with federal categorical standards or local discharge limitations. For each industrial user, identify whether the violation concerned the federal categorical standards or local discharge limitations.
 - iv. Criminal actions regarding the industrial users noncompliance with federal categorical standards or local discharge limitations. For each industrial user, identify whether the violation concerned the federal categorical standards or local discharge limitations.
 - v. Assessment of monetary penalties. For each industrial user identify the amount of the penalties.
 - vi. Restriction of flow to the POTW.
 - vii. Disconnection from discharge to the POTW.
- g. A description of any significant changes in operating the pretreatment program which differ from the information in the Discharger's approved Pretreatment Program including, but not limited to, changes concerning: the program's administrative structure, local industrial discharge limitations, monitoring program or monitoring frequencies, legal authority or enforcement policy, funding mechanisms, resource requirements, or staffing levels.
- h. A summary of the annual pretreatment budget, including the cost of pretreatment program functions and equipment purchases.

Duplicate signed copies of these Pretreatment Program reports shall be submitted to the Regional Water Board and the:

State Water Resources Control Board
Division of Water Quality
P.O. Box 944213
Sacramento, CA 94244-2130

and the

Regional Administrator
U.S. Environmental Protection Agency W-5
75 Hawthorne Street
San Francisco, CA 94105

ATTACHMENT F – FACT SHEET

Table of Contents

Attachment F – Fact Sheet.....	F-1
I. Permit Information	F-1
II. Facility Description	F-2
A. Description of Wastewater and Biosolids Treatment or Controls	F-2
B. Discharge Points and Receiving Waters.....	F-2
C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data	F-3
D. Compliance Summary.....	F-4
E. Planned Changes	F-4
III. Applicable Plans, Policies, and Regulations	F-5
A. Legal Authority	F-5
B. California Environmental Quality Act (CEQA)	F-5
C. State and Federal Regulations, Policies, and Plans	F-5
D. Impaired Water Bodies on CWA 303(d) List	F-7
E. Other Plans, Polices and Regulations.....	F-9
IV. Rationale For Effluent Limitations and Discharge Specifications.....	F-9
A. Discharge Prohibitions	F-10
B. Technology-Based Effluent Limitations.....	F-11
1. Scope and Authority	F-11
2. Applicable Technology-Based Effluent Limitations	F-11
3. Summary of Technology-based Effluent Limitations - Discharge Point D-001 ..	F-12
C. Water Quality-Based Effluent Limitations (WQBELs).....	F-12
1. Scope and Authority	F-12
2. Applicable Beneficial Uses and Water Quality Criteria and Objectives.....	F-12
3. Determining the Need for WQBELs.....	F-18
4. WQBEL Calculations	F-30
5. Summary of Water Quality-based Effluent Limitations – Discharge Point D-001..	F-38
6. Whole Effluent Toxicity (WET)	F-39
D. Final Effluent Limitations.....	F-40
1. Mass-based Effluent Limitations.....	F-40
2. Averaging Periods for Effluent Limitations.....	F-41
3. Satisfaction of Anti-Backsliding Requirements.	F-41
4. Satisfaction of Antidegradation Policy	F-41
5. Summary of Final Effluent Limitations - Discharge Point D-001	F-42
E. Interim Effluent Limitations.....	F-43
F. Land Discharge Specifications.....	F-44
G. Reclamation Specifications	F-44
V. Rationale for Receiving Water Limitations	F-44
A. Surface Water	F-45
B. Groundwater	F-48
VI. Rationale for Monitoring and Reporting Requirements	F-49
A. Influent Monitoring	F-49
B. Effluent Monitoring	F-49
C. Whole Effluent Toxicity Testing Requirements	F-50

D. Receiving Water Monitoring	F-50
1. Surface Water.....	F-50
2. Groundwater – Not Applicable	F-50
E. Other Monitoring Requirements	F-50
VII. Rationale for Provisions.....	F-50
A. Standard Provisions.....	F-50
B. Special Provisions.....	F-51
1. Reopener Provisions	F-51
2. Special Studies and Additional Monitoring Requirements	F-51
3. Best Management Practices and Pollution Prevention	F-55
4. Construction, Operation, and Maintenance Specifications – Not Applicable	F-56
5. Special Provisions for Municipal Facilities (POTWs Only)	F-56
6. Other Special Provisions	F-57
7. Compliance Schedules.....	F-58
VIII. Public Participation	F-59
A. Notification of Interested Parties	F-59
B. Written Comments	F-59
C. Public Hearing	F-59
D. Waste Discharge Requirements Petitions.....	F-60
E. Information and Copying.....	F-60
F. Register of Interested Persons	F-60
G. Additional Information	F-60

List of Tables

Table F-1. Facility Information	F-1
Table F-2. Historic Effluent Limitations and Monitoring Data	F-3
Table F-3. Historical Effluent Flow	F-4
Table F-4. Summary of Technology-based Effluent Limitations	F-12
Table F-5. Effluent and Receiving Water Flows for Calculating Dilution Ratios.....	F-17
Table F-6. Summary of Reasonable Potential Analysis.....	F-20
Table F-7. Summary of Applicable Priority Pollutant Criterion/Objectives	F-21
Table F-8. Salinity Water Quality Criteria/Objectives	F-28
Table F-9. Dilution Credits for Water Quality Criteria.....	F-32
Table F-10. WQBEL Calculations for Copper	F-33
Table F-11. WQBEL Calculations for Zinc	F-33
Table F-12. WQBEL Calculations for Cyanide.....	F-34
Table F-13. WQBEL Calculations for Chlorodibromomethane	F-34
Table F-14. WQBEL Calculations for Dichlorobromomethane.....	F-34
Table F-15. WQBEL Calculations for alpha-BHC	F-35
Table F-16. WQBEL Calculations for beta-BHC	F-35
Table F-17. WQBEL Calculations for gamma-BHC	F-35
Table F-18. Calculation of Effluent Concentration Allowance (ECA)	F-36
Table F-19. WQBEL Calculation Summary Table ¹	F-37
Table F-20. Summary of Water Quality-based Effluent Limitations	F-38
Table F-21. Summary of Final Effluent Limitations	F-42
Table F-22. Copper Interim AMEL Calculation Summary	F-44

ATTACHMENT F – FACT SHEET

As described in section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table F-1. Facility Information

WDID	5A450103004
Discharger	City of Redding
Name of Facility	Stillwater Wastewater Treatment Facility, Anderson
Facility Address	6475 Airport Road
	Anderson, CA 96007
	Shasta County
Facility Contact, Title and Phone	John Szychulda, Plant Supervisor, (530) 378-6702
Authorized Person to Sign and Submit Reports	John Szychulda, Plant Supervisor, (530) 378-6702 Dennis McBride, Wastewater Utility Manager, (530) 224-6063
Mailing Address	P.O. Box 917, Anderson, CA 96007
Billing Address	P.O. Box 496071, Redding, CA 96049
Type of Facility	POTW
Major or Minor Facility	Major
Threat to Water Quality	1
Complexity	A
Pretreatment Program	Y
Reclamation Requirements	Producer (offsite fodder crop and onsite irrigation) Water Reclamation Requirements Order No. 98-016
Facility Design Flow	4.0 mgd
Watershed	Sacramento River
Receiving Water	Sacramento River
Receiving Water Type	Inland surface water

- A.** The City of Redding (hereinafter Discharger) is the owner and operator of the Stillwater Wastewater Treatment Facility (hereinafter Facility), a Publicly Owned Treatment Works.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B.** The Facility discharges wastewater to the Sacramento River, a water of the United States, and is currently regulated by Order No. 5-01-216 which was adopted on 7 September 2001 and expired on 1 September 2006. The terms and conditions of the current Order have been automatically continued and remain in effect until new Waste Discharge Requirements and NPDES permit are adopted pursuant to this Order.
- C.** The Discharger filed a report of waste discharge and submitted an application for renewal of its Waste Discharge Requirements (WDRs) and National Pollutant Discharge Elimination System (NPDES) permit on 28 February 2006. Supplemental information was received on 6 February 2007 (Translator Study), 1 February 2007 (additional priority pollutant data), and 8 March 2007 (receiving water dilution ratio data). A site visit was conducted on 18 October 2006, to observe operations and collect additional data to develop permit limitations and conditions.

II. FACILITY DESCRIPTION

The Discharger provides sewerage service for the community of Redding, CA and serves a population of approximately 8,500. The WWTP design dry weather average flow capacity is 4.0 mgd.

A. Description of Wastewater and Biosolids Treatment or Controls

The treatment system at the Facility consists of screening for removal of large solids; activated sludge treatment with secondary clarification, filtration, and chlorination/dechlorination. Waste activated sludge is treated by aerobic digestion followed by belt-filter-press dewatering. Biosolids are disposed at a sanitary landfill and land applied on property owned by the Discharger. The Report of Waste Discharge describes the discharge as follows:

Design Average Dry Weather Flow:	4.0 mgd
Design Peak Month Wet Weather Flow:	6.0 mgd
Design Peak Day Wet Weather Flow:	8.4 mgd

B. Discharge Points and Receiving Waters

1. The Facility (Assessor's Parcel No. 056-400-07) is located in Section 12, T30N, R4W, MDB&M, as shown in Attachment B (Figure B-1), a part of this Order.

2. Treated municipal wastewater is discharged at Discharge Point 001 to the Sacramento River, a water of the United States at a point latitude 40° 28' 26.8"N and longitude 122° 16' 07.5"W.
3. Discharge Point 001 is located within the Enterprise Flat Hydrologic Area (508.10) of the Redding Hydrologic Unit as defined by the interagency hydrologic map for the Sacramento Hydrologic Basin prepared by the Department of Water Resources (1986).
4. An additional receiving water monitoring location (R-001a) is located at the Caldwell Park boat launch ramp in Redding at a point latitude 40° 35' 38.2"N and longitude 122° 23' 54.0"W. Receiving water location R-001a is utilized as the upstream station of four major discharges (3 POTWs and 1 industrial discharger) within a 11 mile reach of the Sacramento River, with Stillwater WWTF as the farthest downstream discharger. Monitoring at R-001a facilitates the allocation of assimilative capacity in the receiving water throughout this reach of river.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

Effluent limitations contained in the existing Order for discharges from discharge point D-001 (Monitoring Location EFF-001) and representative monitoring data from the term of the previous Order are as follows:

Table F-2. Historic Effluent Limitations and Monitoring Data

Parameter	Units	Effluent Limitations					Monitoring Data Jan. 2004 – Dec. 2006	
		Average Monthly	Average Weekly	Max Daily	4-day Average	Monthly Median	Highest Average Monthly Discharge	Highest Daily Discharge
BOD ¹	mg/L	10	15	30	--	--	2.3	3.2
	lbs/day ²	334	500	1001			86.6	132.6
	lbs/day	500 ³	751 ³	2102 ⁴			143.5	285.9
Total Suspended Solids	mg/L	10	15	30	--	--	2.2	3.0
	lbs/day ²	334	500	1001			105.8	150.0
	lbs/day	500 ³	751 ³	2102 ⁴			207.6	664.1
Chlorine Residual	mg/L	--	--	0.02 ⁵	0.01	--	<0.01	<0.01
Total Coliform Organisms	MPN/100mL	--	--	500	--	23	<2 ⁶	13
pH	pH units			9.0 ⁷			8.0	8.2 ⁽⁸⁾

¹ 5-day, 20°C Biochemical Oxygen Demand (BOD)

² Based upon a design dry weather treatment capacity of 4.0 mgd, applicable from May through September

³ Based upon a design peak-month wet weather flow of 6.0 mgd, applicable from October through April

⁴ Based upon a design peak-month wet weather flow of 8.4 mgd, applicable from October through April

⁵ 1-hour average

⁶ Average monthly median

⁷ pH shall be between 6.0 and 9.0

⁸ Instantaneous maximum

Effluent limits contained in the existing Order included an effluent flow limit of 4.0 mgd from July through September. Historical effluent flow is presented in Table F-3:

Table F-3. Historical Effluent Flow

Effluent Discharge (mgd)	<u>Dry Weather</u>		<u>Wet Weather</u>
	Design Average Dry Weather Flow: 4.0 Discharge Limit (July-September): 4.0		Design Peak Month Wet Weather Flow: 6.0 Design Peak Day Wet Weather Flow: 8.4
	May – September	July – September	October - April
<u>Monthly Average</u> ⁽¹⁾			
Min	2.6	2.6	2.6
Max	4.9	3.0	6.8
Average	3.1	2.8	4.6
<u>Peak Daily Average</u> ⁽²⁾			
Min	2.8	2.8	2.8
Max	7.7	3.6	11.7

(1) Based on reported monthly flow averages from January 2003 through December 2006

(2) Based on reported peak daily averages from July 2003 through December 2006.

D. Compliance Summary

The following is a summary of violations noted during the monthly monitoring and reporting review since the last permit cycle:

<u>Year</u>	<u>Effluent Discharge Violations</u>
2001	None noted.
2002	None noted.
2003	On 8 and 9 October 2003 the pH of the plant effluent to the Sacramento River was depressed below the permit lower limit of 6.0
2004	None noted.
2005	None noted.

E. Planned Changes

In June 2006, during preparation work for a site-specific mixing zone study, the Discharger discovered the outfall diffuser to be buried by approximately 8 to 10 feet of river sediment. A dive inspection revealed only one port (out of the 20 ports) had not been covered in sediment. The open port is located closest to the left bank of the river and is functioning with effluent outflow although rock was detected in the diffuser line. A 6 September 2006 dye analysis of the outfall confirmed the operation of the one port and the likelihood of no significant effluent discharge from the other 19 ports. The Discharger is currently exploring repair options and new outfall designs and subsequent

construction permitting issues. This Order contains a compliance schedule for the repair and/or replacement of the effluent outfall diffuser.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in this Order are based on the applicable plans, policies, and regulations identified in section II of the Limitations and Discharge Requirements (Findings). This section provides supplemental information, where appropriate, for the plans, policies, and regulations relevant to the discharge.

A. Legal Authority

See Limitations and Discharge Requirements - [Findings](#), Section II.C.

B. California Environmental Quality Act (CEQA)

See Limitations and Discharge Requirements - Findings, Section II.E.

C. State and Federal Regulations, Policies, and Plans

Water Quality Control Plans.

1. The Regional Water Board adopted a *Water Quality Control Plan, Fourth Edition (Revised August 2006)*, for the Sacramento and San Joaquin River Basins (Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, State Water Board Resolution No. 88-63 requires that, with certain exceptions, the Regional Water Board assign the municipal and domestic supply use to water bodies that do not have beneficial uses listed in the Basin Plan. The beneficial uses of the Sacramento River downstream of the discharge are municipal and domestic supply; agricultural supply, including stock watering; industrial service supply; hydropower generation; water contact recreation, including canoeing and rafting; non-contact water recreation, including aesthetic enjoyment; commercial and sport fishing; warm freshwater habitat; cold freshwater habitat; warm migration of aquatic organisms; cold migration of aquatic organisms; warm spawning, reproduction, and/or early development; cold spawning, reproduction, and /or early development; wildlife habitat; and navigation.

The Basin Plan on page II-1.00 states: “*Protection and enhancement of existing and potential beneficial uses are primary goals of water quality planning...*” and with respect to disposal of wastewaters states that “*...disposal of wastewaters is [not] a prohibited use of waters of the State; it is merely a use which cannot be satisfied to the detriment of beneficial uses.*”

The federal CWA section 101(a)(2), states: “*it is the national goal that wherever attainable, an interim goal of water quality which provides for the protection and propagation of fish, shellfish, and wildlife, and for recreation in and on the water be achieved by July 1, 1983.*” Federal Regulations, developed to implement the requirements of the CWA, create a rebuttable presumption that all waters be designated as fishable and swimmable. Federal Regulations, 40 CFR sections

131.2 and 131.10, require that all waters of the State regulated to protect the beneficial uses of public water supply, protection and propagation of fish, shell fish and wildlife, recreation in and on the water, agricultural, industrial and other purposes including navigation. Section 131.3(e), 40 CFR, defines existing beneficial uses as those uses actually attained after November 28, 1975, whether or not they are included in the water quality standards. Federal Regulation, 40 CFR section 131.10 requires that uses be obtained by implementing effluent limitations, requires that all downstream uses be protected and states that in no case shall a state adopt waste transport or waste assimilation as a beneficial use for any waters of the United States.

This Order contains Effluent Limitations requiring an advanced secondary level of treatment, which is necessary to protect the beneficial uses of the receiving water. The Regional Water Board has considered the factors listed in CWC section 13241 in establishing these requirements, as discussed in more detail in the Fact Sheet, Attachment F, Section IV.

1. **Thermal Plan. Not Applicable.**
2. **Bay-Delta Plan. Not Applicable.**
3. **Antidegradation Policy.** Section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. As discussed in detail in the Fact Sheet (Attachment F, Section IV.D.4.) the discharge is consistent with the antidegradation provisions of 40 CFR section 131.12 and State Water Board Resolution 68-16.
4. **Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40, Code of Federal Regulations section 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed. Compliance with the Anti-Backsliding requirements is discussed in Section IV.D.3.
5. **Emergency Planning and Community Right to Know Act.** Section 13263.6(a), California Water Code, requires that "*the Regional Water Board shall prescribe effluent limitations as part of the waste discharge requirements of a POTW for all substances that the most recent toxic chemical release data reported to the state emergency response commission pursuant to Section 313 of the Emergency Planning and Community Right to Know Act of 1986 (42 U.S.C. Sec. 11023) (EPCRKA) indicate as discharged into the POTW, for which the State Water Board or the Regional Water Board has established numeric water quality objectives, and*

has determined that the discharge is or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to, an excursion above any numeric water quality objective".

The Regional Water Board has adopted numeric water quality objectives in the Water Quality Control Plan for the Sacramento River Basin (Basin Plan) for the following constituents: arsenic, barium, cadmium, copper, cyanide, iron, manganese, silver, and zinc for which numeric water quality objectives have been adopted for the receiving waters involved in this discharge. As detailed elsewhere in this Permit, available effluent quality data indicate that zinc does have a reasonable potential to cause or contribute to an excursion above the numeric water quality objective included within the Basin Plan. An effluent limitation for zinc is included in this permit.

The most recent toxic chemical data report does not indicate any reportable off-site releases or discharges to the collection system for this facility. Therefore, a reasonable potential analysis based on information from Emergency Planning and Community Right to Know Act (EPCRA) cannot be conducted. Based on information from EPCRA, there is no reasonable potential to cause or contribute to an excursion above any numeric water quality objectives included within the Basin Plan or in any State Water Board plan, so no effluent limitations are included in this permit pursuant to CWC section 13263.6(a).

However, as detailed elsewhere in this Order, available effluent data indicate that there are constituents present in the effluent that have a reasonable potential to cause or contribute to exceedances of water quality standards and require inclusion of effluent limitations based on federal and state laws and regulations.

6. **Stormwater Requirements.** USEPA promulgated Federal Regulations for storm water on 16 November 1990 in 40 CFR Parts 122, 123, and 124. The NPDES Industrial Storm Water Program regulates storm water discharges from wastewater treatment facilities. Wastewater treatment plants are applicable industries under the stormwater program and are obligated to comply with the Federal Regulations.
7. **Endangered Species Act.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code sections 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A. sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The Discharger is responsible for meeting all requirements of the applicable Endangered Species Act.

D. Impaired Water Bodies on CWA 303(d) List

1. Under Section 303(d) of the 1972 Clean Water Act, states, territories and authorized tribes are required to develop lists of water quality limited segments. The waters on these lists do not meet water quality standards, even after point sources of pollution

have installed the minimum required levels of pollution control technology. On July 25, 2003 USEPA gave final approval to California's 2002 Section 303(d) List of Water Quality Limited Segments. The Basin Plan references this list of Water Quality Limited Segments (WQLSs), which are defined as "...those sections of lakes, streams, rivers or other fresh water bodies where water quality does not meet (or is not expected to meet) water quality standards even after the application of appropriate limitations for point sources (40 CFR 130, et seq.)." The Basin Plan also states, "Additional treatment beyond minimum federal standards will be imposed on dischargers to [WQLSs]. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be met in the segment." The listing for the Sacramento River from Keswick Dam to Cottonwood Creek includes: cadmium, copper, zinc, and unknown toxicity. The listing for the metals is mainly a result of long term affects of mining operations at Iron Mountain Mine (located along this reach of river) in addition to other mines up stream of Shasta Dam.

2. **Total Maximum Daily Loads.** The US EPA requires the Regional Water Board to develop total maximum daily loads (TMDLs) for each 303(d) listed pollutant and water body combination. The listing for unknown toxicity has a proposed TMDL completion date of 2019.

In April 2002, the Regional Board published the *Upper Sacramento River TMDL for Cadmium, Copper, and Zinc* final report. A waste load allocation and/or effluent limitations were not established by the final report, rather, proposed numeric acute and chronic targets for dissolved cadmium, copper, and zinc were issued as part of a TMDL program. Due to the proposed remedial activities scheduled for Iron Mountain Mine and other mine sites during the next five years, Regional Board staff proposed a 5-year TMDL water management strategy that included monitoring by NPDES-permitted dischargers for dissolved cadmium, copper, and zinc, and flow to quantify their dissolved metal loads. Review of ambient metal concentration data collected by staff, other agencies, and dischargers will allow for the determination of whether the upstream remediation efforts enable dissolved metal concentrations in the Sacramento River water to comply with the proposed targets. A review of the TMDL along with USEPA's 5-year review for the Iron Mountain Mine site is scheduled for 2008. This Order includes effluent and receiving water cadmium, copper, and zinc monitoring to comply with the TMDL water management strategy and for use in the review of the proposed numeric targets.

In addition, the May 2004 completion of Slickrock Creek Dam downstream of the Iron Mountain Mine site resulted in a significant decrease of cadmium, copper, and zinc from historic levels within the Sacramento River, downstream of Keswick Dam. For this reason the background receiving water data set for cadmium, copper, zinc, hardness, and pH only include data collected after the May 2004 completion of the Slickrock Creek Dam.

This Order contains a reopen provision to modify permit requirements, as necessary, to implement any changes to the TMDL.

E. Other Plans, Polices and Regulations

1. The discharge authorized herein and the treatment and storage facilities associated with the discharge of treated municipal wastewater, except for discharges of residual sludge and solid waste, are exempt from the requirements of Title 27, California Code of Regulations (CCR), section 20005 *et seq.* (hereafter Title 27). The exemption, pursuant to Title 27 CCR section 20090(a), is based on the following:
 - a. The waste consists primarily of domestic sewage and treated effluent;
 - b. The waste discharge requirements are consistent with water quality objectives; and
 - c. The treatment and storage facilities described herein are associated with a municipal wastewater treatment plant.
2. The State Water Board adopted the *Water Quality Control Policy for the Enclosed Bays and Estuaries of California*. The requirements within this Order are consistent with the Policy.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

Effluent limitations and toxic and pretreatment effluent standards established pursuant to Sections 301 (Effluent Limitations), 302 (Water Quality Related Effluent Limitations), 304 (Information and Guidelines), and 307 (Toxic and Pretreatment Effluent Standards) of the Clean Water Act (CWA) and amendments thereto are applicable to the discharge.

The Federal CWA mandates the implementation of effluent limitations that are as stringent as necessary to meet water quality standards established pursuant to state or federal law [33 U.S.C., § 1311(b)(1)(C); 40 CFR, § 122.44(d)(1)]. NPDES permits must incorporate discharge limits necessary to ensure that water quality standards are met. This requirement applies to narrative criteria as well as to criteria specifying maximum amounts of particular pollutants. Pursuant to Federal Regulations, 40 CFR Section 122.44(d)(1)(i), NPDES permits must contain limits that control all pollutants that “*are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any state water quality standard, including state narrative criteria for water quality.*” Federal Regulations, 40 CFR, §122.44(d)(1)(vi), further provide that “[w]here a state has not established a water quality criterion for a specific chemical pollutant that is present in an effluent at a concentration that causes, has the reasonable potential to cause, or contributes to an excursion above a narrative criterion within an applicable State water quality standard, the permitting authority must establish effluent limits.”

The CWA requires point source discharges to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations

and other requirements in NPDES permits. There are two principal bases for effluent limitations: 40 CFR §122.44(a) requires that permits include applicable technology-based limitations and standards, and 40 CFR §122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water where numeric water quality objectives have not been established. The Regional Water Board's Basin Plan, page IV-17.00, contains an implementation policy ("Policy for Application of Water Quality Objectives" that specifies that the Regional Water Board "*will, on a case-by-case basis, adopt numerical limitations in orders which will implement the narrative objectives.*" This Policy complies with 40 CFR §122.44(d)(1). With respect to narrative objectives, the Regional Water Board must establish effluent limitations using one or more of three specified sources, including (1) EPA's published water quality criteria, (2) a proposed state criterion (*i.e.*, water quality objective) or an explicit state policy interpreting its narrative water quality criteria (*i.e.*, the Regional Water Board's "Policy for Application of Water Quality Objectives") (40 CFR 122.44(d)(1) (vi) (A), (B) or (C)), or (3) an indicator parameter. The Basin Plan contains a narrative objective requiring that: "*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life*" (narrative toxicity objective). The Basin Plan requires the application of the most stringent objective necessary to ensure that surface water and groundwater do not contain chemical constituents, discoloration, toxic substances, radionuclides, or taste and odor producing substances that adversely affect beneficial uses. The Basin Plan states that material and relevant information, including numeric criteria, and recommendations from other agencies and scientific literature will be utilized in evaluating compliance with the narrative toxicity objective. The Basin Plan also limits chemical constituents in concentrations that adversely affect surface water beneficial uses. For waters designated as municipal, the Basin Plan specifies that, at a minimum, waters shall not contain concentrations of constituents that exceed Maximum Contaminant Levels (MCL) of CCR Title 22. The Basin Plan further states that, to protect all beneficial uses, the Regional Water Board may apply limits more stringent than MCLs.

A. Discharge Prohibitions

1. *As stated in section I.G of Attachment D, Standard Provisions, this Order prohibits bypass from any portion of the treatment facility. Federal Regulations, 40 CFR 122.41 (m), define "bypass" as the intentional diversion of waste streams from any portion of a treatment facility. This section of the Federal Regulations, 40 CFR 122.41 (m)(4), prohibits bypass unless it is unavoidable to prevent loss of life, personal injury, or severe property damage. In considering the Regional Water Board's prohibition of bypasses, the State Water Board adopted a precedential decision, Order No. WQO 2002-0015, which cites the Federal Regulations, 40 CFR 122.41(m), as allowing bypass only for essential maintenance to assure efficient operation.*

B. Technology-Based Effluent Limitations

1. Scope and Authority

Regulations promulgated in section 125.3(a)(1) require technology-based effluent limitations for municipal Dischargers to be placed in NPDES permits based on Secondary Treatment Standards or Equivalent to Secondary Treatment Standards.

The Federal Water Pollution Control Act Amendments of 1972 (PL 92-500) established the minimum performance requirements for POTWs [defined in section 304(d)(1)]. Section 301(b)(1)(B) of that Act requires that such treatment works must, as a minimum, meet effluent limitations based on secondary treatment as defined by the USEPA Administrator.

Based on this statutory requirement, USEPA developed secondary treatment regulations, which are specified in Part 133. These technology-based regulations apply to all municipal wastewater treatment plants and identify the minimum level of effluent quality attainable by secondary treatment in terms of biochemical oxygen demand (BOD_5), total suspended solids (TSS), and pH.

2. Applicable Technology-Based Effluent Limitations

- a. **BOD_5 and TSS.** Federal Regulations, 40 CFR, Part 133, establish the minimum weekly and monthly average level of effluent quality attainable by secondary treatment for BOD_5 and TSS. However, based on Best Professional Judgment (BPJ) an advanced secondary level of treatment is necessary to protect the beneficial uses of the receiving stream and the final effluent limitations for BOD_5 and TSS are based on the technical capability of an advanced secondary process. BOD_5 is a measure of the amount of oxygen used in the biochemical oxidation of organic matter. These standards for BOD_5 and TSS are indicators of the effectiveness of the treatment processes. The principal design parameter for wastewater treatment plants is the daily BOD_5 and TSS loading rates and the corresponding removal rate of the system. In applying 40 CFR Part 133 for weekly and monthly average BOD_5 and TSS limitations, the application of advanced secondary treatment processes results in the ability to achieve lower levels for BOD_5 and TSS than the secondary standards currently prescribed; the 30-day average BOD_5 and TSS limitations have been revised to 10 mg/L, which is technically based on the capability of an advanced secondary system. In addition to the average weekly and average monthly effluent limitations, a daily maximum effluent limitation for BOD_5 and TSS is included in the Order to ensure that the treatment works are not organically overloaded and operate in accordance with design capabilities. See Table F-4 for final technology-based effluent limitations required by this Order. In addition, 40 CFR 133.102, in describing the minimum level of effluent quality attainable by secondary treatment, states that the 30-day average percent removal shall not be less than 85 percent. If 85 percent removal of BOD_5 and TSS must be achieved by a secondary treatment plant, it must also be achieved by an advanced secondary

treatment plant. This Order contains a limitation requiring an average of 85 percent removal of BOD₅ and TSS over each calendar month.

b. **Flow.** The Stillwater Wastewater Treatment Facility was designed to provide an advanced secondary level of treatment for up to a design flow of 4.0 mgd. Therefore, this Order contains an average daily dry weather (May through September) discharge flow effluent limit of 4.0 mgd. Effluent discharge flows occurring in May shall be excluded from this limitation if significant rain events occur or seasonal high groundwater conditions persist during the month of May.

3. Summary of Technology-based Effluent Limitations - Discharge Point D-001

Table F-4. Summary of Technology-based Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
BOD ₅ ^a	mg/L lbs/day ^b	10 334	15 500	30 1001	--	--
Total Suspended Solids	mg/L lbs/day ^b	10 334	15 500	30 1001	--	--
pH	standard units	--	--	--	6.0	9.0
Removal	85% removal BOD ₅ and TSS					

^a 5-day, 20°C Biochemical Oxygen Demand (BOD).

^b Based upon a dry weather treatment design flow of 4.0 mgd.

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

As specified in section 122.44(d)(1)(i), permits are required to include WQBELs for pollutants (including toxicity) that are or may be discharged at levels that cause, have reasonable potential to cause, or contribute to an in-stream excursion above any state water quality standard. The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

a. **Receiving Water.** The receiving water for the Stillwater Wastewater Treatment Facility is the Sacramento River. The beneficial uses downstream of the discharge are municipal and domestic supply; agricultural supply, including stock watering; industrial service supply; hydropower generation; water contact

recreation, including canoeing and rafting; non-contact water recreation, including aesthetic enjoyment; commercial and sport fishing; warm freshwater habitat; cold freshwater habitat; warm migration of aquatic organisms; cold migration of aquatic organisms; warm spawning, reproduction, and/or early development; cold spawning, reproduction, and /or early development; wildlife habitat; and navigation.

- b. **Hardness.** While no effluent limitation for hardness is necessary in this Order, hardness is critical to the assessment of the need for, and the development of, effluent limitations for certain metals. The *California Toxics Rule*, at (c)(4), states the following:

“Application of metals criteria. (i) For purposes of calculating freshwater aquatic life criteria for metals from the equations in paragraph (b)(2) of this section, for waters with a hardness of 400 mg/L or less as calcium carbonate, the actual ambient hardness of the surface water shall be used in those equations.”
[emphasis added]

The State Water Board, in footnote 19 to Water Quality Order No. 2004-0013, stated: “*We note that...the Regional Water Board...applied a variable hardness value whereby effluent limitations will vary depending on the actual, current hardness values in the receiving water. We recommend that the Regional Water Board establish either fixed or seasonal effluent limitations for metals, as provided in the SIP, rather than ‘floating’ effluent limitations.*”

Effluent limitations for the discharge must be set to protect the beneficial uses of the receiving water for all discharge conditions. In the absence of the option of including condition-dependent, “floating” effluent limitations that are reflective of actual conditions at the time of discharge, effluent limitations must be set using a reasonable worst-case condition in order to protect beneficial uses for all discharge conditions. For purposes of establishing water quality-based effluent limitations, a reported hardness value of 44 mg/L as CaCO₃ and a pH value of 7.19 were used. The values are the minimum observed hardness and pH value based on 28 samples collected from the receiving water from June 2004 through November 2006.

- c. **Assimilative Capacity/Mixing Zone.** The CWA directs states to adopt water quality standards to protect the quality of its waters. USEPA’s current water quality standards regulation authorizes states to adopt general policies, such as for mixing zones, to implement state water quality standards (40 CFR section 122.44 and section 122.45). The USEPA allows states to have broad flexibility in designing its mixing zone policies. Primary policy and guidance on determining mixing zone and dilution credits is provided by the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays and Estuaries of California (State Implementation Policy or SIP), the USEPA Technical Support Document for Water Quality-Based Toxics Control (EPA/505/2-90-001) (TSD), and the Basin Plan. For NPDES permits in California, the SIP policy supersedes

the USEPA guidance for priority pollutants, to the extent that it addresses a particular procedure. The SIP does not apply to non-priority pollutants, in which case the more stringent of the Basin Plan or USEPA guidance applies.

The allowance of mixing zones by the Central Valley Water Board is discussed in the Basin Plan, Policy for Application of Water Quality Objectives, which states in part, *"In conjunction with the issuance of NPDES and storm water permits, the Regional Board may designate mixing zones within which water quality objectives will not apply provided the discharger has demonstrated to the satisfaction of the Regional Board that the mixing zone will not adversely impact beneficial uses. If allowed, different mixing zones may be designated for different types of objectives, including, but not limited to, acute aquatic life objectives, chronic aquatic life objectives, human health objectives, and acute and chronic whole effluent toxicity objectives, depending in part on the averaging period over which the objectives apply. In determining the size of such mixing zones, the Regional Board will consider the applicable procedures and guidelines in the EPA's Water Quality Standards Handbook and the [TSD]. Pursuant to EPA guidelines, mixing zones designated for acute aquatic life objectives will generally be limited to a small zone of initial dilution in the immediate vicinity of the discharge."*

Section 1.4.2 of the SIP states, in part, *"...with the exception of effluent limitations derived from TMDLs, in establishing and determining compliance with effluent limitations for applicable human health, acute aquatic life, or chronic aquatic life priority pollutant criteria/objectives or the toxicity objective for aquatic life protection in a basin plan, the Regional Board may grant mixing zones and dilution credits to dischargers ... The applicable priority pollutant criteria and objectives are to be met throughout a water body except within any mixing zone granted by the Regional Board. The allowance of mixing zones is discretionary and shall be determined on a discharge-by-discharge basis. The Regional Board may consider allowing mixing zones and dilution credits only for discharges with a physically identifiable point of discharge that is regulated through an NPDES permit issued by the Regional Board."*

Section 1.4.2.1 of the SIP defines a dilution credit as, *"a numerical value associated with the mixing zone that accounts for the receiving water entrained into the discharge. The dilution credit is a value used in the calculation of effluent limitations. Dilution credits may be limited or denied on a pollutant-by-pollutant basis, which may result in a dilution credit for all, some or no priority pollutants in a discharge."*

Regarding mixing zones, the SIP states, *"A mixing zone shall be as small as practicable. The following conditions must be met in allowing a mixing zone:*

A: *A mixing zone shall not:*

- (1) *compromise the integrity of the entire water body;*

- (2) cause acutely toxic conditions to aquatic life passing through the mixing zone;
- (3) restrict the passage of aquatic life;
- (4) adversely impact biologically sensitive or critical habitats, including, but not limited to, habitat of species listed under federal or State endangered species laws;
- (5) produce undesirable or nuisance aquatic life;
- (6) result in floating debris, oil, or scum;
- (7) produce objectionable color, odor, taste, or turbidity;
- (8) cause objectionable bottom deposits;
- (9) cause nuisance;
- (10) dominate the receiving water body or overlap a mixing zone from different outfalls; or
- (11) be allowed at or near any drinking water intake. A mixing zone is not a source of drinking water. To the extent of any conflict between this determination and the Sources of Drinking Water Policy (Resolution No. 88-63), this SIP supersedes the provisions of that policy."

The mixing zone is thus an administrative construct defined as an area around the outfall that may exceed water quality objectives, but is otherwise protective of the beneficial uses. Dilution is defined as the amount of mixing that has occurred at the edge of this mixing zone under critical conditions, thus protecting the beneficial uses at the concentration and for the duration and frequency required. The Discharger plans to perform a mixing zone study to determine the actual dilution credit provided by the discharge diffuser. A summary of available dilution for specific criteria is included in Table F-5.

- d. **Evaluation of Available Dilution for Acute Aquatic Life Criteria.** The SIP requires that if a year-round dilution credit is to be considered for establishing effluent limitations for priority pollutants regulated under the California Toxics Rule (CTR), critical receiving water flow and maximum discharged effluent flows must be evaluated as part of the dilution calculation. For acute aquatic life criteria, the SIP requires an evaluation of the lowest one-day receiving water flow with a statistical frequency of once every 10 years (1Q10) compared against the maximum daily effluent flow during the discharge period. Based on information provided by the Discharger, the 1Q10 flow rate of the Sacramento River at the Stillwater Wastewater Treatment Facility is **2,750 cfs**.
- e. **Evaluation of Available Dilution for Chronic Aquatic Life Criteria.** The TSD states that: "Concentrations above the chronic criteria are likely to prevent sensitive taxa from taking up long-term residence in the mixing zone. In this regard, benthic organisms and territorial organisms are likely to be of greatest concern. The higher the concentration occurring within the isopleths, the more taxa are likely to be

excluded, thereby affecting the structure and function of the ecological community. It is thus important to minimize the overall size of the mixing zone and the size of elevated concentration isopleths within the mixing zone."

For the determination of a year-round chronic aquatic life criteria dilution credit, the SIP requires an evaluation of the lowest seven (7) consecutive day receiving water flows with a statistical frequency of once every 10 years (7Q10) compared against the four-day average of daily maximum effluent discharge flows during the discharge period. Based on information provided by the Discharger, the 7Q10 flow rate is **2,880 cfs**.

f. **Evaluation of Available Dilution for Priority Pollutant Human Health Criteria.**

The human health-based criteria for carcinogens, other than arsenic, are based on safe levels for lifetime exposure and dilution is based on the harmonic mean flow of the receiving water. In determining the available receiving water dilution for compliance with human carcinogen criteria, the SIP, section 1.4.2.1 requires that the harmonic mean of the receiving water flow be compared against the arithmetic mean of the effluent flow of the observed discharge period. Based on information provided by the Discharger, the harmonic mean flow rate is **6,850 cfs**.

g. **Evaluation of Available Dilution for Pathogen/Disinfection Considerations.**

The Sacramento River has the designated beneficial use of drinking water/municipal supply and must be protected for that use. For agricultural use and body contact recreational uses, the impacts to human health can result from very short exposures and can occur at or near the outfall. The quality of the discharge must be protective of drinking water/municipal supply, body contact recreation, and agricultural supply within as short a distance downstream of the outfall as possible. In a letter to the Central Valley Water Board dated April 8, 1999, the California Department of Health Services (DHS) indicated that they would consider wastewater discharged to water bodies with identified beneficial uses of irrigation and contact recreation to be adequately disinfected if: 1) the wastewater receives dilution of more than 20:1; 2) the effluent coliform concentration does not exceed 23 MPN/100 mL as a 7-day median; and 3) effluent coliform density does not exceed 240 MPN/100 mL more than once in any 30 day period. Municipal water supply is a beneficial use of the Sacramento River, as noted above. DHS recommends that samples be obtained for coliform at least twice per week if this coliform effluent limitation is used. Currently there is nearly **148:1 dilution** available under the most critical conditions.

Table F-5. Effluent and Receiving Water Flows for Calculating Dilution Ratios

Dilution Ratio for:	Critical Receiving Water Flow ¹ (cfs)	Discharge Effluent Flow ² (cfs)	Dilution Ratio
Acute aquatic life criteria/objectives	<u>1Q10</u> 2,750	Maximum daily flow during period of discharge 18.6	148:1
Chronic aquatic life criteria/objectives Chronic toxicity objectives for aquatic life	<u>7Q10</u> 2,880	4-day average of daily maximum flows during period of discharge 18.6	155:1
Human Health criteria/objectives	<u>Harmonic Mean</u> 6,850	Long-term arithmetic mean flow during period of discharge 6.4	1077:1

¹ Data period: 1 July 1986 through 30 June 2006, USGS 11370500 Sacramento River at Keswick and 11372000 Clear Creek at Igo.

² Data period: 1 March 2005 – 28 Feb. 2007

h. Site-Specific Translators. The Discharger has collected Sacramento River data for low level metals in samples collected at Caldwell Park boat launch in Redding since January 1998 to more thoroughly investigate background concentrations of constituents where historical data show levels are at or near water quality criteria/objectives. Receiving water data indicate that the EPA standard conversion factors (translators) may not be representative of the dissolved fraction of copper and zinc in this reach of the Sacramento River. On 6 February 2007 the Discharger submitted a metal translator report based on receiving water data collected since the May 2004 completion of the Slickrock Creek Dam. The installation of the Slickrock Creek Dam was part of the remedial efforts occurring at Iron Mountain Mine and significantly lowered cadmium, copper, and zinc concentrations in the Sacramento River. The Discharger's previous site-specific metal translators for this reach of river have been updated and the following site-specific translators have been used in the Order to reflect current conditions:

	<u>Chronic</u>	<u>Acute</u>
Copper	0.771	0.811
Zinc	0.705	0.766

3. Determining the Need for WQBELs

- a. CWA section 301 (b)(1) requires NPDES permits to include effluent limitations that achieve technology-based standards and any more stringent limitations necessary to meet water quality standards. Water quality standards include Regional Water Board Basin Plan beneficial uses and narrative and numeric water quality objectives, State Water Board-adopted standards, and federal standards, including the CTR and NTR. The Basin Plan includes numeric site-specific water quality objectives and narrative objectives for toxicity, chemical constituents, and tastes and odors. The narrative toxicity objective states: "*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.*" (Basin Plan at III-8.00.) With regards to the narrative chemical constituents objective, the Basin Plan states that waters shall not contain chemical constituents in concentrations that adversely affect beneficial uses. At minimum, "*...water designated for use as domestic or municipal supply (MUN) shall not contain concentrations of chemical constituents in excess of the maximum contaminant levels (MCLs)*" in Title 22 of CCR. The narrative tastes and odors objective states: "*Water shall not contain taste- or odor-producing substances in concentrations that impart undesirable tastes or odors to domestic or municipal water supplies or to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.*"
- b. Federal regulations require effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause, or contribute to an in-stream excursion above a narrative or numerical water quality standard. Based on information submitted as part of the application, in studies, and as directed by monitoring and reporting programs, the Regional Water Board finds that the discharge has a reasonable potential to cause or contribute to an in-stream excursion above a water quality standard for copper, zinc, cyanide, chlorodibromomethane, dichlorobromomethane, alpha-BHC, beta-BHC, and gamma-BHC. Water quality-based effluent limitations (WQBELs) for these constituents are included in this Order. A summary of the reasonable potential analysis (RPA) is provided in Table F-6 and applicable priority pollutant water quality criteria and objectives are included in Table F-7. A detailed discussion of the RPA for each constituent is provided below.
- c. The Regional Water Board conducted the RPA in accordance with Section 1.3 of the SIP. Although the SIP applies directly to the control of CTR priority pollutants, the State Water Board has held that the Regional Water Board may use the SIP as guidance for water quality-based toxics control.¹ The SIP states in the introduction "*The goal of this Policy is to establish a standardized approach for permitting discharges of toxic pollutants to non-ocean surface waters in a*

¹ See, Order WQO 2001-16 (Napa) and Order WQO 2004-0013 (Yuba City)

manner that promotes statewide consistency." Therefore, in this Order the RPA procedures from the SIP were used to evaluate reasonable potential for both CTR and non-CTR constituents.

- d. WQBELs were calculated in accordance with section 1.4 of the SIP, as described in Attachment F, Section IV.C.4.

Table F-6. Summary of Reasonable Potential Analysis

Parameter	Units	No. Effluent Samples	MEC	No. Receiving Water Samples	<u>BC</u>	Most Stringent Applicable Criterion <u>C</u>	Criterion	Basis for Reasonable Potential Determination
Copper	ug/l	9	15.3	28	4.01 ^a	5.71	Chronic aquatic life	MEC>C
Zinc	ug/l	8	66.3	28	7.5 ^a	22.61	Acute aquatic life	MEC>C
Cyanide	ug/l	6	16	2	<0.003	5.2	Chronic aquatic life	MEC>C
Chlorodibromomethane	ug/l	5	0.92	2	<0.15	0.410	Human Health	MEC>C
Dichlorobromomethane	ug/l	5	15	2	<0.17	0.560	Human Health	MEC>C
alpha-BHC	ug/l	5	0.064	3	<0.0016	0.0039	Human Health	MEC>C
beta-BHC	ug/l	5	0.077	3	<0.0018	0.005	Basin Plan Objective	MEC>C
gamma-BHC	ug/l	5	0.029	3	<0.0014	0.019	Human Health	MEC>C

MEC = maximum effluent concentration (data set from January 2003 to December 2006).

BC = maximum background concentration (receiving water data set from January 2003 to March 2007 except as noted in footnote a).

^a Data set from June 2004 through December 2006.

Table F-7. Summary of Applicable Priority Pollutant Criterion/Objectives

		CTR Water Quality Criteria			Basin Plan		Most Stringent Applicable Criterion (C)		
		Freshwater		Human Health for consumption of:					
Parameter	Units	CMC (acute)	CCC (chronic)	Water & Organisms (W&O)	Organisms Only	Max (acute)	Max (chronic)	Value	Criterion
Copper ¹	ug/l	7.64	5.71	1300	--	7.52	--	5.71	CTR CCC
Zinc ¹	ug/l	75.72	83.69	--	--	22.61	--	22.61	BP Max-Acute
Cyanide	ug/l	22	5.2	700	220,000	10	10	5.2	CTR CCC
Chlorodibromomethane	ug/l	--	--	0.410	34	--	--	0.410	CTR HH- (W&O)
Dichlorobromomethane	ug/l	--	--	0.560	46	--	--	0.560	CTR HH- (W&O)
alpha-BHC	ug/l	--	--	0.0039	0.013	ND (ML= 0.01)	--	0.0039	CTR HH- (W&O)
beta-BHC	ug/l	--	--	0.014	0.046	ND (ML= 0.005)	--	0.005	BP Objective
gamma-BHC	ug/l	0.95	--	0.019	0.063	ND (ML= 0.02)	--	0.019	CTR HH- (W&O)

¹ Based on receiving water hardness of 44 mg/L, pH value of 7.19, and site-specific translators (Data set from June 2004 through November 2006).

CTR = California Toxic Rule

CMC = Criterion Maximum Concentration (acute)

CCC = Criterion Continuous Concentration (chronic)

ML= Minimum quantifiable level required by Appendix 4 of the SIP

- e. **Ammonia.** Untreated domestic wastewater contains ammonia. Nitrification is a biological process that converts ammonia to nitrite and nitrite to nitrate. Denitrification is a process that converts nitrate to nitrite or nitric oxide and then to nitrous oxide or nitrogen gas, which is then released to the atmosphere. The Discharger does currently use nitrification to remove ammonia from the waste stream. Inadequate or incomplete nitrification may result in the discharge of ammonia to the receiving stream. Ammonia is known to cause toxicity to aquatic organisms in surface waters. Discharges of ammonia would violate the Basin Plan narrative toxicity objective. Applying 40 CFR section 122.44(d)(1)(vi)(B), it is appropriate to use USEPA's Ambient National Water Quality Criteria for the Protection of Freshwater Aquatic Life for ammonia, which was developed to be protective of aquatic organisms.

USEPA's *Ambient Water Quality Criteria for the Protection of Freshwater Aquatic Life*, for total ammonia, recommends acute (1-hour average; criteria maximum concentration) standards based on pH and chronic (30-day average, criteria continuous concentration) standards based on pH and temperature. It also recommends a maximum four-day average concentration of 2.5 times the criteria continuous concentration. USEPA found that as pH increased, both the acute and chronic toxicity of ammonia increased. Salmonids were more sensitive to acute toxicity effects than other species. However, while the acute toxicity of ammonia was not influenced by temperature, it was found that invertebrates and young fish experienced increasing chronic toxicity effects with increasing temperature. Because the Sacramento River has a beneficial use of cold freshwater habitat and the presence of salmonids and early fish life stages in the Sacramento River is well-documented, the recommended criteria for waters where salmonids and early life stages are present were used. USEPA's recommended criteria are show below:

$$CCC_{30\text{-day}} = \left(\frac{0.0577}{1+10^{7.688-pH}} + \frac{2.487}{1+10^{pH-7.688}} \right) \times MIN(2.85, 1.45 \cdot 10^{0.028(25-T)}), \text{ and}$$
$$CMC = \left(\frac{0.275}{1+10^{7.204-pH}} + \frac{39.0}{1+10^{pH-7.204}} \right),$$

where T is in degrees Celsius

The maximum permitted effluent pH is 9.0. The maximum historical effluent pH is 8.2. The Basin Plan objective for pH in the receiving stream is the range of 6.5 to 8.5. The maximum observed 30-day average effluent temperature was 82.4°F (28°C), for the period of January 2004 through December 2006 and occurred on the 30-day period ending in July 2004. The maximum observed 30-day background receiving water temperature for the period of January 2004 through December 2006 (33 samples) was 55.4°F (13.0°C), for the 30-day period ending 30 September 2004. Using a pH value of 9.0 and the worst-case temperature value of 55.4°F (13.0°C) on a 30-day basis, the resulting effluent limitations are 0.486 mg/L (as N) for the average monthly effluent limitation and 0.885 mg/L (as

N) for the average one-hour effluent limitation. The maximum observed daily pH value for effluent during the period of January 2004 through December 2006 occurred on 25 March 2004 and was reported as 8.2. Using the observed maximum pH value of 8.2 and the worst-case temperature value of 55.4°F (13.0°C) on a 30-day basis, the resulting effluent limitations are 1.79 mg/L (as N) for the average monthly effluent limitation and 3.83 mg/L (as N) for the average one-hour effluent limitation.

The maximum effluent concentration for ammonia was 0.354 mg/L, based on 32 samples collected between January 2004 and December 2006. There are no background receiving water ammonia sample results. The maximum observed ammonia effluent concentration does not exceed the chronic or acute criteria for ammonia utilizing both the worst-case effluent pH limit of 9.0 and the observed maximum pH of 8.2. Based on historical ammonia effluent data, the treatment process adequately nitrifies the waste stream. There is no reasonable potential for ammonia, therefore effluent limits for ammonia are not included in this Order. This Order requires effluent monitoring and receiving water monitoring for ammonia.

- f. **Chlorine Residual.** The Discharger uses chlorine for disinfection, which is extremely toxic to aquatic organisms. The Discharger uses a sulfur dioxide process to dechlorinate the effluent prior to discharge to the Sacramento River. Due to the existing chlorine use and the potential for chlorine to be discharged, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan's narrative toxicity objective.

The USEPA Technical Support Document for Water Quality-Based Toxics Control [EPA/505/2-90-001] contains statistical methods for converting chronic (four-day) and acute (one-hour) aquatic life criteria to average monthly and maximum daily effluent limitations based on the variability of the existing data and the expected frequency of monitoring. However, because chlorine is an acutely toxic constituent that can and will be monitored continuously, an average one-hour limitation is considered more appropriate than an average daily limitation. Average one-hour and four-day limitations for chlorine, based on these criteria, are included in this Order. The Discharger can immediately comply with these new effluent limitations for chlorine residual.

The Facility discharges through a diffuser to Sacramento River. The chlorine residual limitations required in this Order are protective of aquatic organisms in the undiluted discharge. If compliance is maintained, the Regional Water Board does not anticipate residual chlorine impacts to benthic organisms.

- g. **Copper.** The CTR includes hardness-dependent criteria for the protection of freshwater aquatic life for copper. The criteria for copper are presented in dissolved concentrations. USEPA recommends conversion factors to translate dissolved concentrations to total concentrations. The USEPA default conversion factors for copper in freshwater are 0.96 for both the acute and the chronic criteria. Using the worst-case measured hardness from the effluent and

receiving water (44 mg/L as CaCO₃) and the USEPA recommended dissolved-to-total translator, the applicable chronic criterion (maximum four-day average concentration) is 4.6 ug/L and the applicable acute criterion (maximum one-hour average concentration) is 6.5 ug/L, as total recoverable. Applying the site-specific translator for copper of 0.771 for the chronic criteria and 0.811 for the acute criteria, the applicable chronic criterion (maximum four-day average concentration) is 5.71 ug/L and the applicable acute criterion (maximum one-hour average concentration) is 7.64 ug/L, as total recoverable.

The Basin Plan includes hardness-dependent criteria for the protection of freshwater aquatic life for copper. Using the worst-case measured hardness from the effluent and receiving water (44 mg/L as CaCO₃) and the USEPA recommended dissolved-to-total translator, the applicable Basin Plan instantaneous maximum criterion is 6.35 ug/L, as total recoverable. Applying the site-specific translator for copper of 0.811 for the acute criteria, the applicable acute criterion (maximum one-hour average concentration) is 7.52 ug/L, as total recoverable.

The MEC for total copper was 15.3 ug/L, based on 9 samples collected between 18 July 2001 and 13 October 2005, while the maximum observed upstream receiving water total copper concentration was 4.01 ug/L, based on 28 samples collected between 17 June 2004 and 1 November 2006. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criteria for copper. The ambient monitoring demonstrates the receiving water has assimilative capacity for copper. A dilution credit for copper of up to 39:1 can be granted, based on the available freshwater chronic life criteria (see Attachment F, Section IV.4). An AMEL and MDEL for total copper of 13.7 ug/L and 27.4 ug/L, respectively, are included in this Order based on CTR criteria for the protection of freshwater aquatic life (See Attachment F, Table F-10 for WQBEL calculations). Based on the sample results in the effluent, it appears the Discharger can meet the MDEL but cannot meet the AMEL for copper.

Section 2.1 of the SIP allows for compliance schedules within the permit for existing discharges where it is demonstrated that it is infeasible for a Discharger to achieve immediate compliance with a CTR criterion. Using the statistical methods for calculating interim effluent limitations described in Attachment F, Section IV.D.1., an interim performance-based AMEL of 29.1 ug/L was calculated.

This Order requires the Discharger to submit a corrective action plan and implementation schedule to assure compliance with the final average monthly copper effluent limitation. The interim effluent limitation is in effect through **17 May 2010**. As part of the compliance schedule for copper, the Discharger shall develop a pollution prevention program in compliance with CWC section 13263.3(d)(3) and submit an engineering treatment feasibility study.

h. **Cyanide.** The CTR includes maximum 1-hour average and 4-day average cyanide criteria concentrations of 22 ug/L and 5.2 ug/L, respectively, for the protection of freshwater aquatic life. The Basin Plan also includes criteria for the protection of freshwater aquatic life for cyanide. The Basin Plan instantaneous maximum criterion is 10 ug/L. The MEC for cyanide was 16 ug/L, based on 6 samples collected between 16 September 2003 and 1 November 2006, while the maximum observed upstream receiving water cyanide concentration was <0.003 ug/L, based on 2 samples collected between 12 September 2006 and 1 November 2006. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR and Basin Plan criteria for cyanide. The ambient monitoring demonstrates the receiving water has assimilative capacity for cyanide. A dilution credit for cyanide of up to 39:1 can be granted, based on the available freshwater chronic life criteria (see Attachment F, Section IV.4). An AMEL and MDEL for cyanide of 31.8 ug/L and 63.7 ug/L, respectively, are included in this Order based on CTR and Basin Plan criteria for the protection of freshwater aquatic life (See Attachment F, Table F-12 for WQBEL calculations). Based on the sample results in the effluent, it appears the Discharger can meet these new limitations.

i. **Chlorodibromomethane.** The CTR includes a chlorodibromomethane criterion of 0.41 ug/L for the protection of human health and is based on a one-in-a-million cancer risk for waters from which both water and organisms are consumed. The MEC for chlorodibromomethane was 0.92 ug/L, based on 5 samples collected between 5 November 2003 and 1 November 2006, while the maximum observed upstream receiving water chlorodibromomethane concentration was <0.15 ug/L, based on 2 samples collected between 12 September 2006 and 1 November 2006. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for chlorodibromomethane.

The ambient monitoring demonstrates the receiving water has assimilative capacity for chlorodibromomethane. A dilution credit for chlorodibromomethane of up to 269:1 can be granted, based on the available human health dilution (see Attachment F, Section IV.4). An AMEL and MDEL for chlorodibromomethane of 12.1 ug/L and 24.2 ug/L, respectively, are included in this Order based on based on the CTR criterion for the protection of human health (See Attachment F, Table F-13 for WQBEL calculations). Based on the sample results in the effluent, it appears the Discharger can meet these new limitations.

j. **Dichlorobromomethane.** The CTR includes a dichlorobromomethane criterion of 0.56 ug/L for the protection of human health and is based on a one-in-a-million cancer risk for waters from which both water and organisms are consumed. The MEC for dichlorobromomethane was 15 ug/L, based on 5 samples collected between 5 November 2003 and 1 November 2006, while the maximum observed upstream receiving water dichlorobromomethane concentration was <0.17 ug/L, based on 2 samples collected between 12 September 2006 and 1 November 2006. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for

dichlorobromomethane.

The ambient monitoring demonstrates the receiving water has assimilative capacity for dichlorobromomethane. A dilution credit for dichlorobromomethane of up to 269:1 can be granted, based on the available human health dilution (see Attachment F, Section IV.4). An AMEL and MDEL for dichlorobromomethane of 18.1 ug/L and 36.2 ug/L, respectively, are included in this Order based on based on the CTR criterion for the protection of human health (See Attachment F, Table F-14 for WQBEL calculations). Based on the sample results in the effluent, it appears the Discharger can meet these new limitations.

k. Electrical Conductivity. (see Subsection o. Salinity)

- i. Persistent Chlorinated Hydrocarbon Pesticides.** alpha-BHC (alpha-hexachlorocyclohexane), beta-BHC, and lindane (gamma-BHC) were detected in the effluent in concentrations as high as 0.064 ug/L, 0.077 ug/L, 0.029 ug/L, respectively. Each of these constituents is a chlorinated hydrocarbon pesticide. The Basin Plan requires that no individual pesticides shall be present in concentrations that adversely affect beneficial uses; discharges shall not result in pesticide concentrations in bottom sediments or aquatic life that adversely affect beneficial uses; total chlorinated hydrocarbon pesticides shall not be present in the water column at detectable concentrations; and pesticide concentrations shall not exceed those allowable by applicable antidegradation policies. The CTR contains numeric criteria for alpha-BHC, beta-BHC, and gamma-BHC of 0.0039 ug/L, 0.014 ug/L, and 0.019 ug/L, respectively, for freshwaters from which both water and organisms are consumed. The CTR also contains an acute criterion for protection of aquatic life for gamma-BHC of 0.95 ug/L. The detection of alpha-BHC at 0.064 ug/L, beta-BHC at 0.077 ug/L, and gamma-BHC at 0.029 ug/L in the effluent presents a reasonable potential to exceed the Basin Plan limitations for chlorinated hydrocarbon pesticides and the CTR criteria for alpha-BHC, beta-BHC, and gamma-BHC. Receiving water limitations for persistent chlorinated hydrocarbon pesticides are included in this Order and are based on the Basin Plan objective of no detectable concentrations of chlorinated hydrocarbon pesticides. Final effluent limits for alpha-BHC, beta-BHC, and gamma-BHC were determined as follows:

alpha-BHC

The ambient monitoring demonstrates the receiving water has assimilative capacity for alpha-BHC. A dilution credit for alpha-BHC of up to 269:1 can be granted, based on the available human health dilution (see Attachment F, Section IV.4). An AMEL and MDEL for alpha-BHC of 0.11 ug/L and 0.21 ug/L, respectively, are included in this Order based on the CTR criterion for the protection of human health (See Attachment F, Table F-14 for WQBEL calculations). Based on the sample results in the effluent, it appears the Discharger can meet these new limitations.

beta-BHC

The ambient monitoring demonstrates the receiving water has assimilative

capacity for beta-BHC. A dilution credit for beta-BHC of up to 269:1 can be granted, based on the available human health dilution (see Attachment F, Section IV.4). An AMEL and MDEL for beta-BHC of 0.15 ug/L and 0.30 ug/L, respectively, are included in this Order based on the Basin Plan objective of "non-detect" and the minimum quantifiable level (ML) required by Appendix 4 of the SIP (See Attachment F, Table F-14 for WQBEL calculations). Based on the sample results in the effluent, it appears the Discharger can meet these new limitations.

gamma-BHC

The ambient monitoring demonstrates the receiving water has assimilative capacity for gamma-BHC. A dilution credit for gamma-BHC of up to 269:1 can be granted, based on the available human health dilution (see Attachment F, Section IV.4). An AMEL and MDEL for gamma-BHC of 0.81 ug/L and 1.62 ug/L, respectively, are included in this Order based on based on the CTR criterion for the protection of human health (See Attachment F, Table F-14 for WQBEL calculations). Based on the sample results in the effluent, it appears the Discharger can meet these new limitations.

The final gamma-BHC AMEL of 0.81 ug/L is significantly greater than the MEC of 0.029 ug/L. Performance triggers of 1.55 times the MEC have been established for parameters where the percent increase of the final AMEL compared to the performance trigger is greater than 50 percent. The final AMEL of 0.81 ug/L is 1697 percent greater than the trigger value of 0.04 ug/L ($1.55 * 0.029$). Therefore a performance evaluation report (Section VI.C.3.d) is required when gamma-BHC effluent concentrations exceed an AMEL of 0.04 ug/L.

- m. **Pathogens.** Municipal and domestic supply, agricultural irrigation, and body contact water recreation are beneficial uses of the receiving stream. Coliform limits are imposed to protect the beneficial uses of the receiving water, including public health through contact recreation and drinking water pathways. In a letter to the Regional Water Board dated 8 April 1999, the California Department of Health Services indicated that DHS would consider wastewater discharged to water bodies with identified beneficial uses of irrigation or contact recreation and where the wastewater receives dilution of more than 20:1 to be adequately disinfected if the effluent coliform concentration does not exceed 23 MPN/100 mL as a 7-day median and if the effluent coliform concentration does not exceed 240 MPN/100 mL more than once in any 30 day period. This Order contains a 500 MPN/100mL daily maximum effluent coliform limit and a 23 MPN/100mL as a 30-day median.
- n. **pH.** The Basin Plan includes a water quality objective for surface waters (except for Goose Lake) that the "...*pH shall not be depressed below 6.5 nor raised above 8.5. Changes in normal ambient pH levels shall not exceed 0.5 in fresh waters with designated COLD or WARM beneficial uses.*" Effluent Limitations for pH are included in this Order based on the Basin Plan objectives for pH.

- o. **Salinity.** The discharge contains total dissolved solids (TDS) and electrical conductivity (EC). These are water quality parameters that are indicative of the salinity of the water. Their presence in water can be growth limiting to certain agricultural crops and can affect the taste of water for human consumption. There are no USEPA water quality criteria for the protection of aquatic organisms for these constituents. The Basin Plan contains a chemical constituent objective that incorporates State MCLs, contains a narrative objective, and contains numeric water quality objectives for EC and TDS.

Table F-8. Salinity Water Quality Criteria/Objectives

Parameter	Agricultural WQ Goal ¹	Secondary MCL ³	Effluent	
			Avg	Max
EC ($\mu\text{mhos}/\text{cm}$)	700 ²	900, 1600, 2200	423	568
TDS (mg/L)	450 ²	500, 1000, 1500	266	356

- 1 Agricultural water quality goals based on *Water Quality for Agriculture*, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985).
- 2 Agricultural water quality goals listed provide no restrictions on crop type or irrigation methods for maximum crop yield. Higher concentrations may require special irrigation methods to maintain crop yields or may restrict types of crops grown.
- 3 The secondary MCLs are stated as a recommended level, upper level, and a short-term maximum level.

- i. **Electrical Conductivity (EC).** The secondary MCL for EC is 900 $\mu\text{mhos}/\text{cm}$ as a recommended level, 1600 $\mu\text{mhos}/\text{cm}$ as an upper level, and 2200 $\mu\text{mhos}/\text{cm}$ as a short-term maximum. The agricultural water quality goal, that would apply the narrative chemical constituents objective, is 700 $\mu\text{mhos}/\text{cm}$ as a long-term average based on *Water Quality for Agriculture, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1* (R.S. Ayers and D.W. Westcot, Rome, 1985). The 700 $\mu\text{mhos}/\text{cm}$ agricultural water quality goal is intended to prevent reduction in crop yield, i.e. a restriction on use of water, for salt-sensitive crops, such as beans, carrots, turnips, and strawberries. Most other crops can tolerate higher EC concentrations without harm, however, as the salinity of the irrigation water increases, more crops are potentially harmed by the EC, or extra measures must be taken by the farmer to minimize or eliminate any harmful impacts.

A review of the Discharger's monitoring reports from January 2004 through December 2006 shows an average monthly effluent EC of 423 umhos/cm, a one-day maximum observed EC of 568 umhos/cm , and an average monthly range from 304 umhos/cm to 524 umhos/cm for 36 samples. These levels do not exceed the applicable water quality objectives. There is no background receiving water EC sample results. This Order requires effluent and receiving water monitoring for EC.

- ii. **Total Dissolved Solids (TDS).** The secondary MCL for TDS is 500 mg/L as a recommended level, 1000 mg/L as an upper level, and 1500 mg/L as a

short-term maximum. The recommended agricultural water quality goal for TDS, that would apply the narrative chemical constituent objective, is 450 mg/L as a long-term average based on Water Quality for Agriculture, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985). Water Quality for Agriculture evaluates the impacts of salinity levels on crop tolerance and yield reduction, and establishes water quality goals that are protective of the agricultural uses. The 450 mg/L water quality goal is intended to prevent reduction in crop yield, i.e. a restriction on use of water, for salt-sensitive crops. Only the most salt sensitive crops require irrigation water of 450 mg/L or less to prevent loss of yield. Most other crops can tolerate higher TDS concentrations without harm, however, as the salinity of the irrigation water increases, more crops are potentially harmed by the TDS, or extra measures must be taken by the farmer to minimize or eliminate any harmful impacts.

The average TDS effluent concentration was 266 mg/L and ranged from 201 mg/L to 356 mg/L for 12 samples collected by the Discharger from January 2004 through December 2006. These concentrations do not exceed the applicable water quality objectives. There are no background receiving water TDS sample results.

- iii. **Salinity Effluent Limitations and Evaluation and Minimization Plan.** The average electrical conductivity in the discharge is 423 umhos/cm, which is less than the lowest applicable criteria of 700 umhos/cm (agricultural water quality goal). No reasonable potential exists, therefore no effluent limitation is necessary. Nonetheless, in an effort to minimize salt loading to the Sacramento River, this Order requires the Discharger to submit a salinity evaluation and minimization plan to address sources of salinity from the Facility.
- p. **Settleable Solids.** For inland surface waters, the Basin Plan states that “[w]ater shall not contain substances in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.” This Order does not contain average monthly and average daily effluent limitations for settleable solids. With total suspended solids limits in place, the settleable solids limits can be eliminated and still protect water quality objectives in the receiving water.
- q. **Toxicity.** See Section IV.C.5. of the Fact Sheet regarding whole effluent toxicity.
- r. **Zinc.** The CTR includes hardness-dependent criteria for the protection of freshwater aquatic life for zinc. The criteria for zinc are presented in dissolved concentrations. USEPA recommends conversion factors to translate dissolved concentrations to total concentrations. The conversion factors for zinc in freshwater are 0.978 for the acute criteria and 0.986 for the chronic criteria. Using the worst-case ambient (lowest upstream receiving water) measured hardness from the effluent and receiving water, (44 mg/L), the applicable chronic

criterion (maximum four-day average concentration) and the applicable acute criterion (maximum one-hour average concentration) are both 60 ug/L, as total recoverable. Applying the site-specific translator for zinc of 0.705 for the chronic criteria and 0.766 for the acute criteria, the applicable chronic criterion (maximum four-day average concentration) is 83.69 ug/L and the applicable acute criterion (maximum one-hour average concentration) is 75.72 ug/L, as total recoverable.

The Basin Plan includes hardness-dependent criteria for the protection of freshwater aquatic life for zinc. Using the worst-case measured hardness from the effluent and receiving water (44 mg/L as CaCO₃) and the USEPA recommended dissolved-to-total translator, the applicable Basin Plan instantaneous maximum criterion is 17.71 ug/L, as total recoverable. Applying the site-specific translator for zinc of 0.766 for the acute criteria, the applicable acute criterion (maximum one-hour average concentration) is 22.61 ug/L, as total recoverable.

The MEC for total zinc was 66.3 ug/L, based on 8 samples collected between 5 November 2003 and 1 November 2006, while the maximum observed upstream receiving water total zinc concentration was 7.5 ug/L, based on 28 samples collected between 17 June 2004 and 1 November 2006. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan criteria for zinc. A dilution credit for zinc of up to 37:1 can be granted, based on the available freshwater acute life criteria (see Attachment F, Section IV.4). An AMEL and MDEL for total zinc of 57.8 ug/L and 115.9 ug/L, respectively, are included in this Order based on Basin Plan criteria for the protection of freshwater aquatic life (See Attachment F, Table F-11 for WQBEL calculations). Based on the sample results in the effluent, it appears the Discharger can meet the MDEL for zinc but cannot meet the AMEL for zinc.

In accordance with the Regional Board's Policy for *Application of Water Quality Objectives*, presented in Chapter IV of the Basin Plan, schedules for compliance with final effluent limitations, which are based on water quality criteria adopted before 25 September 1995, cannot be authorized. Here, as the final AMEL for zinc is based on water quality criteria of the Basin Plan adopted before 25 September 1995, an interim limit cannot be considered and the final AMEL for zinc will become immediately effective upon adoption of the Order. However, the Regional Board may adopt other Orders, such as a Cease and Desist Order, allowing a period of time to fully comply with the AMEL for zinc.

Furthermore, this Order does require the Discharger to develop a pollution prevention program for zinc in compliance with CWC section 13263.3(d)(3).

4. WQBEL Calculations

- a. Effluent limitations for copper, zinc, cyanide, chlorodibromomethane, dichlorobromomethane, alpha-BHC, beta-BHC, and gamma-BHC were

calculated in accordance with section 1.4 of the SIP. The following paragraphs describe the methodology used for calculating effluent limitations.

- b. **Effluent Limitation Calculations.** For each water quality criterion/objective, the effluent concentration allowance was calculated using the following steady-state mass balance equation:

$$\begin{aligned} ECA &= C + D[X(C - B)] && \text{when } C > B, \text{ and} \\ ECA &= C && \text{when } C \leq B \end{aligned}$$

where:

ECA_{acute} = effluent concentration allowance for acute (one-hour average) toxicity criterion, adjusted, if necessary, for hardness, pH, and translators.

$ECA_{chronic}$ = effluent concentration allowance for chronic (four-day average) toxicity criterion adjusted, if necessary, for hardness, pH, and translators.

ECA_{HH} = effluent concentration allowance for human health, or other long-term criterion/objective

X= receiving water allocation factor

C = human health, aquatic life, or other long-term criterion/objective

D = dilution credit (dilution ratio * estimated mixing)

B = maximum receiving water concentration

Acute and chronic toxicity ECAs were then converted to equivalent long-term averages (LTA) using statistical multipliers and the lowest is used. Additional statistical multipliers were then used to calculate the maximum daily effluent limitation (MDEL) and the average monthly effluent limitation (AMEL).

Human health ECAs are set equal to the AMEL and a statistical multiplier is used to calculate the MDEL.

$$\overbrace{AMEL = mult_{AMEL} [\min(M_A ECA_{acute}, M_C ECA_{chronic})]}^{\text{LTA}_{acute}}$$
$$MDEL = mult_{MDEL} [\min(M_A ECA_{acute}, M_C ECA_{chronic})] \overbrace{\quad\quad\quad}^{\text{LTA}_{chronic}}$$
$$MDEL_{HH} = \left(\frac{mult_{MDEL}}{mult_{AMEL}} \right) AMEL_{HH}$$

where: $mult_{AMEL}$ = statistical multiplier converting minimum LTA to AMEL
 $mult_{MDEL}$ = statistical multiplier converting minimum LTA to MDEL
 M_A = statistical multiplier converting ECA_{acute} to LTA
 M_C = statistical multiplier converting $ECA_{chronic}$ to LTA

The preliminary estimated mixing of the effluent in the Sacramento River is 25 percent. The percent mixing is partially based on the length of the diffuser (80 feet) relative to the width of the river (450 feet) at low flows (2400 cfs). At approximately 2400 cfs, the outfall line (including the diffuser) extends 260 feet from the left bank of the river, thus placing the diffuser in relatively the center of the river where rapid mixing is expected to occur. The discharger plans to perform a mixing zone study to determine the actual dilution credit provided by the discharge diffuser. Table F-9 shows the calculated dilution credit (D) for each water quality criterion and/or objective.

Table F-9. Dilution Credits for Water Quality Criteria

Criterion/Objective	Dilution Ratio	Estimated Mixing	Dilution Credit
Acute	148:1	25%	37:1
Chronic	155:1	25%	39:1
Human Health	1077:1	25%	269:1

An allocation factor (X) of 1/6 has been applied to the "C-B" in the effluent concentration allowance (ECA) calculation. The "C-B" value represents the critical condition assimilative capacity in the receiving water. The allocation factor of 1/6 has been applied to the "C-B" value such that 16.6 percent of the assimilative capacity of the receiving water is used to calculate an effluent limit. This allows for four dischargers in this reach of the river to share the assimilative capacity (16.6 percent each) and gives 16.6 percent allowance for non-point sources discharges and 16.6 percent allowance for future allocation and/or use.

Water quality-based effluent limitations were calculated for copper, zinc, cyanide, dichlorobromomethane, chlorodibromomethane, alpha-BHC, beta-BHC, and gamma-BHC as follows in Tables F-10 through F-17, below. A summary table for the calculation of the effluent concentration allowance and the final effluent limitations are provided in Table F-18 and F-19, respectively.

Table F-10. WQBEL Calculations for Copper

	Acute	Chronic	Human Health
Criteria, dissolved (ug/L)	7.52 ⁽¹⁾	5.71 ⁽²⁾	1300
Dilution Credit ⁽³⁾	37:1	39:1	269:1
Translator ⁽⁴⁾	0.811	0.771	
ECA, total recoverable ⁽⁵⁾	29.18	16.70	59468.06
ECA Multiplier ⁽⁶⁾	0.321	0.527	--
LTA	9.37	8.81	--
AMEL Multiplier (95 th %) ⁽⁷⁾⁽⁸⁾	(10)	1.55	--
AMEL (ug/L)	(10)	13.67	59468.06
MDEL Multiplier (99 th %) ⁽⁹⁾	(10)	3.11	2.01
MDEL (ug/L)	(10)	27.43	119304.17

⁽¹⁾ Basin Plan aquatic life criteria, based on a hardness of 44 mg/L as CaCO₃ and site- specific translator for acute conditions of 0.811.

⁽²⁾ CTR aquatic life criteria, based on a hardness of 44 mg/L as CaCO₃ and site- specific translator for chronic conditions of 0.771.

⁽³⁾ Estimated Mixing of 25%.

⁽⁴⁾ Site-Specific Translator.

⁽⁵⁾ ECA calculated per section 1.4.B, Step 2 of SIP. This allows for the consideration of dilution.

⁽⁶⁾ Acute and Chronic ECA Multiplier calculated at 99th percentile per section 1.4.B, Step 3 of SIP or per sections 5.4.1 and 5.5.4 of the TSD.

⁽⁷⁾ Assumes sampling frequency n=>4.

⁽⁸⁾ The probability basis for AMEL is 95th percentile per section 1.4.B, Step 5 of SIP or section 5.5.4 of the TSD.

⁽⁹⁾ The probability basis for MDEL is 99th percentile per section 1.4.B, Step 5 of SIP or section 5.5.4 of the TSD.

⁽¹⁰⁾ Limitations based on chronic LTA (Chronic LTA < Acute LTA).

Table F-11. WQBEL Calculations for Zinc

	Acute	Chronic
Criteria, dissolved (ug/L)	22.61 ⁽¹⁾	83.69 ⁽²⁾
Dilution Credit ⁽³⁾	37:1	39:1
Translator ⁽⁴⁾	0.766	0.705
ECA, total recoverable ⁽⁵⁾	115.86	576.12
ECA Multiplier ⁽⁶⁾	0.321	0.527
LTA	37.20	303.86
AMEL Multiplier (95 th %) ⁽⁷⁾⁽⁸⁾	1.55	(10)
AMEL (ug/L)	57.75	(10)
MDEL Multiplier (99 th %) ⁽⁹⁾	3.11	(10)
MDEL (ug/L)	115.86	(10)

⁽¹⁾ Basin Plan aquatic life criteria, based on a hardness of 44 mg/L as CaCO₃ and site- specific translator for acute conditions of 0.766.

⁽²⁾ CTR aquatic life criteria, based on a hardness of 44 mg/L as CaCO₃ and site- specific translator for chronic conditions of 0.705.

⁽³⁾ Estimated Mixing of 25%.

⁽⁴⁾ Site-Specific Translator.

⁽⁵⁾ ECA calculated per section 1.4.B, Step 2 of SIP. This allows for the consideration of dilution.

⁽⁶⁾ Acute and Chronic ECA Multiplier calculated at 99th percentile per section 1.4.B, Step 3 of SIP or per sections 5.4.1 and 5.5.4 of the TSD.

⁽⁷⁾ Assumes sampling frequency n=>4.

⁽⁸⁾ The probability basis for AMEL is 95th percentile per section 1.4.B, Step 5 of SIP or section 5.5.4 of the TSD.

⁽⁹⁾ The probability basis for MDEL is 99th percentile per section 1.4.B, Step 5 of SIP or section 5.5.4 of the TSD.

⁽¹⁰⁾ Limitations based on acute LTA (Acute LTA < Chronic LTA).

Table F-12. WQBEL Calculations for Cyanide

	Acute	Chronic	Human Health
Criteria (ug/L)	10 ⁽¹⁾	5.2 ⁽²⁾	700
Dilution Credit ⁽³⁾	37:1	39:1	269:1
ECA	71.70	38.79	32118.04
ECA Multiplier	0.321	0.527	--
LTA	23.02	20.46	--
AMEL Multiplier (95 th %)	(4)	1.55	--
AMEL (ug/L)	(4)	31.76	32118.04
MDEL Multiplier (99 th %)	(4)	3.11	2.01
MDEL (ug/L)	(4)	63.72	64434.86

(1) Basin Plan instantaneous maximum aquatic life criteria.

(2) CTR aquatic life criteria for chronic conditions.

(3) Estimated Mixing of 25%.

(4) Limitations based on chronic LTA (Chronic LTA < Acute LTA).

Table F-13. WQBEL Calculations for Chlorodibromomethane

	Human Health
Criteria (ug/L)	0.41
Dilution Credit ⁽¹⁾	269:1
ECA	12.08
AMEL (ug/L) ⁽²⁾	12.08
MDEL/AMEL Multiplier ⁽³⁾	2.01
MDEL (ug/L)	24.23

(1) Estimated Mixing of 25%.

(2) AMEL = ECA per section 1.4.B, Step 6 of SIP

(3) Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

Table F-14. WQBEL Calculations for Dichlorobromomethane

	Human Health
Criteria (ug/L)	0.56
Dilution Credit ⁽¹⁾	269:1
ECA	18.06
AMEL (ug/L) ⁽²⁾	18.06
MDEL/AMEL Multiplier ⁽³⁾	2.01
MDEL (ug/L)	36.24

(1) Estimated Mixing of 25%.

(2) AMEL = ECA per section 1.4.B, Step 6 of SIP.

(3) Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

Table F-15. WQBEL Calculations for alpha-BHC

	Human Health
Criteria (ug/L)	0.0039
Dilution Credit ⁽¹⁾	269:1
ECA	0.11
AMEL (ug/L) ⁽²⁾	0.11
MDEL/AMEL Multiplier ⁽³⁾	2.01
MDEL (ug/L)	0.21

⁽¹⁾ Estimated Mixing of 25%.

⁽²⁾ AMEL = ECA per section 1.4.B, Step 6 of SIP.

⁽³⁾ Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

Table F-16. WQBEL Calculations for beta-BHC

	Human Health
Criteria (ug/L)	0.005
Dilution Credit ⁽¹⁾	269:1
ECA	0.15
AMEL (ug/L) ⁽²⁾	0.15
MDEL/AMEL Multiplier ⁽³⁾	2.01
MDEL (ug/L)	0.30

⁽¹⁾ Estimated Mixing of 25%.

⁽²⁾ AMEL = ECA per section 1.4.B, Step 6 of SIP.

⁽³⁾ Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

Table F-17. WQBEL Calculations for gamma-BHC

	Acute	Human Health
Criteria (ug/L)	0.95 ⁽¹⁾	0.019
Dilution Credit ⁽²⁾	37:1	269:1
ECA	6.80	0.81
ECA Multiplier	0.321	--
LTA	2.18	--
AMEL Multiplier (95 th %)	1.55	--
AMEL (ug/L)	3.39	0.81⁽³⁾
MDEL Multiplier (99 th %)	3.11	2.01 ⁽⁴⁾
MDEL (ug/L)	6.80	1.62

⁽¹⁾ CTR acute aquatic life criteria.

⁽²⁾ Estimated Mixing of 25%.

⁽³⁾ AMEL = ECA per section 1.4.B, Step 6 of SIP.

⁽⁴⁾ Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

Table F-18. Calculation of Effluent Concentration Allowance (ECA)

Parameter	Units	Criteria C	Criterion	Dilution Credit D	Allocation Factor X	Background (Sacramento River) B	ECA
Copper	ug/l	7.52 5.71 1300	Acute aquatic life Chronic aquatic life Human Health	37:1 39:1 269:1	1/6	4.01	29.18 16.70 59468.06
Zinc	ug/l	22.61 83.69	Acute aquatic life Chronic aquatic life	37:1 39:1	1/6	7.5	115.9 576.12
Cyanide	ug/l	10 5.2 700	Acute aquatic life Chronic aquatic life Human Health	37:1 39:1 269:1	1/6	0.003	71.70 38.8 32118.04
Chloro-dibromomethane	ug/l	0.410	Human Health	269:1	1/6	0.15	12.08
Dichloro-bromomethane	ug/l	0.560	Human Health	269:1	1/6	0.17	18.06
alpha-BHC	ug/l	0.0039	Human Health	269:1	1/6	0.0016	0.11
beta-BHC	ug/l	0.005	Basin Plan Objective	269:1	1/6	0.0018	0.15
gamma-BHC	ug/l	0.95 0.019	Acute aquatic life Human Health	37:1 269:1	1/6	0.0014	6.80 0.81

Table F-19. WQBEL Calculation Summary Table¹

Parameter	Units	Criterion	ECA	CV	ECA multiplier	LTA	Most limiting LTA	AMEL aq.	MDEL aq.	AMEL hh	MDEL hh
Copper	ug/l	Acute aquatic life	29.18		0.321	9.37	--				
		Chronic aquatic life	16.70	0.6	0.527	8.81	8.81	13.67	27.43		
		Human Health	59468.06		n/a	--	--			59468	119304
Zinc	ug/l	Acute aquatic life	115.9	0.6	0.321	37.20	37.20	57.75	115.86	n/a	n/a
		Chronic aquatic life	576.12		0.527	303.9	--				
Cyanide	ug/l	Acute aquatic life	71.70	0.6	0.321	23.02	--				
		Chronic aquatic life	38.8		0.527	20.46	20.46	31.76	63.72		
		Human Health	32118.04		n/a	--	--			32118	64435
Chloro-dibromomethane	ug/l	Human Health	12.08	0.6	n/a	--	--	n/a	n/a	12.08	24.23
Dichloro-bromomethane	ug/l	Human Health	18.06	0.6	n/a	--	--	n/a	n/a	18.06	36.24
alpha-BHC	ug/l	Human Health	0.11	0.6	n/a	--	--	n/a	n/a	0.11	0.21
beta-BHC	ug/l	Basin Plan Objective	0.15	0.6	n/a	--	--	n/a	n/a	0.15	0.30
gamma-BHC	ug/l	Acute aquatic life	6.80	0.6	0.321	2.18	2.18	3.39	2.18		
		Human Health	0.81		n/a	--	--			0.81	1.62

¹ Final AMEL and MDEL are shaded for each parameter.

n/a Not Applicable.

5. Summary of Water Quality-based Effluent Limitations – Discharge Point D-001

Table F-20. Summary of Water Quality-based Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Conventional Pollutants						
pH	standard units	--	--	--	6.0	9.0
Priority Pollutants						
Copper	ug/L	13.7	--	27.4	--	--
Zinc	ug/L	57.8	--	115.9		
Cyanide, Total (as CN)	ug/L	31.8	--	63.7	--	--
Chlorodibromomethane	ug/L	12.1	--	24.2		
Dichlorobromomethane	ug/L	18.1	--	36.2		
alpha-BHC	ug/L	0.11	--	0.21	--	
beta-BHC	ug/L	0.15	--	0.30		
gamma-BHC	ug/L	0.81	--	1.62		
Non-Conventional Pollutants						
Chlorine, Total Residual	mg/L	--	0.01 ⁽¹⁾	--	--	0.02 ⁽²⁾
Total Coliform	MPN/100 mL	23 ⁽³⁾		--	--	500

(1)-Applied as a 4-day average effluent limitation.

(2)-Applied as a 1-hour average effluent limitation.

(3)-Expressed as a 30-day median.

6. Whole Effluent Toxicity (WET)

For compliance with the Basin Plan's narrative toxicity objective, this Order requires the Discharger to conduct whole effluent toxicity testing for acute and chronic toxicity, as specified in the Monitoring and Reporting Program (Attachment E, Section V.). This Order also contains effluent limitations for acute toxicity and requires the Discharger to implement best management practices to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity.

- a. **Acute Aquatic Toxicity.** The Basin Plan contains a narrative toxicity objective that states, "*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.*" (Basin Plan at III-8.00) The Basin Plan also states that, "*...effluent limits based upon acute biotoxicity tests of effluents will be prescribed where appropriate...*". USEPA Region 9 provided guidance for the development of acute toxicity effluent limitations in the absence of numeric water quality objectives for toxicity in its document titled "Guidance for NPDES Permit Issuance", dated February 1994. In section B.2. "Toxicity Requirements" (pgs. 14-15) it states that, "*In the absence of specific numeric water quality objectives for acute and chronic toxicity, the narrative criterion 'no toxics in toxic amounts' applies. Achievement of the narrative criterion, as applied herein, means that ambient waters shall not demonstrate for acute toxicity: 1) less than 90% survival, 50% of the time, based on the monthly median, or 2) less than 70% survival, 10% of the time, based on any monthly median. For chronic toxicity, ambient waters shall not demonstrate a test result of greater than 1 TUc.*" Accordingly, effluent limitations for acute toxicity have been included in this Order as follows:

Acute Toxicity. Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:

Minimum for any one bioassays -----	70%
Median for any three or more consecutive bioassays -----	90%

- b. **Chronic Aquatic Toxicity.** Based on annual whole effluent chronic toxicity testing performed by the Discharger from 2002 through 2006, the discharge does not have reasonable potential to cause or contribute to an in-stream excursion above of the Basin Plan's narrative toxicity objective.

Numeric chronic WET effluent limitations have not been included in this order. The SIP contains implementation gaps regarding the appropriate form and implementation of chronic toxicity limits. This has resulted in the petitioning of a NPDES permit in the Los Angeles Region¹ that contained numeric chronic

¹ In the Matter of the Review of Own Motion of Waste Discharge Requirements Order Nos. R4-2002-0121 [NPDES No. CA0054011] and R4-2002-0123 [NPDES NO. CA0055119] and Time Schedule Order Nos. R4-

toxicity effluent limitations. To address the petition, the State Water Board adopted WQO 2003-012 directing its staff to revise the toxicity control provisions in the SIP. The State Water Board states the following in WQO 2003-012, "*In reviewing this petition and receiving comments from numerous interested persons on the propriety of including numeric effluent limitations for chronic toxicity in NPDES permits for publicly-owned treatment works that discharge to inland waters, we have determined that this issue should be considered in a regulatory setting, in order to allow for full public discussion and deliberation. We intend to modify the SIP to specifically address the issue. We anticipate that review will occur within the next year. We therefore decline to make a determination here regarding the propriety of the final numeric effluent limitations for chronic toxicity contained in these permits.*" The process to revise the SIP is currently underway. Proposed changes include clarifying the appropriate form of effluent toxicity limits in NPDES permits and general expansion and standardization of toxicity control implementation related to the NPDES permitting process. Since the toxicity control provisions in the SIP are under revision it is infeasible to develop numeric effluent limitations for chronic toxicity. Therefore, this Order requires that the Discharger meet best management practices for compliance with the Basin Plan's narrative toxicity objective, as allowed under 40 CFR 122.44(k).

To ensure compliance with the Basin Plan's narrative toxicity objective, the Discharger is required to conduct chronic whole effluent toxicity testing, as specified in the Monitoring and Reporting Program (Attachment E, Section V.). Furthermore, Special Provisions VI.C.2.a. of this Order requires the Discharger to investigate the causes of, and identify and implement corrective actions to reduce or eliminate effluent toxicity. If the discharge demonstrates a pattern of toxicity exceeding the numeric toxicity monitoring trigger, the Discharger is required to initiate a Toxicity Reduction Evaluation (TRE), in accordance with an approved TRE work plan. The numeric toxicity monitoring trigger is not an effluent limitation, it is the toxicity threshold at which the Discharger is required to perform accelerated chronic toxicity monitoring, as well as, the threshold to initiate a TRE if a pattern of effluent toxicity has been demonstrated.

D. Final Effluent Limitations

1. Mass-based Effluent Limitations.

Title 40 CFR 122.45(f)(1) requires effluent limitations be expressed in terms of mass, with some exceptions, and 40 CFR 122.45(f)(2) allows pollutants that are limited in terms of mass to additionally be limited in terms of other units of measurement. This Order includes effluent limitations expressed in terms of mass and concentration. In addition, pursuant to the exceptions to mass limitations provided in 40 CFR

2002-0122 and R4-2002-0124 for Los Coyotes and Long Beach Wastewater Reclamation Plants Issued by the California Regional Water Quality Control Board, Los Angeles Region SWRCB/OCC FILES A-1496 AND 1496(a)

122.45(f)(1), some effluent limitations are not expressed in terms of mass, such as pH and temperature, and when the applicable standards are expressed in terms of concentration (e.g. CTR criteria and MCLs) and mass limitations are not necessary to protect the beneficial uses of the receiving water.

Mass-based effluent limitations were calculated based upon the permitted average daily discharge flow allowed in Section IV.A.1.g. of the Limitations and Discharge Requirements.

2. Averaging Periods for Effluent Limitations.

Title 40 CFR 122.45 (d) requires average weekly and average monthly discharge limitations for publicly owned treatment works (POTWs) unless impracticable. However, for toxic pollutants and pollutant parameters in water quality permitting, the US EPA recommends the use of a maximum daily effluent limitation in lieu of average weekly effluent limitations for two reasons. *"First, the basis for the 7-day average for POTWs derives from the secondary treatment requirements. This basis is not related to the need for assuring achievement of water quality standards. Second, a 7-day average, which could comprise up to seven or more daily samples, could average out peak toxic concentrations and therefore the discharge's potential for causing acute toxic effects would be missed."* (TSD, pg. 96) This Order utilizes maximum daily effluent limitations in lieu of average weekly effluent limitations for chlorine residual², copper, zinc, cyanide, dichlorobromomethane, chlorodibromomethane, alpha-BHC, beta-BHC, and gamma-BHC as recommended by the TSD for the achievement of water quality standards and for the protection of the beneficial uses of the receiving stream. Furthermore, for BOD, TSS, pH, and coliform, weekly average effluent limitations have been replaced or supplemented with effluent limitations utilizing shorter averaging periods. The rationale for using shorter averaging periods for these constituents is discussed in Attachment F, Section IV.C.3., above.

3. Satisfaction of Anti-Backsliding Requirements.

All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order.

4. Satisfaction of Antidegradation Policy

The permitted discharge is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution 68-16. Compliance with these requirements will result in the use of best practicable treatment or control of the discharge. The impact on existing water quality will be insignificant.

² This Order applies the USEPA National Ambient Water Quality Criteria for chlorine directly as effluent limitations (1 hour average, acute, and 4-day average, chronic). See Section IV.C.3., above, for rational regarding the chlorine residual effluent limitations.

5. Summary of Final Effluent Limitations - Discharge Point D-001

Table F-21. Summary of Final Effluent Limitations

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instant. Minimum	Instant. Maximum	
Average Dry Weather Flow	mgd	4.0	--	--	--	--	Design
BOD ⁽¹⁾	mg/L	10	15	30	--	--	Tech.
	lbs/day ²	334	500	1,001	--	--	Tech.
Total Suspended Solids	mg/L	10	15	30	--	--	Tech.
	lbs/day ²	334	500	1,001	--	--	Tech.
Removal	85% removal BOD ₅ and TSS						Tech.
pH	--	--	--	--	6.0	9.0	Tech.
Copper, Total Recoverable	ug/L	13.7	--	27.4	--	--	CTR
Zinc, Total Recoverable	ug/L	57.8	--	115.9	--	--	BP
Cyanide, Total (as CN)	ug/L	31.8	--	63.7	--	--	CTR
Chlorodibromomethane	ug/L	12.1	--	24.2	--	--	CTR
Dichlorobromomethane	ug/L	18.1	--	36.2	--	--	CTR
alpha-BHC	ug/L	0.11	--	0.21	--	--	CTR
beta-BHC	ug/L	0.15	--	0.30	--	--	BP
gamma-BHC	ug/L	0.81	--	1.62	--	--	CTR
Chlorine Residual	mg/L	--	0.01 ³	0.02 ⁴	--	--	USEPA
Total Coliform Organisms	MPN/100 mL	23 ⁵	--	500	--	--	BP/DHS

¹ 5-day, 20°C Biochemical Oxygen Demand (BOD)

² Based upon a design dry weather treatment capacity of 4.0 mgd, applicable from May through September

³ 4-day average

⁴ 1-hour average

⁵ 30-day median

E. Interim Effluent Limitations

1. **Copper.** The SIP, section 2.2.1, requires that if a compliance schedule is granted for a CTR or NTR constituent, the Regional Water Board shall establish interim requirements and dates for their achievement in the NPDES permit. The interim limitations must be based on current treatment plant performance or existing permit limitations, whichever is more stringent. The State Water Board has held that the SIP may be used as guidance for non-CTR constituents. Therefore, the SIP requirement for interim effluent limitations has been applied to both CTR and non-CTR constituents in this Order.

The interim limitation for copper in this Order is based on the current treatment plant performance. In developing the interim limitation, where there are ten sampling data points or more, sampling and laboratory variability is accounted for by establishing interim limits that are based on normally distributed data where 99.9% of the data points will lie within 3.3 standard deviations of the mean (*Basic Statistical Methods for Engineers and Scientists, Kennedy and Neville, Harper and Row*). Therefore, the interim limitations in this Order are established as the mean plus 3.3 standard deviations of the available data.

When there are less than ten sampling data points available, the *Technical Support Document for Water Quality- Based Toxics Control ((EPA/505/2-90-001), TSD)* recommends a coefficient of variation of 0.6 be utilized as representative of wastewater effluent sampling. The TSD recognizes that a minimum of ten data points is necessary to conduct a valid statistical analysis. The multipliers contained in Table 5-2 of the TSD are used to determine a maximum daily limitation and average monthly limitation based on a long-term average objective. In this case, the long-term average objective is to maintain, at a minimum, the current plant performance level. Therefore, when there are less than ten sampling points for a constituent, interim limitations are based on 3.11 times the maximum observed effluent concentration to obtain the daily maximum interim limitation (MDEL) and 1.90 times the maximum observed effluent concentration to obtain the average monthly interim limitation (AMEL) (TSD, Table 5-2). The AMEL and MDEL multipliers are based on the 99th percentile confidence interval in recognition of the discharger's concern that actual copper effluent concentration variability is greater than reflected in the limited sample set available at this time. The Discharger can currently meet the final MDEL for copper but is unable to meet the final AMEL for copper. Therefore, only an interim limitation for the AMEL has been calculated.

The Regional Water Board finds that the Discharger can undertake source control and treatment plant measures to maintain compliance with the interim limitations included in this Order. Interim limitations are established when compliance with effluent limitations cannot be achieved by the existing discharge. Discharge of constituents in concentrations in excess of the final effluent limitations, but in compliance with the interim effluent limitations, can significantly degrade water quality and adversely affect the beneficial uses of the receiving stream on a long-

term basis. The interim limitations, however, establish an enforceable ceiling concentration until compliance with the effluent limitation can be achieved.

Table F-8 summarizes the calculations of the interim effluent limitations for copper:

Parameter	MEC	Mean	Std. Dev.	# of Samples	Interim Limitation
Copper	15.3	14.1	0.785	9	29.1

2. **Zinc.** In accordance with the Regional Board's Policy for *Application of Water Quality Objectives*, presented in Chapter IV of the Basin Plan, schedules for compliance with final effluent limitations, which are based on water quality criteria adopted before 25 September 1995, cannot be authorized. Here, as the final average monthly effluent limit for zinc is based on water quality criteria of the Basin Plan adopted before 25 September 1995, a compliance schedule and interim limits have not been considered, and the final average monthly effluent limit for zinc will become immediately effective upon adoption of the Order. However, the Regional Board may adopt other Orders, such as a Cease and Desist Order, allowing a period of time to fully comply with the average monthly effluent limit for zinc.

F. Land Discharge Specifications

The Land Discharge Specifications are necessary to protect the beneficial uses of the groundwater.

G. Reclamation Specifications

Treated wastewater discharged for reclamation is regulated under separate water reclamation requirements and must meet the requirements of California Code of Regulations, Title 22.

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

Basin Plan water quality objectives to protect the beneficial uses of surface water and groundwater include numeric objectives and narrative objectives, including objectives for chemical constituents, toxicity, and tastes and odors. The toxicity objective requires that surface water and groundwater be maintained free of toxic substances in concentrations that produce detrimental physiological responses in humans, plants, animals, or aquatic life. The chemical constituent objective requires that surface water and groundwater shall not contain chemical constituents in concentrations that adversely affect any beneficial use or that exceed the maximum contaminant levels (MCLs) in Title 22, CCR. The tastes and odors objective states that surface water and groundwater shall not contain taste- or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses. The Basin Plan requires the application of the most stringent objective necessary to ensure that surface water and groundwater do not contain chemical constituents, toxic

substances, radionuclides, or taste and odor producing substances in concentrations that adversely affect domestic drinking water supply, agricultural supply, or any other beneficial use.

A. Surface Water

1. CWA section 303(a-c), requires states to adopt water quality standards, including criteria where they are necessary to protect beneficial uses. The Regional Water Board adopted water quality criteria as water quality objectives in the Basin Plan. The Basin Plan states that "*[t]he numerical and narrative water quality objectives define the least stringent standards that the Regional Board will apply to regional waters in order to protect the beneficial uses.*" The Basin Plan includes numeric and narrative water quality objectives for various beneficial uses and water bodies. This Order contains Receiving Surface Water Limitations based on the Basin Plan numerical and narrative water quality objectives for bacteria, biostimulatory substances, chemical constituents, color, dissolved oxygen, floating material, oil and grease, pH, pesticides, radioactivity, salinity, sediment, settleable material, suspended material, tastes and odors, temperature, toxicity, and turbidity.

Numeric Basin Plan objectives for bacteria, dissolved oxygen, pH, temperature, and turbidity are applicable to this discharge and have been incorporated as Receiving Surface Water Limitations. Rational for these numeric receiving surface water limitations are as follows:

- a. **Bacteria.** The Basin Plan includes a water quality objective that "*[I]n water designated for contact recreation (REC-1), the fecal coliform concentration based on a minimum of not less than five samples for any 30-day period shall not exceed a geometric mean of 200/100 ml, nor shall more than ten percent of the total number of samples taken during any 30-day period exceed 400/100 ml.*" Numeric Receiving Water Limitations for bacteria are included in this Order and are based on the Basin Plan objective.
- b. **Biostimulatory Substances.** The Basin Plan includes a water quality objective that "*[W]ater shall not contain biostimulatory substances which promote aquatic growths in concentrations that cause nuisance or adversely affect beneficial uses.*" Receiving Water Limitations for biostimulatory substances are included in this Order and are based on the Basin Plan objective.
- c. **Color.** The Basin Plan includes a water quality objective that "*[W]ater shall be free of discoloration that causes nuisance or adversely affects beneficial uses.*" Receiving Water Limitations for color are included in this Order and are based on the Basin Plan objective.
- d. **Chemical Constituents.** The Basin Plan includes a water quality objective that "*[W]aters shall not contain chemical constituents in concentrations that adversely affect beneficial uses.*" Receiving Water Limitations for chemical constituents are included in this Order and are based on the Basin Plan objective.

- e. **Dissolved Oxygen.** The Sacramento River has been designated as having the beneficial use of cold freshwater aquatic habitat (COLD). For water bodies designated as having COLD as a beneficial use, the Basin Plan includes a water quality objective of maintaining a minimum of 7.0 mg/L of dissolved oxygen. Since the beneficial use of COLD does apply to the Sacramento River, a receiving water limitation of 7.0 mg/L for dissolved oxygen was included in this Order.

In addition, the Basin Plan includes a site-specific dissolved oxygen water quality objective of 9.0 mg/L for this reach of the Sacramento River from 1 June to 31 August. For this reason a receiving water limitation of 9.0 mg/L for dissolved oxygen from 1 June to 31 August is included in the Order.

For surface water bodies outside of the Delta, the Basin Plan includes the water quality objective that “*...the monthly median of the mean daily dissolved oxygen (DO) concentration shall not fall below 85 percent of saturation in the main water mass, and the 95 percentile concentration shall not fall below 75 percent of saturation.*” This objective was included as a receiving water limitation in this Order.

- f. **Floating Material.** The Basin Plan includes a water quality objective that “[W]ater shall not contain floating material in amounts that cause nuisance or adversely affect beneficial uses.” Receiving Water Limitations for floating material are included in this Order and are based on the Basin Plan objective.
- g. **Oil and Grease.** The Basin Plan includes a water quality objective that “[W]aters shall not contain oils, greases, waxes, or other materials in concentrations that cause nuisance, result in a visible film or coating on the surface of the water or on objects in the water, or otherwise adversely affect beneficial uses.” Receiving Water Limitations for oil and grease are included in this Order and are based on the Basin Plan objective.
- h. **pH.** The Basin Plan includes water quality objective that “[T]he pH shall not be depressed below 6.5 nor raised above 8.5. Changes in normal ambient pH levels shall not exceed 0.5 in fresh waters with designated COLD or WARM beneficial uses” This Order includes receiving water limitations for both pH range and pH change.

The Basin Plan allows an appropriate averaging period for pH change in the receiving stream. Since there is no technical information available that indicates that aquatic organisms are adversely affected by shifts in pH within the 6.5 to 8.5 range, an averaging period is considered appropriate and a monthly averaging period for determining compliance with the 0.5 receiving water pH limitation is included in this Order.

- i. **Pesticides.** The Basin Plan includes a water quality objective for pesticides beginning on page III-6.00. Receiving Water Limitations for pesticides are included in this Order and are based on the Basin Plan objective.

- j. **Radioactivity.** The Basin Plan includes a water quality objective that “[R]adionuclides shall not be present in concentrations that are harmful to human, plant, animal or aquatic life nor that result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal or aquatic life.” The Basin Plan states further that “[A]t a minimum, waters designated for use as domestic or municipal supply (MUN) shall not contain concentrations of radionuclides in excess of the maximum contaminant levels (MCLs) specified in Table 4 (MCL Radioactivity) of Section 64443 of Title 22 of the California Code of Regulations...” Receiving Water Limitations for radioactivity are included in this Order and are based on the Basin Plan objective.
- k. **Sediment.** The Basin Plan includes a water quality objective that “[T]he suspended sediment load and suspended sediment discharge rate of surface waters shall not be altered in such a manner as to cause nuisance or adversely affect beneficial uses” Receiving Water Limitations for suspended sediments are included in this Order and are based on the Basin Plan objective.
- l. **Settleable Material.** The Basin Plan includes a water quality objective that “[W]aters shall not contain substances in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.” Receiving Water Limitations for settleable material are included in this Order and are based on the Basin Plan objective.
- m. **Suspended Material.** The Basin Plan includes a water quality objective that “[W]aters shall not contain suspended material in concentrations that cause nuisance or adversely affect beneficial uses.” Receiving Water Limitations for suspended material are included in this Order and are based on the Basin Plan objective.
- n. **Taste and Odors.** The Basin Plan includes a water quality objective that “[W]ater shall not contain taste- or odor-producing substances in concentrations that impart undesirable tastes or odors to domestic or municipal water supplies or to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.” Receiving Water Limitations for taste- or odor-producing substances are included in this Order and are based on the Basin Plan objective.
- o. **Temperature.** The Sacramento River has the beneficial uses of both COLD and WARM. The Basin Plan includes the objective that “[a]t no time or place shall the temperature of COLD or WARM intrastate waters be increased more than 5°F above natural receiving water temperature.” In addition, the Basin Plan includes a site-specific objective for this reach of the Sacramento River that limits an increase in natural temperature to higher than 56°F when such an increase will be detrimental to the fishery. This Order includes a receiving water limitation based on these objectives.

- p. **Toxicity.** The Basin Plan includes a water quality objective that “[A]ll waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.” Receiving Water Limitations for toxicity are included in this Order and are based on the Basin Plan objective.
- q. **Turbidity.** The Basin Plan includes a water quality objective that “[I]ncreases in turbidity attributable to controllable water quality factors shall not exceed the following limits:
- *Where natural turbidity is between 0 and 5 Nephelometric Turbidity Units (NTUs), increases shall not exceed 1 NTU.*
 - *Where natural turbidity is between 5 and 50 NTUs, increases shall not exceed 20 percent.*
 - *Where natural turbidity is between 50 and 100 NTUs, increases shall not exceed 10 NTUs.*
 - *Where natural turbidity is greater than 100 NTUs, increases shall not exceed 10 percent.”*

A numeric Receiving Surface Water Limitation for turbidity is included in this Order and is based on the Basin Plan objective for turbidity.

B. Groundwater

1. The beneficial uses of the underlying ground water are municipal and domestic supply, industrial service supply, industrial process supply, and agricultural supply.
2. Basin Plan water quality objectives include narrative objectives for chemical constituents, tastes and odors, and toxicity of groundwater. The toxicity objective requires that groundwater be maintained free of toxic substances in concentrations that produce detrimental physiological responses in humans, plants, animals, or aquatic life. The chemical constituent objective states groundwater shall not contain chemical constituents in concentrations that adversely affect any beneficial use. The tastes and odors objective prohibits taste- or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses. The Basin Plan also establishes numerical water quality objectives for chemical constituents and radioactivity in groundwaters designated as municipal supply. These include, at a minimum, compliance with MCLs in Title 22 of the CCR. The bacteria objective prohibits coliform organisms at or above 2.2 MPN/100 ml. The Basin Plan requires the application of the most stringent objective necessary to ensure that waters do not contain chemical constituents, toxic substances, radionuclides, taste- or odor-producing substances, or bacteria in concentrations that adversely affect municipal or domestic supply, agricultural supply, industrial supply or some other beneficial use.

3. Groundwater limitations are required to protect the beneficial uses of the underlying groundwater.

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP), Attachment E of this Order, establishes monitoring and reporting requirements to implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this facility.

A. Influent Monitoring

1. Influent monitoring is required to collect data on the characteristics of the wastewater and to assess compliance with effluent limitations (e.g., BOD and TSS reduction requirements).

B. Effluent Monitoring

1. Pursuant to the requirements of 40 CFR §122.44(i)(2) effluent monitoring is required for all constituents with effluent limitations. Effluent monitoring is necessary to assess compliance with effluent limitations, assess the effectiveness of the treatment process, and to assess the impacts of the discharge on the receiving stream and groundwater.
2. The SIP states that if “*...all reported detection limits of the pollutant in the effluent are greater than or equal to the C [water quality criterion or objective] value, the RWQCB [Regional Water Board] shall establish interim requirements...that require additional monitoring for the pollutant....*” All reported detection limits for acrylonitrile, 1,1-dichloroethylene, pentachlorophenol, benzidine, benzo (a) anthracene, benzo (a) pyrene, benzo (b) fluoranthene, benzo (k) fluoranthene, bis (2-chloroethyl) ether, chrysene, dibenzo (a, h) anthracene, 3,3 dichlorobenzidine, 2,4-dinitrotoluene, 1,2-diphenylhydrazine, hexachlorobenzene, hexachloroethane, indeno (1,2,3-cd) pyrene, n-nitrosodimethylamine, n-nitrosodi-n-propylamine, aldrin, delta-bhc, chlordane, 4,4'-ddt, 4,4'-dde, 4,4'-ddd, dieldrin, endrin aldehyde, heptachlor, heptachlor epoxide, PCB 1016, PCB 1221, PCB 1232, PCB 1242, PCB 1248, PCB 1254, PCB 1260, and toxaphene are greater than or equal to corresponding applicable water quality criteria or objectives. Monitoring for these constituents has been included in this Order in accordance with the SIP.
3. Effluent monitoring for electrical conductivity, aluminum, ammonia, nitrate, and nitrite are necessary to assess whether there is a reasonable potential for an exceedence of a water quality criteria/objective in the receiving water.

C. Whole Effluent Toxicity Testing Requirements

1. **Acute Toxicity.** Quarterly 96-hour bioassay testing is required to demonstrate compliance with the effluent limitation for acute toxicity.
2. **Chronic Toxicity.** Annual chronic whole effluent toxicity testing is required in order to demonstrate compliance with the Basin Plan's narrative toxicity objective.

D. Receiving Water Monitoring

1. Surface Water

- a. Receiving water monitoring is necessary to assess compliance with receiving water limitations and to assess the impacts of the discharge on the receiving stream.
- b. Receiving water monitoring for total and dissolved concentrations of cadmium, copper, and zinc are necessary to assess the site-specific metal translators and to comply with the TMDL water management study.

2. Groundwater – Not Applicable

E. Other Monitoring Requirements

1. Biosolids Monitoring

Biosolids monitoring is required to ensure compliance with the biosolids disposal requirements (Special Provisions VI.C.6.a.). Biosolids disposal requirements are imposed pursuant to 40 CFR Part 503 to protect public health and prevent groundwater degradation.

2. Water Supply Monitoring

Water supply monitoring is required to evaluate the source of constituents in the wastewater.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42.

Section 122.41(a)(1) and (b) through (n) establish conditions that apply to all State-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. Section 123.25(a)(12) allows the state to omit or modify conditions to impose more stringent requirements. In accordance with section 123.25, this Order omits federal conditions that address enforcement authority specified in sections 122.41(j)(5) and (k)(2) because the enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates by reference Water Code section 13387(e).

B. Special Provisions

1. Reopener Provisions

- a. **Pollution Prevention.** This Order requires the Discharger prepare pollution prevention plans following CWC section 13263.3(d)(3) for copper and zinc. This reopener provision allows the Regional Water Board to reopen this Order for addition and/or modification of effluent limitations and requirements for these constituents based on a review of the pollution prevention plans.
- b. **Whole Effluent Toxicity.** This Order requires the Discharger to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity through a Toxicity Reduction Evaluation (TRE). This Order may be reopened to include a numeric chronic toxicity limitation, a new acute toxicity limitation, and/or a limitation for a specific toxicant identified in the TRE. Additionally, if a numeric chronic toxicity water quality objective is adopted by the State Water Board, this Order may be reopened to include a numeric chronic toxicity limitation based on that objective.
- c. **Water Effects Ratio (WER) and Metal Translators.** A default WER of 1.0 has been used in this Order for calculating CTR criteria for applicable priority pollutant inorganic constituents. In addition, site-specific dissolved-to-total metal translators have been used to convert water quality objectives from dissolved to total recoverable when developing effluent limitations for copper and zinc. If the Discharger performs studies to determine site-specific WERs and/or additional site-specific dissolved-to-total metal translators, this Order may be reopened to modify the effluent limitations for the applicable inorganic constituents.
- d. **Technical Studies.** The Discharger may perform technical studies in order to demonstrate and justify a change or modification of effluent limitations. This Order may be reopened for the addition and/or modification of effluent limitations and requirements.

2. Special Studies and Additional Monitoring Requirements

- a. **Chronic Whole Effluent Toxicity Requirements.** The Basin Plan contains a narrative toxicity objective that states, "All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in

human, plant, animal, or aquatic life." (Basin Plan at III-8.00.) Adequate WET data is not available to determine if the discharge has reasonable potential to cause or contribute to an in-stream excursion above of the Basin Plan's narrative toxicity objective. Attachment E of this Order requires annual chronic WET monitoring for demonstration of compliance with the narrative toxicity objective.

In addition to WET monitoring, this provision requires the Discharger to submit to the Regional Water Board an Initial Investigative TRE Work Plan for approval by the Executive Officer, to ensure the Discharger has a plan to immediately move forward with the initial tiers of a TRE, in the event effluent toxicity is encountered in the future. The provision also includes a numeric toxicity monitoring trigger and requirements for accelerated monitoring, as well as, requirements for TRE initiation if a pattern of toxicity is demonstrated.

Monitoring Trigger. A numeric toxicity monitoring trigger of > 10 TUc (where TUc = 100/NOEC) is applied in the provision, because this Order does allow dilution for the chronic condition. Minimum dilution credit to be applied is 39 parts of receiving water to 1 part effluent resulting in a theoretical allowance TUc of 39. The discharge showed no chronic toxicity at 100% effluent during the past permitted cycle. Therefore, based on best professional judgment, a cap of 10 to 1 dilution has been applied, and a monitoring trigger of greater than 10 TUc has been applied.

Accelerated Monitoring. The provision requires accelerated WET testing when a regular WET test result exceeds the monitoring trigger. The purpose of accelerated monitoring is to determine, in an expedient manner, whether there is a pattern of toxicity before requiring the implementation of a TRE. Due to possible seasonality of the toxicity, the accelerated monitoring should be performed in a timely manner, preferably taking no more than 2 to 3 months to complete.


The provision requires accelerated monitoring consisting of four chronic toxicity tests every two weeks using the species that exhibited toxicity. Guidance regarding accelerated monitoring and TRE initiation is provided in the *Technical Support Document for Water Quality-based Toxics Control, EPA/505/2-90-001, March 1991* (TSD). The TSD at page 118 states, "EPA recommends if toxicity is repeatedly or periodically present at levels above effluent limits more than 20 percent of the time, a TRE should be required." Therefore, four accelerated monitoring tests are required in this provision. If no toxicity is demonstrated in the four accelerated tests, then it demonstrates that toxicity is not present at levels above the monitoring trigger more than 20 percent of the time (only 1 of 5 tests are toxic, including the initial test). However, notwithstanding the accelerated monitoring results, if there is adequate evidence of a pattern of effluent toxicity (i.e. toxicity present exceeding the monitoring trigger more than 20 percent of the time), the Executive Officer may require that the Discharger initiate a TRE.

See the WET Accelerated Monitoring Flow Chart (Figure F-1), below, for further clarification of the accelerated monitoring requirements and for the decision points for determining the need for TRE initiation.

TRE Guidance. The Discharger is required to prepare a TRE Work Plan in accordance with USEPA guidance. Numerous guidance documents are available, as identified below:

- *Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants*, (EPA/833B-99/002), August 1999.
- Generalized Methodology for Conducting Industrial TREs, (*EPA/600/2-88/070*), April 1989.
- *Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures*, Second Edition, EPA 600/6-91/005F, February 1991.
- *Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I*, EPA 600/6-91/005F, May 1992.
- *Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting acute and Chronic Toxicity*, Second Edition, EPA 600/R-92/080, September 1993.
- *Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity*, Second Edition, EPA 600/R-92/081, September 1993.
- *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, Fifth Edition, EPA-821-R-02-012, October 2002.
- *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition, EPA-821-R-02-013, October 2002.
- *Technical Support Document for Water Quality-based Toxics Control*, EPA/505/2-90-001, March 1991

Figure F-1
WET Accelerated Monitoring Flow Chart



- b. **Groundwater Monitoring (Special Provisions VI.C.2.d.) - Not Applicable**
- c. **Mixing Zone and Dilution Study.** The mixing zone and dilution study is required to determine the actual mixing and dilution that is achievable in the receiving water.
- d. **Site-Specific Translator Study.** The translator study is required in order to continue to refine the current site-specific metal translators as the remediation efforts to decrease cadmium, copper, and zinc loadings to the Sacramento River continue upstream at Iron Mountain Mine.

3. Best Management Practices and Pollution Prevention

- a. **Pollution Prevention Plan (PPP) for Copper.** A PPP for copper is required in this Order per CWC section 13263.3(d)(1)(D) as part of the interim effluent limitation for copper. The interim average monthly effluent limitations for copper limits the mass loading to current levels. The PPP shall be developed in conformance with CWC section 13263.3(d)(3) as outlined in subsection b., below.
- b. **Pollution Prevention Plan (PPP) for Zinc.** A PPP for zinc is required in this Order per CWC section 13263.3(d)(1)(D). The PPP shall be developed in conformance with CWC section 13263.3(d)(3) as outlined in subsection b., below.
- c. **CWC section 13263.3(d)(3) Pollution Prevention Plans.** The pollution prevention plans required for copper shall, at minimum, meet the requirements outlined in CWC section 13263.3(d)(3). The minimum requirements for the pollution prevention plans include the following:
 - i. An estimate of all of the sources of a pollutant contributing, or potentially contributing, to the loadings of a pollutant in the treatment plant influent.
 - ii. An analysis of the methods that could be used to prevent the discharge of the pollutants into the Facility, including application of local limits to industrial or commercial dischargers regarding pollution prevention techniques, public education and outreach, or other innovative and alternative approaches to reduce discharges of the pollutant to the Facility. The analysis also shall identify sources, or potential sources, not within the ability or authority of the Discharger to control, such as pollutants in the potable water supply, airborne pollutants, pharmaceuticals, or pesticides, and estimate the magnitude of those sources, to the extent feasible.
 - iii. An estimate of load reductions that may be attained through the methods identified in subparagraph ii.
 - iv. A plan for monitoring the results of the pollution prevention program.

- v. A description of the tasks, cost, and time required to investigate and implement various elements in the pollution prevention plan.
 - vi. A statement of the Discharger's pollution prevention goals and strategies, including priorities for short-term and long-term action, and a description of the Discharger's intended pollution prevention activities for the immediate future.
 - vii. A description of the Discharger's existing pollution prevention programs.
 - viii. An analysis, to the extent feasible, of any adverse environmental impacts, including cross-media impacts or substitute chemicals that may result from the implementation of the pollution prevention program.
 - ix. An analysis, to the extent feasible, of the costs and benefits that may be incurred to implement the pollution prevention program.
- d. **Salinity Evaluation and Minimization Plan.** In an effort to minimize salt loading to the Sacramento River, this Order requires the Discharger to submit a salinity evaluation and minimization plan to address sources of salinity from the Facility.
- e. **Performance Evaluation Report.** Final effluent limitations for gamma-BHC are included in the Order. Based on analysis of influent and effluent characteristics, the treatment facility has the capability to discharge this constituent at concentrations significantly less than the final effluent limitation. Therefore, to ensure that influent water quality and treatment plant removal efficiencies for this constituent are maintained, an AMEL performance evaluation trigger is utilized as described in the Fact Sheet, Section IV.C.3. The Discharger shall prepare a performance evaluation report when the AMEL performance trigger is exceeded.

4. Construction, Operation, and Maintenance Specifications – Not Applicable

5. Special Provisions for Municipal Facilities (POTWs Only)

a. Pretreatment Requirements.

- i. The Federal Clean Water Act, Section 307(b), and Federal Regulations, 40 CFR Part 403, require publicly owned treatment works to develop an acceptable industrial pretreatment program. A pretreatment program is required to prevent the introduction of pollutants, which will interfere with treatment plant operations or sludge disposal, and prevent pass through of pollutants that exceed water quality objectives, standards or permit limitations. Pretreatment requirements are imposed pursuant to 40 CFR Part 403.

- ii. The Discharger shall implement and enforce its approved pretreatment program and is an enforceable condition of this Order. If the Discharger fails to perform the pretreatment functions, the Regional Water Board, the State Water Board or the U.S. EPA may take enforcement actions against the Discharger as authorized by the CWA.

b. Sanitary Sewer Overflow Requirements.

On May 2, 2006, the State Water Board adopted State Water Board Order 2006-0003, a Statewide General WDR for Sanitary Sewer Systems. The Discharger shall be subject to the requirements of Order 2006-0003 and any future revisions thereto. Order 2006-0003 requires that all public agencies that currently own or operate sanitary sewer systems apply for coverage under the General WDR.

6. Other Special Provisions

- a. Final effluent limitations for gamma-BHC are included in the Order. Based on analysis of influent and effluent characteristics, the treatment facility has the capability to discharge this constituent at concentrations significantly less than the final effluent limitations. Therefore, to ensure that influent water quality and treatment plant removal efficiencies for this constituent are maintained, an AMEL performance evaluation trigger is utilized as described in Section IV.C.3..
- b. This Order requires the Discharger to use the best practicable treatment or control technique currently available to limit mineralization to no more than a reasonable increment.
- c. Recycled water shall meet the criteria contained in Chapter 3, Division 4, Title 22, California Code of Regulations (CCR) (Section 60301, et. seq.).
- d. All technical reports required herein that involve planning, investigation, evaluation, or design, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in California pursuant to California Business and Professions Code, Sections 6735, 7835, and 7835.1. To demonstrate compliance with Title 16, CCR, Sections 415 and 3065, all technical reports must contain a statement of the qualifications of the responsible registered professional(s). As required by these laws, completed technical reports must bear the signature(s) and seal(s) of the registered professional(s) in a manner such that all work can be clearly attributed to the professional responsible for the work.
- e. In the event the Discharger does not comply or will be unable to comply for any reason, with any prohibition or limitation contained in this Order, this Order requires the Discharger to notify the Regional Water Board by telephone (530) 224-4845 (or to the Regional Water Board staff engineer

assigned to the facility) within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing within five days, unless the Regional Water Board waives confirmation. The written notification shall include the information required by Federal Standard Provision [40 CFR §122.41(l)(6)(i)].

- f. Prior to making any change in the discharge point, place of use, or purpose of use of the wastewater, the Discharger must obtain approval of, or clearance from the State Water Resources Control Board (Division of Water Rights).

In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to this office.

To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order.

The request must contain the requesting entity's full legal name, the State of incorporation if a corporation, address and telephone number of the persons responsible for contact with the Regional Water Board and a statement. The statement shall comply with the signatory paragraph of Federal Standard Provision V.B.5 and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the California Water Code. Transfer shall be approved or disapproved in writing by the Executive Officer.

7. Compliance Schedules

The use and location of compliances schedules in the permit depends on the Discharger's ability to comply and the source of the applied water quality criteria.

- a. The Discharger submitted a request, and justification dated 1 May 2007, for a compliance schedule for copper and zinc. The compliance schedule justification included all items specified in Paragraph 3, items (a) through (d), of Section 2.1 of the SIP. This Order establishes a compliance schedule for the new, final, water quality-based effluent limitations for copper and requires full compliance by not later than 18 May 2010.
- b. The discharge requires the use of BPTC to maximize the initial dilution of the effluent with the receiving water. This requires a properly constructed and maintained effluent diffuser system.

VIII. PUBLIC PARTICIPATION

The California Regional Water Quality Control Board, Central Valley Region (Regional Water Board) is considering the issuance of waste discharge requirements (WDRs) that will serve as a National Pollutant Discharge Elimination System (NPDES) permit for the Stillwater Wastewater Treatment Facility. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

A. Notification of Interested Parties

The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Notification was provided through physical (including local newspaper announcement) and Internet posting.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments must be submitted either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Regional Water Board, written comments should be received at the Regional Water Board offices by 5:00 p.m. on 7 June 2007.

C. Public Hearing

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: 21/22 June 2007
Time: 8:30 am
Location: Regional Water Quality Control Board, Central Valley Region
11020 Sun Center Dr., Suite #200
Rancho Cordova, CA 95670

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is <http://www.waterboards.ca.gov/rwqcb5/> where you can access the current agenda for changes in dates and locations.

D. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

E. Information and Copying

The Report of Waste Discharge (RWD), related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling (530) 224-4845.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this Order should be directed to Stacy Gotham at (530) 224-4845.

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION**

ORDER NO. R5-2007-0059

**REQUIRING
CITY OF REDDING
STILLWATER WASTEWATER TREATMENT FACILITY
SHASTA COUNTY
TO
CEASE AND DESIST
FROM DISCHARGING CONTRARY TO REQUIREMENTS**

The California Regional Water Quality Control Board, Central Valley Region (hereafter referred to as Regional Board), finds:

1. On 21 June 2007, the Regional Board adopted Waste Discharge Requirements Order No. R5-2007-0058, (NPDES No. CA0082589) for the City of Redding, Stillwater Wastewater Treatment Facility, (hereafter Discharger). Waste Discharge Requirements Order No. R5-2007-0058 regulates the discharge of advanced secondary treated municipal wastewater to the Sacramento River.
2. Waste Discharge Requirements Order (WDRs) No. R5-2007-0058, Effluent Limitations A.1 includes effluent limitations for zinc as follows:
 - A. Effluent Limitations- Discharger Point D-001
 1. Final Effluent limitations – Discharge Point D-001

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Zinc, Total Recoverable	ug/L	57.8	--	115.9	--	--

3. The effluent limitations zinc is dependent on the hardness of the receiving water as shown in Attachment F of Order No. R5-2007-0058.
4. Zinc has been detected in the effluent at concentrations that have the reasonable potential to cause the receiving water to exceed applicable water quality standards for zinc.
5. The Discharger can meet the maximum daily effluent limitation (MDEL) for zinc but cannot meet the average monthly effluent limitation (AMEL) for zinc.
6. The Discharger has requested a time schedule to come into compliance with the zinc AMEL or to conduct studies, such as a mixing zone and dilution study, to demonstrate that the AMEL for zinc should be modified.

7. California Water Code (CWC) Section 13385(h) and (i) require the Regional Board to impose mandatory minimum penalties upon dischargers that violate certain effluent limitations. CWC Section 13385(j) exempts certain violations from the mandatory penalties. CWC Section 13385(j)(3) exempts the discharge from mandatory penalties "where the waste discharge is in compliance with either a cease and desist order issued pursuant to Section 13301 or a time schedule order issued pursuant to Section 13300 or Section 13308, if all the [specified] requirements are met."
8. In accordance with CWC 13385(j)(3), the Regional Board finds that the Discharger is not able to consistently comply with zinc AMEL contained in the Waste Discharge Requirements Order No. R5-2007-0058. The zinc AMEL is a new requirement that became applicable to the permit after the effective date of adoption of the waste discharge requirements, and after 1 July 2000, for which new or modified control measures are necessary in order to comply with the limitation, and the new or modified control measures cannot be completed, and put into operation within 30 calendar days. As the zinc limitation is based on existing Basin Plan water quality objectives that were adopted prior to 25 September 1995, a compliance schedule for this effluent limitations must be placed in a Cease and Desist Order.
9. The Discharger needs time to develop reasonable measures to achieve compliance with the AMEL for zinc. The Discharger may also conduct studies, such as a mixing zone and dilution study, to demonstrate that the final AMEL for zinc should be modified. The development of measures to achieve compliance and study periods require up to five (5) years from the effective date of the waste discharge requirements. Since the time schedule for completion of actions necessary to achieve full compliance exceeds one year, interim requirements are included in and by this Order. A time schedule for compliance is included in this Order. In accordance with CWC Section 13385(j)(3) this Order requires the Discharger to prepare and implement a pollution prevention plan pursuant to Section 13263.3(d)(3) of the CWC. Zinc may be able to be reduced through source control measures.
10. The interim limitation in this Order as an AMEL is based on the current operation and treatment practices. In developing the interim limitation, when there are less than ten sampling data points available, the USEPA Technical Support Document (TSD) recommends a coefficient of variation of 0.6 be utilized as representative of wastewater effluent sampling. The TSD recognizes that a minimum of ten data points is necessary to conduct a valid statistical analysis. The multipliers contained in Table 5-2 of the TSD are used to determine an AMEL based on a long-term average objective. In this case, the long-term average objective is to maintain, at a minimum, the current performance level. Therefore, when there are fewer than ten sampling points for a constituent, interim limitations are based on 1.90 times the maximum observed sampling point to obtain the AMEL. The data used to develop the interim effluent limitations are summarized in the following table:

INTERIM EFFLUENT LIMITATIONS	
	Total Zinc
Number of Samples	8
Coefficient of Variation (cv)	0.6
Minimum Concentration (ug/L)	41.1
Maximum Concentration (ug/L)	66.3
Multiplier	1.90
Interim (AMEL)	126 ug/L

11. Section 13301 of the California Water Code states, in part:

“When a regional board finds that a discharge of waste is taking place or threatening to take place in violation of requirements or discharge prohibitions prescribed by the regional board or the state board, the board may issue an order to cease and desist and direct that those persons not complying with the requirements or discharge prohibitions (a) comply forthwith, (b) comply in accordance with a time schedule set by the board, or (c) in the event of a threatened violation, take appropriate remedial or preventative action. In the event of an existing or threatened violation of waste discharge requirements in the operation of a community sewer system, cease and desist orders may restrict or prohibit the volume, type, or concentration of waste that might be added to such system by dischargers who did not discharge into the system prior to the issuance of the cease and desist order. Cease and desist orders may be issued directly by a board, after notice and hearing, or in accordance with the procedure set forth in Section 13302.”

12. Compliance with this Order exempts the Discharger from mandatory minimum penalties for violations of the zinc limitation, in accordance with CWC Section 13385 (j)(3).
13. On 21 June 2007, in Rancho Cordova, California, after due notice to the Discharger and all other affected persons, the Regional Board conducted a public hearing at which evidence was received to consider a Cease and Desist Order pursuant to CWC Section 13301 to establish a time schedule to achieve compliance with waste discharge requirements in Order No. R5-2007-0058.
14. Issuance of this Order is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000, et seq.), in accordance with Section 15321 (a)(2), Title 14, California Code of Regulations.
15. Any person adversely affected by this action of the Regional Board may petition the State Water Resources Control Board to review this action. The petition must be received by the State Water Resources Control Board, Office of the Chief Counsel, P.O. Box 100, Sacramento, CA 95812-0100, within 30 days of the date in which the action was taken. Copies of the law and regulations applicable to filing petitions will be provided on request.

IT IS HEREBY ORDERED PURSUANT TO CALIFORNIA WATER CODE SECTION 13301, THAT:

1. The Discharger shall comply with the following time schedule to assure compliance with Waste Discharge Requirements Order No. R5-2007-0058, Effluent Limitations A.1 for zinc:

Task	Compliance Date
1. Corrective Action Plan/Implementation Schedule. i. The Discharger shall submit to the Regional Water Board a corrective action plan and implementation schedule to assure compliance with the final effluent limitation for zinc.	i. 6 months after the effective date of Order R5-2007-0058.
2. Pollution Prevention Plan. This Discharger shall prepare and implement a pollution prevention plan for zinc, in accordance with CWC section 13263.3. i. A work plan and time schedule for preparation of a pollution prevention plan submitted for approval by the Executive Officer. ii. The Pollution Prevention Plan shall be completed and submitted to the Regional Water Board for approval by the Executive Officer. iii. Progress reports shall be submitted in accordance with the Monitoring and Reporting Program (Attachment E, Section X.D.1) in Order R5-2007-0058.	i. 6 months after the effective date of Order R5-2007-0058. ii. 2 years following work plan approval by the Executive Officer.

Task	Compliance Date
<p>3. Treatment Feasibility Study. The Discharger is required to perform an engineering treatment feasibility study examining the feasibility, costs, and benefits of different treatment options that may be required to remove zinc from the discharge.</p> <ul style="list-style-type: none"> i. A work plan and time schedule for preparation of the treatment feasibility study submitted for approval by the Executive Officer. ii. If studies to be conducted by the Discharger do not result in justifying alternate effluent limitations that can be met by current treatment facilities, then the treatment feasibility study shall be completed and submitted to the Regional Water Board for approval by the Executive Officer. iii. Progress reports shall be submitted in accordance with the Monitoring and Reporting Program (Attachment E, Section X.D.1) in Order R5-2007-0058. 	<ul style="list-style-type: none"> i. 6 months after the effective date of Order R5-2007-0058. ii. 2 years following work plan approval by the Executive Officer.
4. Implement selected operational measures and/or treatment upgrades. Final effluent limitation becomes effective.	18 May 2010.

2. The Discharger shall comply with the following interim effluent limitation for zinc. The final water quality based effluent limitations will become effective on **18 May 2010**. The average monthly effluent limitation cited in the table below will be the enforceable interim limitation until that time.

Parameter	Unit	Average Monthly Effluent Limitation
Zinc, Total Recoverable	ug/L	126

3. The Discharger shall monitor the effluent for zinc in accordance with the Monitoring and Reporting Program (Attachment E) in Order No. R5-2007-0058.
4. If, in the opinion of the Executive Officer, the Discharger fails to comply with the provisions of this Order, the Executive Officer may apply to the Attorney General for judicial enforcement or issue a complaint for Administrative Civil Liability. Additionally, the interim limit in this Order may be revoked, and the final limit contained in Order No. R5-2007-0058 will immediately become fully applicable.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 21 June 2007.

 PAMELA C. CREEDON, Executive Officer